

## CAHAYA HORNBILL SDN BHD

Lot 10591, Block 10 Kuala Baram Land District Pujut 7 Commercial Centre,  
Jalan Dato Sri Joseph Balan Seling, 98000, Miri Sarawak  
Tel: +6 085 656 655 | Fax +6 085 640 055 | Email: business@cahayahornbill.com.my

### EEBD Refil

Model : INTERSPIRO, Spiroscape-15  
Certificate Number : 4/00273/2025.SRV  
Report Number : CHSB-ES-25-16  
Service Date : February 5, 2025  
Next Service : February 5, 2026  
Serial Number : 42014 | 42025 | 43034 | 42030 | 42054 | 42013 | 42096

### Visual Check

#### 1. Face Piece

##### 1.1 Body Mask

- Rubber Condition
- Metal Parts

Good	Good
Good	Good

##### 1.2 Hood

- Rubber Condition
- Rubber Hose

Good
Good

##### 1.3 Lens (Visor Plastic)

- Condition

Good
------

##### 1.4 Nose Cup

- Valve Seat
- Valve Disc

Good
Good

##### 1.5 Inhalation Valve

- Spinder Gasket
- Valve Disc

Good
Good

##### 1.6 Exhalation Valve

- Valve Spring

Good
------

#### 2. Cylinder

15 mins 3.0 Liter 200 Bar

Refilled	210 Bar
----------	---------

#### 3. Gauge

Good	200 Bar
------	---------

### Operation Check

#### 1. Face Piece

Good
------

#### 2. Leak Test

Good
------

Cleaning & Disinfectant

Done
------

Remarks

- Ready for use
- Refer to manual book, this product should be regularly checked and serviced by a specialist
- Recommended next inspection 12 Months after date of inspection

Inspected By:

.....

Service Technician