

SPEAR3 RF System

Legacy System Architecture

Faya Wang

SLAC National Accelerator Laboratory

Version 4.0 • September 8, 2026

Document ID	Doc L
Tier	2 — Legacy System and Operational Reference
Status	Release candidate; pending named-engineer sign-off
Source	Designs/tex/L_legacy_system_architecture.tex

This document describes the SPEAR3 RF station *as built and as operated before the LLRF upgrade*. It is a reference for the existing plant, not a design proposal. Every technical statement is referenced to an original source document, an engineering drawing read directly, or the legacy source code; Section 21 records the verification basis section by section, and Section 20 lists the items that still require field verification.

Contents

Document Scope and Provenance	9
I SYSTEM OVERVIEW	11
1 Introduction and Purpose	11
1.1 PEP-II Heritage	11
2 System Architecture Overview	12
2.1 Top-Level System Block Diagram	12
2.2 Subsystem Summary	14
3 Physical Layout and Locations	17
4 Key System Parameters	21
4.1 RF System Parameters	21
4.2 HVPS Parameters	22
4.3 Representative Operating Point (June 2020)	23
II RF SIGNAL CHAIN	24
5 LLRF Controller (VXI System)	24
5.1 Overview	24
5.2 VXI Module Inventory	24
5.3 RFP (RF Processor) Module — Heart of the LLRF	26
5.4 IQA (IQ/Amplitude Detector) Modules	27
5.5 ARC/Interlock Module (AIM)	27
5.6 Feedback Loop Architecture	29
5.7 Communication Architecture	29
5.8 CLK (Clock and RF Reference Distribution) Module	31
6 Klystron and Drive System	34
6.1 Klystron	34
6.2 Drive Amplifier	36
7 Waveguide Distribution Network	36
7.1 Network Topology	36
7.2 Monitored RF Signals	36
8 RF Cavities and Tuner Assemblies	40
8.1 Cavity Specifications	40
8.2 Tuner Mechanical Assembly	40
III POWER SYSTEMS	46

9	High-Voltage Power Supply — Power Section	46
9.1	Architecture Overview	46
9.2	Power Conversion Chain	46
9.3	Key Component Specifications	46
9.4	Monitoring Signals (B514 → B118)	49
9.5	Stored Energy and Discharge Times	50
9.6	Control Power and Trigger Pulses	52
10	HVPS Control System — Hoffman Box (B118)	58
10.1	Overview	58
10.2	SLC-500 PLC Hardware Configuration	58
10.3	Control Functions	59
10.4	Analog Regulation	60
10.5	Terminal Strips and External Connections	60
11	Enerpro SCR Firing System	64
11.1	Overview	64
11.2	Current Hardware	64
11.3	Phase References	65
11.4	Legacy vs. Upgrade Firing Board	66
12	Arc Protection and Crowbar System	67
12.1	Four-Layer Protection Architecture	67
12.2	Klystron Arc Energy Budget	68
IV	PROTECTION AND SAFETY SYSTEMS	69
13	Personnel Protection System (PPS) Interface	69
13.1	Overview	69
13.2	Legacy PPS Chain 1: HV Contactor	69
13.3	Legacy PPS Chain 2: Ross Grounding Switch	69
13.4	Identified Issues	69
13.5	Relay Chain Details (Contactor Disconnect Panel)	71
13.6	PPS Dual-Chain Interaction and Roles	73
14	RF Machine Protection System (MPS)	74
14.1	Overview	74
14.2	Hardware Evolution	74
14.3	Protection Functions	75
14.4	MPS Wiring	75
15	Interlock Architecture and Signal Chain	75
15.1	Overview	75
15.2	Interlock Chassis	76
15.3	Complete Trip Chain	76
V	CONTROL SOFTWARE AND INSTRUMENTATION	79

16 EPICS IOC and SNL Software Architecture	79
16.1 IOC Platform	79
16.2 rf_states.st — Master Station State Machine	79
16.3 rf_hvps_loop.st — HVPS Supervisory Control	80
16.4 rf_tuner_loop.st — Cavity Tuner Control	80
16.5 rf_dac_loop.st — Drive/Gap Voltage DAC Control	80
16.6 rf_calib.st — Calibration Sequences	80
16.7 rf_msgs.st — Message Logging	80
17 Tuner Control System	80
17.1 Configuration Currently in Service	80
17.2 Planned Upgrade Configuration (not yet installed)	81
17.3 Tuner Motion Parameters	81
18 Diagnostics, Calibration and Monitoring	83
18.1 RF Signal Monitoring	83
18.2 HVPS Monitoring	83
18.3 Fault Recording	83
18.4 Calibration Data	84
18.5 Fault Data Availability and Analysis	84
VI INTEGRATION AND LEGACY CONSIDERATIONS	86
19 Cabling and Interconnections	86
19.1 Major Cable Runs	86
19.2 Connector Types	86
20 Known Issues, Limitations and Legacy Debt	86
20.1 Critical Issues	86
20.2 Documentation Gaps and Items Requiring Field Verification	87
20.3 Operational Workarounds	89
21 Verification Status	89
21.1 Appendix A — Source Document Reference Index	91
21.2 Appendix B — Symbol and Notation Conventions	98

List of Figures

1	Control-layer hierarchy of the legacy LLRF system, and the three interlock paths that can remove RF drive or high voltage. Redrawn from the 2003 system-overview slide; several values embedded in that slide were stale and have been corrected here against the original sources.	11
2	Top-level architecture of the legacy SPEAR3 RF station. Buildings: B132 klystron and control, B118 HVPS control, B514 HVPS power. Solid lines are electrical or hardwired connections; dashed lines are fiber optic.	16
3	LLRF control electronics in Room 101, Building B132 — the primary control location for the SPEAR3 RF station, housing the VXI crate, drive amplifier, and associated electronics racks	17
4	Building B132 — the klystron building housing the LLRF control electronics, drive amplifier, and RF MPS; the "132" building number is visible on the metal-clad corrugated exterior, with utility pipe runs, electrical panels, and the RF area access road in the foreground . . .	18
5	Building B514 — the high-voltage power supply substation housing the main transformer/rectifier tank, phase tank, and crowbar tank	18
6	HVPS grounding and termination tank located near Building B132 — cylindrical stainless/aluminum vessel with two high-voltage cable entries through flexible metallic conduit at the top; contains the Ross Engineering HV grounding switch, the Danfysik UltraStab DC-CT that measures klystron cathode current, a 3.333 mΩ (15 A = 50 mV) return-cable shunt, and the Pearson CT-110 wide-bandwidth current transformer used for klystron arc detection [R25]	19
7	RF cavities installed in the SPEAR3 storage ring tunnel (inward view) — showing the waveguide connections and cavity arrangement in the radiation enclosure	20
8	VXI crate running VxWorks RTOS in Building B132 — slot 0: EPICS IOC host (350 MHz MPC 750 PowerPC, VxWorks); slot 1: AB6008 scanner (DCM serial link); slot 2: CLK/RF distribution (clock and 471.187 MHz LO, requires ≥9 dBm RF input); slot 3: empty (GVF not installed); slot 4: RFP (RF Processor, direct feedback loop); slot 5: MPS Shutoff; slot 6: Link Passthru (also routes ripple-link backplane signal between IQA-1 and RFP); slot 7: IQA-1 (forward/reflected power, ripple-link source); slot 8: empty; slot 9: IQA-2 (cavity reflected); slot 10: empty; slot 11: IQA-3 (cavity probe); slot 12: AIM (arc/interlock) . . .	24
9	Rear of the LLRF VXI crate (Elma chassis, SLAC EEIP accepted 2019) in Building B132 — showing the dense cable plant of orange fiber optic cables (SCR ENABLE/CROWBAR/STATUS runs to B514), blue coaxial signal cables (IQA measurement inputs), and multi-conductor control wiring interconnecting the VXI modules	25
10	Communication architecture below the VXI IOC.	30
11	VXI crate slot map. Elma 13-slot chassis, SLAC EEIP accepted 2019, label B132-101-11-24. Slots 3, 8 and 10 are empty: the gap-voltage feed-forward module and the two comb-filter modules that PEP-II carries are not required by SPEAR3.	31
12	Clock module top-level inputs and outputs.	32
13	Clock module internal architecture.	33
14	Marconi klystron installed in Building B132 — 476 MHz CW klystron rated ~1.5 MW, showing the input waveguide, output waveguide, collector cooling, and solenoid focusing magnets	35

15	Klystron filament control chassis — manages the klystron heater/filament power and sequencing during startup and shutdown. The legacy chassis uses a motor-driven variac feeding a 10:1 step-down toroidal isolation transformer and a solid-state relay; it is enabled by the AIM Klys_Filament_On signal (§5.5) and its variac position is commanded through Allen-Bradley I/O [R5] §13.1	35
16	RF drive amplifier (KAW2051M12) in the B132 electronics rack — amplifies the LLRF drive signal to ~29 W (44.6 dBm) at ~476.3 MHz to drive the klystron input	36
17	Waveguide distribution network from klystron to cavities. Each magic-tee splits power equally between its P2 and P3 ports; the P4 difference port receives the sum of equal reflected power from the two cavities and directs it to a waveguide load.	37
18	AFT circulator — positioned between the klystron output and the magic-tee splitter network; routes reflected power from the load network away from the klystron to protect it from reflected energy	37
19	Magic-tee power splitter and bellows network on the SPEAR3 tunnel roof — the two-stage magic-tee arrangement divides RF power equally among all four cavities; flexible bellows sections accommodate thermal expansion in the waveguide runs	38
20	Waveguide distribution network routing RF power from the klystron output through the circulator, magic-tee splitters, and into the tunnel toward the four RF cavities	38
21	Water-cooled waveguide load — absorbs circulator dump power and magic-tee difference-port reflected power; water cooling carries away dissipated RF energy	39
22	High-conductivity water (HCW) cooling station behind the booster — supplies cooling water to the waveguide loads, absorbing reflected and dump power from the RF distribution network	39
23	PEP-II bare single-cell RF cavity — copper cavity body prior to installation of HOM dampers, tuner assembly, and waveguide couplers; the SPEAR3 cavities are of this same design	40
24	RF cavity assembly — cavity body with waveguide coupler, HOM damper waveguide stubs, and tuner plunger installed	42
25	Labeled RF cavity assembly — identifying the accelerating cell, input coupler, HOM damper ports, movable tuner plunger, probe port, and ceramic RF window	42
26	Movable tuner plunger assembly mounted below an RF cavity — the SLO-SYN stepper motor drives the plunger in/out to shift the cavity resonant frequency and hold it at the station RF frequency under varying beam loading	43
27	HOM (Higher-Order Mode) load at an E-plane mitre bend in the waveguide stub — absorbs parasitic cavity modes that would otherwise cause beam instability	43
28	HOM load at an H-plane mitre bend — the three HOM loads per cavity (E-mitre, H-mitre, and plate) together damp all significant parasitic resonances above the fundamental accelerating mode	44
29	Water-cooled HOM load plate — dissipates HOM power as heat, carried away by the high-conductivity water cooling system; each cavity has one of these plates in addition to the E- and H-mitre loads	44
30	Four RF cavities installed in the SPEAR3 storage ring tunnel (outward view, tuner side) — showing the complete cavity row with waveguide distribution network and interconnecting bellows runs visible	45
31	HVPS power conversion chain, substation to klystron cathode.	51

32	PEP-II Klystron Power Supply — annotated circuit schematic showing the complete power conversion chain from the 12.5 kV 3-phase input through the disconnect/breaker, phase-shifting transformer (T0), thyristor-controlled rectifier bridges (40 kV, 80 A), filter inductors, secondary rectifier stages, 8 μ F/30 kV filter capacitors, 500 Ω /1 kW filter resistors, 30 kV/30 A rectifiers, Crowbar, and Termination Tank to the Klystron (90 kV, 27 A). The intermediate DC levels labelled on the power stage outputs (−26 kV, −52 kV, −77 kV, −90 kV) are cumulative stage tap voltages , not the klystron operating point — see §4.2. The SPEAR3 HVPS is directly derived from this PEP-II design	52
33	HVPS2 main oil tank at Building B514 — this large oil-immersed enclosure houses the phase-shift transformer (T0), the two rectifier transformers (T1, T2), the two filter inductors, four filter capacitors with their eight resistors, and the main and filter diode rectifier stacks. The SCR phase controller and the SCR crowbar are mounted inside it in their own isolated oil tanks with oil-to-oil bushings, so either can be serviced without contaminating the main tank oil [R6]. SPEAR1 is an identical installation	53
34	Thyristor stack assemblies inside the HVPS2 phase tank, viewed into the side access opening with the cover removed — showing columns of Powerex T8K7 SCR thyristor discs (flat black cylinders) paired on copper bus bar assemblies with gate driver signal wiring; this photo was taken with SPEAR2 drained and accessed during the April 2026 scheduled downtime; SPEAR1 contains identical hardware	54
35	HVPS cable switch tank at Building B514 — provides the switchover connection between the SPEAR1 and SPEAR2 HVPS units and the klystron HV cable; allows the active unit to be changed without disconnecting the klystron high-voltage cable	55
36	HVPS2 installation at Building B514 — outdoor view from the switchgear area showing the large beige oil-filled power supply enclosures, "SPEAR 2" identification label, and "DANGER HIGH VOLTAGE" placard on the panel door; the cable trays, conduit runs, and grounding conductors are visible overhead; a "DO NOT ENERGIZE" lock-and-tag notice is visible at left (SPEAR2 is the off-duty unit during this April 2026 downtime); SPEAR1 forms an identical installation beside this	56
37	HVPS2 main oil tank being accessed from the top during the 2026 HVPS inspection — a rectangular access hatch in the ribbed/bolted steel tank top plate is open, revealing the internal copper bus bar assembly and SCR bridge structures below; three personnel are visible (two engineers working at the access opening, one documenting with a notebook); the orange fiber optic conduit visible at upper left routes the SCR ENABLE, CROWBAR, and STATUS fiber signals to the B118 Hoffman Box	57
38	HVPS controller Hoffman enclosures in Building B118. The two units are identical; one is energized and the other completely switched off, with the roles exchanged at each scheduled down.	58
39	HVPS controller Hoffman Box interior (SPEAR1) — the SLC-500 PLC rack (centre, CPU and I/O modules in slots 0 through 9+, labelled "SPEAR 1 RFHVPS"), four blue switching power supplies PS-1 to PS-4 (120 V $\times$ 2, 240 V and 5 V rails), the Enerpro FCOG6100 SCR firing board (dark blue PCB, lower centre), the analog regulation board (green PCB), and terminal strips TS-1 to TS-6 in the lower section; the BNC monitoring output panel is at lower right.	62
40	HVPS analog voltage regulation loop. The analog regulator card compares the PLC reference with the HVPS output voltage feedback and generates a <i>bipolar</i> error signal; that error is weighted and added to the PLC's <i>unipolar</i> feedforward output to form SIG HI. Power-line harmonics are clearly visible on the error signal in normal operation.	63
41	The two legacy PPS chains.	70

42	PPS contact readback trace across four drawings.	73
43	Complete trip chain, ordered by response time.	77
44	SLAC PEP-II Fast Interlock Chassis 340-308 in the B132 electronics rack — front panel showing FAULT RESET, LAMENT TIMEOUT, and BEAM ABORT controls (left cluster); 12-channel test port (TEST CH.); CH.1–CH.12 INPUT MONITOR test points (center); HVPS ON, SOLENOID ON, and FILAMENT ON status indicators; and J16 DETECTED KLYSTRON POWER coaxial input; the chassis provides sub-microsecond hardware protection by monitoring RF detector inputs and asserting SCR ENABLE removal and CROWBAR firing via fiber optic to the B514 HVPS on fault conditions	78
45	Allen-Bradley Cavity Tuner Motor Driver chassis (SLAC 340-315, SN08) in the B132 electronics rack — showing the SLC adapter module (leftmost, with COMM FAULT indicator and STATUS showing RUN/fault) followed by four AB 1746-HSTP1 STEPPER modules (each with RUN, CCW, CW, ERR, FLT indicators; green RUN lights confirm active communication), plus one additional STEPPER module at far right. This chassis is the motion controller currently driving all four cavity tuners; it is to be replaced by the Galil DMC-4143 when the LLRF upgrade project completes	82
46	Allen-Bradley Cavity Tuner Motor Driver chassis (SLAC 340-315, SN08) — closed front panel view showing the rack-mounted chassis faceplate with designation label, SLAC EEIP Accepted sticker, and two green power-health LEDs (+24V and +5V both illuminated); the chassis occupies approximately four rack units; slot position labels 08–13 from the adjacent rack frame are visible; the interior modules (SLC adapter and four 1746-HSTP1 stepper controllers) are shown in Figure 17-1	83

Document Scope and Provenance

Purpose

This document is the **Tier 2 legacy system reference** for the SPEAR3 RF system. It describes the complete RF system **as currently installed and operating** — the “legacy” configuration prior to the LLRF Upgrade Project. It covers every major subsystem from design concepts through real-world implementation: physical hardware, control electronics, software, protection systems, cabling, calibration data, and known limitations.

Doc L serves three critical functions:

1. **Upgrade baseline** — Provides the complete “as-built” reference against which upgrade designs (U1–U10) are specified
2. **Knowledge preservation** — Captures institutional knowledge about a system designed in 1997 (PEP-II era) before key personnel retire and obsolete hardware is removed
3. **Operational reference** — Consolidates scattered documentation into a single navigable resource

Provenance Statement

All technical content in this document is derived from **original source documents** as defined in the Documentation Architecture Proposal (v6.0, §2.1). These include:

- Original engineering schematics, wiring diagrams, and drawings (PDFs from SLAC/PEP-II project)
- Human-authored design notes and operational procedures (docx files by J. Sebek, R. Cassel, et al.)
- Measurement and calibration data (xlsx files from actual hardware)
- The complete legacy source code (2,293 files in `spear-rf-code-legacy/`)
- Published SLAC technical papers and conference proceedings
- Vendor documentation (Enerpro, Galil, Superior Electric, Ross Engineering)

Every technical statement in this document is referenced to an original source in Appendix A. AI-generated technical notes elsewhere in the repository are **not** cited as authority anywhere in this document.

External references obtained through web research are cited with full bibliographic information in Appendix A.

Relationship to Other Documents

Document	Relationship
Doc 0 (System Design Report)	Doc 0 describes the <i>upgrade</i> architecture. Doc L describes the <i>legacy</i> system that Doc 0's upgrade replaces
Doc I (Legacy Interlock Architecture)	Doc I is the Tier 2 interlock deep-dive companion to Doc L. Where Doc L (§13–§15) summarizes the protection subsystems, Doc I provides the complete signal flow diagrams, per-actor input/output tables, PPS compliance analysis, fault timeline examples, and step-by-step fault data access procedures.
Doc P (RF Physics and Plant)	Doc P covers physics and control theory independent of hardware. Doc L covers the specific hardware implementation
Doc D (Operational Data Catalog)	Doc D will contain measured data and calibrations. Doc L explains the system that produced that data
U1–U10 (Upgrade Documents)	Each U-document references the relevant Doc L sections for the legacy baseline of its subsystem

What This Document Contains

- Physical hardware descriptions with part numbers, serial numbers, and specifications
- Control system architecture and PLC configurations
- Software architecture for 6 SNL programs (7,112 lines total)
- Protection and safety system signal chains
- Complete cabling and interconnection references
- Known issues and legacy debt catalog

What This Document Does NOT Contain

- RF physics or control theory derivations (see Doc P)
- Upgrade design specifications (see U1–U10)
- Measured calibration data tables (see Doc D)
- Source code listings (see `spear-rf-code-legacy/`)
- Detailed interlock signal analysis, fault timeline examples, and fault data access procedures (see Doc I)

Reference Tag Format

- **[Rn]** — Numbered references to original source documents, published papers, and repository files
 - **[Wn]** — External web references with URLs
- All references are cataloged in Appendix A.

Part I

SYSTEM OVERVIEW

1 Introduction and Purpose

1.1 PEP-II Heritage

The SPEAR3 RF system is a direct adaptation of a PEP-II B-Factory High Energy Ring (HER) RF station. PEP-II was an asymmetric electron-positron collider at SLAC that operated from 1999 to 2008 with up to 10 RF stations. When SPEAR was upgraded to SPEAR3 (a 3rd-generation synchrotron light source) in 2003, a complete PEP-II HER station — klystron, four RF cavities, HVPS, waveguide distribution, and LLRF electronics — was installed as the SPEAR3 RF system [R1] [R2] [R3].




Figure 1: Control-layer hierarchy of the legacy LLRF system, and the three interlock paths that can remove RF drive or high voltage. Redrawn from the 2003 system-overview slide; several values embedded in that slide were stale and have been corrected here against the original sources.

2 System Architecture Overview

2.1 Top-Level System Block Diagram

The legacy SPEAR3 RF system consists of the following major elements:

Note on interlock timings shown above: $<1\ \mu\text{s}$ is the *signal* latency of the Fast Interlock Chassis comparator and its fiber-optic link. The physical response is slower and is what actually bounds the protection: the crowbar thyristors begin conducting $\approx 10\ \mu\text{s}$ after the trigger, and complete interruption of primary current takes 4–8 ms because the phase-control thyristors can only stop conducting at an AC zero crossing [R6]. See §12.1.

Note on the tuner chain: The legacy path — `rf_tuner_loop.st,v` (SNL) → Remote I/O → Stepper Chassis 340-315 (1746-HSTP1) → SS2000MD4 translators → SLO-SYN motors — **is the configuration currently in service**. A Galil DMC-4143 4-axis Ethernet controller in a new SLAC chassis has been procured and bench-tested (it successfully drove the installed cavity motors in August 2025 [R34]) but is **not yet installed or operational**; it will go online when the LLRF upgrade project completes. The SLO-SYN motors and linear potentiometers are retained in both configurations.

2.1.1 Major Block Descriptions

Block	Location	Description
EPICS Control Layer	B132	VxWorks RTOS on VXI slot-0 PowerPC (350 MHz). Hosts 6 SNL state-machine programs (<code>rf_states</code> , <code>rf_hvps_loop</code> , <code>rf_tuner_loop</code> ×4, <code>rf_dac_loop</code> , <code>rf_calib</code> , <code>rf_msgs</code>) plus ~78 EPICS process-variable database files. Provides ~1 Hz supervisory control; all fast feedback is in hardware below this layer.
VXI Crate (Elma 13-slot)	B132, rm 101	The master intelligence of the RF station. Slot 1 (AB 6008-SV1R) is the Remote I/O scanner linking to all PLCs. Slot 2 (CLK) generates the 471.187 MHz LO and all system clocks. Slot 4 (RFP) implements the analog RF feedback loop. Slots 7/9/11 (IQA×3) measure forward power, reflected power, and cavity probes. Slot 12 (AIM) manages arc detection, fault capture, and direct hardware interlock I/O.
AB Remote I/O (RIO) serial link	B132 back-bone	Allen-Bradley proprietary Remote I/O (“blue hose”) serial bus — not Data Highway+. The VXI slot-1 AB 6008-SV1R is the RIO <i>scanner</i> (link master); the PLCs appear on the link as RIO <i>adapters</i> (racks) through their DCM modules. Three adapters share the one link: rack 1 = HVPS SLC-500 via 1747-DCM (B118, Full rack), rack 2 = cavity tuner stepper chassis (B132, 3/4 rack), rack 3 = RF MPS PLC-5 via 1771-DCM (B132, 1/4 rack). ~1 Hz update rate. All supervisory setpoints, enables, and readbacks between the VXI IOC and the external PLCs/stepper chassis travel on this link. See §5.7.1 for the adapter/card map.

Block	Location	Description
SLC-500 PLC (AB-1747-L532)	B118, Hoffman Box	HVPS controller. Appears on the Remote I/O link as adapter (rack) 1 through its 1747-DCM. Functions: HVPS power-up/down sequencing, analog voltage regulation (PLC reference + analog regulator error → Enerpro SIG HI → SCR firing angle), 8-channel thermocouple monitoring, PPS relay chain (Slot-5 OX8 → K4 → MX → L1 hold coil → Ross HQ3 contactor; Slot-2 IO8 → Ross Grounding Switch), supervisory fiber-optic SCR ENABLE/CROWBAR outputs to B514. Note: legacy PPS compliance issue — both PPS chains pass through PLC ladder logic.
RF MPS — AB PLC-5 + 1771-DCM	B132	RF Machine Protection System. Allen-Bradley PLC-5 with 1771-series I/O; appears on the Remote I/O link as adapter (rack) 3 through its 1771-DCM. Monitors klystron collector power (cathode power minus RF output), cavity reflected power, waveguide arc conditions, cooling water flow, klystron vacuum, and HVPS fault conditions. On any trip: removes MPS permit → HVPS SCR ENABLE removed + RF drive inhibited. Hardwired to Fast Interlock Chassis for permit exchange. <i>A ControlLogix 1756 replacement has been assembled and tested without RF power but is not yet in service — see §14.2.</i>
Stepper Chassis 340-315	B132	SLAC chassis (SN08) with SLC bus adapter and 4× AB 1746-HSTP1 high-speed stepper controller modules. One 1746-HSTP1 per cavity. Remote I/O adapter (rack) 2, commanded by the <code>rf_tuner_loop.st,v</code> SNL program. Outputs step-pulse and direction signals to the SS2000MD4 translators. <i>Currently in service; to be replaced by the Galil DMC-4143 at the end of the LLRF upgrade project.</i>
SS2000MD4 PWM Motor Translators	B132	Superior Electric SLO-SYN SS2000MD4-M bipolar PWM step drive translators, one per motor. Convert the step/direction digital pulse train from the 1746-HSTP1 (or Galil) into bipolar phase current to drive the two-phase stepper motor windings.
Fast Interlock Chassis 340-308	B132	Hardware interlock hub. Inputs: arc sensor fiber optics from the 4 cavity waveguide windows, klystron window and circulator; RF power detector signals for reflected-power limits; RF MPS PLC permit (relay); HVPS status (fiber optic from B514, informational only). Outputs: SCR ENABLE removal and CROWBAR firing (fiber → B514). Comparator-to-fiber signal latency is $<1\ \mu\text{s}$; the resulting crowbar conduction begins $\approx 10\ \mu\text{s}$ later and primary current interruption takes 4–8 ms (§12.1). Note: the SPEAR MPS beam permit and orbit interlock connect to the back connector of VXI Slot 5 (MPS Shutoff) , not to this chassis. Summarized status word is reported to the VXI AIM module (slot 12).
Local Control Chassis	B132	Separate SLAC chassis that gathers and distributes a portion of the station's hardwired interlock and control wiring and connects it to the Fast Interlock Chassis [R5] §2.1. It is a wiring/permit aggregation point, not a trip-decision element. <i>Detailed I/O list not yet captured — see §20.2.</i>

Block	Location	Description
HVPS Power Section (SPEAR1 + SPEAR2)	B514	Two complete, identical 12-pulse thyristor phase-controlled rectifier units. One unit is energized and the other is completely switched off (not a warm standby); the roles are exchanged at the two scheduled downs each year (April and August). Input: 12.47 kV 3-phase AC from substation 507. Conversion chain: phase-shift transformer T0 (2750 kVA, $\pm 15^\circ$) $\rightarrow$ 12-pulse SCR bridges ($168 \times$ Powerex T8K7) $\rightarrow$ filter inductors L1/L2 (0.3 H) $\rightarrow$ 4 series rectifier/filter stages ($8 \mu\text{F}$ each) $\rightarrow$ crowbar (4 SCR stacks, fiber-optic trigger, $\approx 10 \mu\text{s}$) $\rightarrow$ termination-tank inductors L1/L2 ($350 \mu\text{H}$) $\rightarrow$ HV DC to the klystron cathode (§4.2).
Drive Amplifier KAW2051M12	B132	Broadband RF power amplifier. Amplifies the VXI RFP module baseband-modulated RF output to $\sim 29 \text{ W}$ (44.6 dBm) at 476.3 MHz, which drives the klystron input waveguide.
Klystron	B132	Marconi 476 MHz CW klystron, rated $\sim 1.5 \text{ MW}$ — the rating the HVPS and RF system were sized for. Negative HV cathode; solenoid focused; non-full-power collector (collector dissipation must be monitored by MPS). Typical operating point: $\sim 800 \text{ kW}$ RF output at $\approx -72 \text{ kV} / \approx 19 \text{ A}$ (§4.3). Filament controlled by VXI AIM module.
Circulator + Waveguide Network	B132/Tunnel	AFT ferrite circulator routes klystron reflected power to a water-cooled load, protecting the klystron. WR-1800 rectangular waveguide then divides power through a 2-stage magic-tee network: Magic-Tee 1 $\rightarrow$ Magic-Tees 2 and 3 $\rightarrow$ each feeds a pair of RF cavities. Three water-cooled waveguide loads absorb difference-port (reflected) power.
RF Cavities $\times 4$	Tunnel	Four single-cell HOM-damped copper cavities (PEP-II HER design). Each at 476.3 MHz, $\sim 712 \text{ kV}$ gap voltage (operating), 3 HOM dampers, ceramic RF window, internal probe, and movable tuner plunger. Arc detection sensors at cavity waveguide windows send fiber-optic fault signals to the Fast Interlock Chassis.
SLO-SYN M093-FC11 Stepper Motors $\times 4$	Tunnel	Superior Electric NEMA 34D stepper motors. Each drives a movable plunger in its RF cavity; plunger depth shifts the cavity resonant frequency. Linear potentiometer on each assembly provides position feedback. The SNL rf_tuner_loop.st,v program closes a phase-based slow loop: IQA cavity phase reading $\rightarrow$ compute resonance error $\rightarrow$ command motor steps.

2.2 Subsystem Summary

Subsystem	Location	Primary Hardware	Legacy Control	Function
LLRF Controller	B132	VXI crate (RFP, IQA $\times 3$, CLK, AIM)	SNL/EPICS on VxWorks	RF feedback and station control
HVPS Power Section	B514	Transformer, thyristor bridges, crowbar	— (power electronics)	Negative HV DC to klystron cathode

Subsystem	Location	Primary Hardware	Legacy Control	Function
HVPS Controller	B118	SLC-500 PLC, analog regulator, Enerpro FCOG6100 + FCOAUX60	PLC ladder logic + SNL	Voltage regulation and sequencing
RF MPS	B132	AB PLC-5 + 1771 I/O	PLC ladder logic	Equipment protection
PPS Interface	B118/Switchgear	Hoffman box, relay chain, Ross switch	Hardwired + PLC	Personnel safety
Tuner Motors	Tunnel	SLO-SYN M093-FC11 $\times$ 4	AB 1746-HSTP1 via SNL	Cavity frequency tuning
Interlock System	B132	Fast Interlock Chassis 340-308 + Local Control Chassis (separate units)	Analog + PLC	Fault detection and trip chains
Klystron + Drive	B132	Marconi klystron, KAW2051M12 drive amp	VXI (RF output)	RF power amplification
Waveguide + Cavities	B132/Tunnel	WR-1800 waveguide, 4 PEP-II cavities	— (passive)	RF power distribution and acceleration

Sources: [R5] §2.1; [R9]; [R10], [R11]; [R53] §2.2.




Figure 2: Top-level architecture of the legacy SPEAR3 RF station. Buildings: **B132** klystron and control, **B118** HVPS control, **B514** HVPS power. Solid lines are electrical or hardwired connections; dashed lines are fiber optic.




Figure 3: LLRF control electronics in Room 101, Building B132 — the primary control location for the SPEAR3 RF station, housing the VXI crate, drive amplifier, and associated electronics racks

3 Physical Layout and Locations

The SPEAR3 RF station is distributed across multiple buildings at SSRL. Understanding the physical geography is essential for understanding cable runs, signal latency, and maintenance access.

Location	Equipment	Distance from B132
Building B132 (room 101)	Klystron, drive amplifier, VXI crate (LLRF controller), RF MPS PLC, Fast Interlock Chassis, Local Control Chassis, stepper motor controllers	— (primary location)
Building B118 (Power Supply Room)	HVPS Controller (Hoffman NEMA enclosure), SLC-500 PLC, Enerpro firing boards, analog regulator card, monitoring oscilloscope	~100 m cable run to B514
Building B514 (HVPS Substation)	HVPS Main Tank (transformer, rectifier, inductor, filter caps), Phase Tank (12 thyristor stacks), Crowbar Tank (4 thyristor stacks, output voltage divider)	-
Contactor Disconnect Panel (Switchgear)	Vacuum contactor (Ross HQ3), contactor controller/driver (Ross HCA-1-A), K4/MX/RR/TX/BR relays, L1 holding and L2 closing coils, S2–S5 auxiliary contacts	B514
Termination Tank (B132, rm101)	HV cable termination, Ross Engineering HV grounding switch, Danfysik DC-CT, Pearson CT-110 current transformer	Near klystron
Switch-over Tank	HV cable connections between SPEAR1/SPEAR2 HVPS and klystron	Adjacent to B514

Location	Equipment	Distance from B132
SPEAR3 Storage Ring Tunnel	4 RF cavities, waveguide distribution network (circulator, magic-tees, waveguide loads), tuner motor assemblies, arc detection sensor mounting points	Radiation area, restricted access



Figure 4: Building B132 — the klystron building housing the LLRF control electronics, drive amplifier, and RF MPS; the "132" building number is visible on the metal-clad corrugated exterior, with utility pipe runs, electrical panels, and the RF area access road in the foreground



Figure 5: Building B514 — the high-voltage power supply substation housing the main transformer/rectifier tank, phase tank, and crowbar tank

Sources: [R5] §3; [R25]; [R14].



Figure 6: HVPS grounding and termination tank located near Building B132 — cylindrical stainless/aluminum vessel with two high-voltage cable entries through flexible metallic conduit at the top; contains the Ross Engineering HV grounding switch, the Danfysik UltraStab DC-CT that measures klystron cathode current, a $3.333\text{ m}\Omega$ ($15\text{ A} = 50\text{ mV}$) return-cable shunt, and the Pearson CT-110 wide-bandwidth current transformer used for klystron arc detection [R25]



Figure 7: RF cavities installed in the SPEAR3 storage ring tunnel (inward view) — showing the waveguide connections and cavity arrangement in the radiation enclosure

4 Key System Parameters

How to read the numbers in this section. Note that two of the station's headline quantities are not fixed constants:

- **RF frequency.** The ring circumference changes slowly with tunnel temperature, and the RF frequency is retuned to keep the harmonic condition satisfied. The operating frequency therefore wanders over a range of a few tens of kHz about 476.3 MHz. This document uses **476.3 MHz** as the nominal value and quotes precise figures only where the source of a specific reading matters (see the RF frequency row below).
- **Klystron cathode voltage and current.** These are adjusted continuously by the HVPS supervisory loop to hold drive power in range as beam current, klystron gain, and cavity conditions vary. Values quoted in this document are typical readbacks with their date/source identified, not setpoints.

Where two source documents give slightly different values for the same quantity, both are given with their provenance rather than being averaged or silently reconciled.

4.1 RF System Parameters

Parameter	Value	Notes
RF Frequency (nominal)	~476.3 MHz	Harmonic 372 of the revolution frequency. Not fixed: retuned by a few tens of kHz as the ring circumference drifts with tunnel temperature. Representative values on record: 476.3051755 MHz measured [R8]; 476.309 MHz is the value the CLK module was designed to (§5.8.2) [R53]. Both lie well inside the ± 200 PPM CLK tuning range.
Revolution Frequency	~1.2804 MHz	$f_{\text{rev}} = f_{\text{RF}}/372$
Ring Circumference	~234.14 m	Doc P value [R55]. The CLK design table quotes 234.126 m (§5.8.2); the difference is within the thermal drift described above.
Beam Energy	3.0 GeV	
Design Beam Current	500 mA	Top-off mode
Fill Pattern	276 bunches in 4 groups + 1 camshaft	
Number of Cavities	4	Single-cell, HOM-damped copper (PEP-II HER type)
Cavity Shunt Impedance (R_s)	3.73 M Ω (linac convention)	Schwarz [R7]. Equivalent to 7.5 M Ω in the accelerator convention; McIntosh [R1] quotes 3.8 M Ω accelerator-convention. See Appendix B.3.
Cavity Unloaded Q (Q_0)	32,000	Schwarz [R7]
Cavity Loaded Q (Q_L)	~6,700	$\beta \approx 3.78$ (coupling factor); $Q_L = Q_0/(1 + \beta)$
Gap Voltage per Cavity	~712 kV	Operating point (design: 800 kV) [R4]

Parameter	Value	Notes
Total Accelerating Voltage	~2.85 MV	Sum of 4 cavities (design 3.2 MV)
Klystron Output Power	~800 kW	Typical operating (tube rated ~1.5 MW)
Drive Power	~29 W	At klystron input
IF Frequency	5.1216 MHz	$f_{\text{IF}} = f_{\text{RF}}/93 = f_{\text{RF}} - f_{\text{LO}}$. (The PEP-II IF is 4.9072 MHz = $f_{\text{RF}}/97$ — a <i>different</i> divisor; see §5.8.2.)
LO Frequency	471.187 MHz	Generated by CLK module PLL471 ($f_{\text{LO}} = f_{\text{RF}} \times 92/93$); distributed to the IQAs at +14.0 dBm on PKZ front-panel connectors [R53] §3.0.5

Cross-reference: Doc P [R55] is the authoritative source for beam and cavity physics parameters and their derivations. Where this document and Doc P differ, Doc P governs for physics quantities and Doc L governs for as-installed hardware.

4.2 HVPS Parameters

Parameter	Value	Notes
Input Power	12.47 kV RMS, 3-phase, 60 Hz	Substation 507, Breaker 160. Rated 127 A/phase at 12.5 kV, 2750 kVA, per the NWL nameplate schematic [R70]; typical input current ≈ 113 A [R56]
Phase-shifted secondary (to T1/T2 primaries)	12.91 kV RMS phase-to-phase	The $\pm 15^\circ$ extended-delta output is 4% larger than the incoming line. The specification [R22] carries 12.47 kV in its text but 12.91 kV in its figures; 12.91 kV is correct [R56]
Output Voltage (rated max)	−90 kV DC	Negative polarity for klystron cathode
Output Current (rated max)	27 A	
Output Power (rated max)	2.5 MW	
Output Voltage (typical operating)	≈ -72 to -75 kV	Varies with beam current and klystron gain. -74.7 kV is quoted for full 500 mA operation [R56]; -72.08 kV was the June 2020 reading (§4.3)
Output Current (typical operating)	≈ 19 – 22 A	22.0 A at full 500 mA operation [R56]; 19.4 A in June 2020 (§4.3)
Output Voltage with HVPS off (klystron load)	≈ 1.3 kV	Not zero. Transformer primary-to-secondary leakage is rectified by the output diodes even with the phase-control thyristors not firing. Goes to zero only when the input contactor opens [R56]

Parameter	Value	Notes
Topology	12-pulse thyristor phase-controlled rectifier	”Star point controller” configuration, primary-side filter inductor [R6]
Voltage Regulation	< 0.1%	Design specification, Cassel & Nguyen [R6]. <i>A $\pm 0.5\%$ figure appears in a later PEP-II slide set; the published paper value is used here.</i>
Ripple	< 1% peak-to-peak, < 0.2% RMS	Above 60 kV [R6]
Configuration	2 units — SPEAR1 and SPEAR2	One unit is energized; the other is completely switched off (not a warm standby). Roles are exchanged at the two scheduled downs each year (April and August). Either unit may be the active one.

4.3 Representative Operating Point (June 2020)

A single consistent set of readbacks, used throughout this document to check the HVPS control-chain arithmetic. It is a snapshot, not a setpoint.

Parameter	Measured	Calculated	Difference
Output Voltage	72.08 kV	72.08 kV (input)	—
Output Current	19.4 A	19.2 A (Child–Langmuir, perveance $\approx 1 \mu\text{perv}$)	1.0%
Power	1.398 MW	1.384 MW	1.0%
Firing Angle	SIG HI = 4.40 V	$\alpha \approx 36.8^\circ$	Consistent
Voltage Sense	7.183 V	7.19 V (divider $\div 10,035$)	0.1%

Divider check: each HVPS output divider is **five 20 M Ω resistors in series (100 M Ω) into two 1 M Ω in parallel (500 k Ω)** — R1–R7 and R11–R17 on WD-730-794-04-C0 [R71]. The 500 k Ω bottom leg is loaded by the regulator board’s $\approx 10.5 \text{ k}\Omega$ input, which dominates it, so the end-to-end scale factor is $R_{\text{load}}/R_{\text{div}} = 10^4/10^8 = 10^{-4}$, i.e. $\approx \mathbf{10,000:1}$ — 9.1 V at the full 91 kV output, consistent with the $\div 10,035$ above [R72].

Part II

RF SIGNAL CHAIN

5 LLRF Controller (VXI System)

5.1 Overview

The LLRF controller is a VXI-based system located in Building B132 that provides the fast RF feedback, station state management, and measurement functions for the RF station. It was designed for PEP-II by P. Corredoura, S. Allison, R. Sass, R. Tighe, and R. Claus at SLAC (1996–1997).

The VXI crate hosts a Kinetics Systems IOC running VxWorks RTOS, which serves as the primary intelligence for the entire RF system. All communication with external PLCs (HVPS, MPS, stepper motors) passes through the VXI crate via an Allen-Bradley DCM serial communication module.



Figure 8: VXI crate running VxWorks RTOS in Building B132 — slot 0: EPICS IOC host (350 MHz MPC 750 PowerPC, VxWorks); slot 1: AB6008 scanner (DCM serial link); slot 2: CLK/RF distribution (clock and 471.187 MHz LO, requires ≥ 9 dBm RF input); slot 3: empty (GVF not installed); slot 4: RFP (RF Processor, direct feedback loop); slot 5: MPS Shutoff; slot 6: Link Passthru (also routes ripple-link backplane signal between IQA-1 and RFP); slot 7: IQA-1 (forward/reflected power, ripple-link source); slot 8: empty; slot 9: IQA-2 (cavity reflected); slot 10: empty; slot 11: IQA-3 (cavity probe); slot 12: AIM (arc/interlock)

5.2 VXI Module Inventory



Figure 9: Rear of the LLRF VXI crate (Elma chassis, SLAC EEIP accepted 2019) in Building B132 — showing the dense cable plant of orange fiber optic cables (SCR ENABLE/CROWBAR/STATUS runs to B514), blue coaxial signal cables (IQA measurement inputs), and multi-conductor control wiring interconnecting the VXI modules

Slot	Module	Function	SPEAR3 Status
0	B132-IOCRF (Slot 0 μ Processor)	VXI bus controller, EPICS IOC host (VxWorks RTOS, Kinetics Systems)	Active
1	AB Scanner	Allen-Bradley DCM serial communication module (PLC interface)	Active
2	CLK/RF Distribution	Master clock, LO generation ($471.187 \text{ MHz} = \text{RF} \times 92/93$), RF reference fanout (+14.0 dBm); CLK40/20/10 timing signals; TSYNC synchronization pulse	Active
3	(empty)	GVF slot from PEP-II — not installed in SPEAR3	! Not installed
4	RFP (RF Processor)	Central feedback processing — IQ demod, vector sum, direct loop, baseband modulator	Active
5	MPS Shutoff	CF2 slot from PEP-II, repurposed for MPS Shutoff in SPEAR3	Active

Slot	Module	Function	SPEAR3 Status
6	Link Passthru	RF amplifier Link passthrough module	Active
7	IQA-1	Forward power — klystron output forward and reflected power	Active
8	(empty)	—	—
9	IQA-2	Reflected power — all-cavity reflected power measurement (4 cavities via channel mux)	Active
10	(empty)	—	—
11	IQA-3	Cavity probe — all-cavity probe signal measurement (4 cavities via channel mux)	Active
12	ARC/Interlock Module (AIM)	Arc detection, interlock management, fault history	Active

Authoritative source: `rfApp/DbIoc/srf1.substitutions,v` (lines 103–104), which instantiates the `crat_vxi_13slot.db` template for the SRF1 station VXI crate (Elma, B132-101-11-24).

Sources: [R53] §2.0 and Fig. 2 (crate layout); [R7] (RF System Description); [R10], [R11] (block diagrams); [R2] Fig. 1 (VXI crate topology).

5.3 RFP (RF Processor) Module — Heart of the LLRF

The RFP module is the central signal processing module in the VXI crate. It performs:

Analog Signal Processing:

- IQ demodulation of 4 cavity probe signals (476 MHz $\rightarrow$ 5.122 MHz IF $\rightarrow$ baseband I/Q)
- Vector summing of 4 cavity I/Q signals
- Direct loop error amplifier comparing vector sum against IQ reference
- Lead and integral compensation networks for loop stability
- Baseband modulator ($4 \times$ Gilbert-cell multipliers in 2×2 matrix for $I \rightarrow I$, $I \rightarrow Q$, $Q \rightarrow I$, $Q \rightarrow Q$ correction)
- IQ RF modulator (baseband $\rightarrow$ 476 MHz upconversion for klystron drive)

Digital Control Interface:

- Octal DACs (12-bit, ± 2048 counts) for: tune mode IQ setpoints, operate mode IQ offsets, klystron modulator matrix coefficients, ripple loop coefficients
- Mode control: TUNE / OPERATE switching
- RF switch: enable/disable RF output to klystron
- Built-in history buffer (circular buffer, freeze on fault for post-mortem analysis)

Key PVs (from `rf_dac_loop_pvs.h,v`, `rf_states.st,v`, and `rfp.db`):

Process variable	Meaning
{STN}:STN:TUNE:IQ.A	Tune mode IQ setpoint magnitude (counts)
{STN}:STN:TUNE:CTRL	Tune loop control
{STN}:STNDIRECT:LOOP:PHASE	Direct loop phase setpoint
{STN}:STNDIRECT:LOOP:COUNTS	Direct loop amplitude setpoint (counts)
{STN}:STN:RFP:RFENABLE	RF output enable/disable (from rf_states.st)
{STN}:STN:RFP:RUNMODE	TUNE/OPERATE mode select (from rfp.db)
{STN}:STN:RFP:MODU.DLE	Direct loop enable (RFP module register)

Sources: [R53] §2.4; [R16]; PV names verified against rfApp/Db/rf_fbck.db, rfApp/Db/rfp.db, rfApp/Db/historyList.

5.4 IQA (IQ/Amplitude Detector) Modules

Three IQA modules provide precision digital measurement of RF signals. Each module performs digital IQ demodulation using a custom SLAC ASIC, producing:

- I component (in-phase), Q component (quadrature)
- Amplitude $A = \sqrt{I^2 + Q^2}$
- Phase $\phi = \arctan(Q/I)$

Channel allocation (SPEAR3 four-cavity configuration):

- IQA-1 (Slot 7): Forward power — klystron output forward and reflected power measurement; also sources the **ripple link** — one downconverted/sampled channel sent to the RFP via the VXIbus backplane for use in the ripple loop [R53] §2.7
- IQA-2 (Slot 9): Reflected power — all-cavity reflected power measurement (all 4 cavities, channel select mux)
- IQA-3 (Slot 11): Cavity probe — all-cavity probe signal measurement (all 4 cavities, channel select mux)

Verification status: the IQA-1/2/3 functional split above is consistent with the station database and with [R53] §2.7, but the **per-connector mapping of the 8 RF inputs on each module has not been recovered from an original source**. It should be taken from the coaxial interconnection drawing [R33] and confirmed in the field before this table is used for cabling work. See §20.2.

Each IQA muxes 8 RF input channels through a single ADC in round-robin fashion, downconverting from 476.3 MHz to the 5.1216 MHz IF (using the 471.187 MHz LO from the CLK module) and bandpass-filtering at the IF before quadrature sampling with the 20.486 MHz CLK20. The PEP-II variant of the module uses a different IF (4.9072 MHz) and therefore a different bandpass filter — this filter change was one of the modifications required to adapt the IQA to SPEAR3 [R53] §2.7. The 8 channels also have amplitude threshold comparators that assert RF_FAULT on the VXIbus backplane if any channel exceeds its programmed limit. Each IQA contains circular history buffers that record I/Q data per channel and can be read out over VXI after a fault.

Sources: [R53] §2.7; Ziomek, C. and Corredoura, P., "Digital I/Q Demodulator," PAC 1995 [R41]; [R2].

5.5 ARC/Interlock Module (AIM)

The AIM module provides the interface between the VXI crate and the external interlock system:

- Beam abort force/reset interface
- Filament control signals
- HVPS permissive signals
- Fault history buffers — two independent systems:
 - **System A** (12-ch AIM only): 512 KB on-module hardware ring buffer (HISBUF register at A24 offset 0x0038); Fast IC fast ADC continuously samples arc-channel voltages + HVPS voltage; freezes on fault. Controlled by ADCMUX and ADCCTL bits in FICTRL. Read back via ARCVOL sequential register.
 - **System B** (both AIM versions): SNL ss rf_statesFF in rf_states.st,v captures 11 RF/IQA signal channels to /dat/FAULT*_N files at ≈ 1 s after fault. These are RF/IQA signals — distinct from the arc voltage data in System A.
- Station fault word monitoring (AIM reads FISTAT A16 register from Fast IC)
- Arc voltage comparator threshold configuration: AIM EPICS writes **TRIPLVL** registers (A24 offset 0x0020) which are applied directly to the Fast IC analog comparators (range 10–255). This is the primary mechanism for setting arc detection sensitivity.

AIM FICTRL control register. The AIM drives the external interlock system through bits of its Fast Interlock Control register (FICTRL, A16 offset 0x20). Dusatko [R53] §2.8 identifies **six control signals** that the AIM sends to the Interlock/PLC system, and states that they travel **from the AIM to the ARC chassis and from there onward through optical fibers**, which provide the galvanic isolation — they are not individually run from the VXI module to each end device. The register also carries a seventh bit used only as a test stimulus. Bit assignments are from rfApp/src/db/p2RfAimDef.h,v:

Signal	FICTRL bit	Symbol	One of Dusatko's six?	Ultimate destination
Solenoid_On	0	AIM_V_SOLENOID	Yes	Klystron solenoid power supply
HVPS_On	1	AIM_V_HVPS	Yes	B514 HVPS SCR enable hardware
Klys_Filament_On	2	AIM_V_FILAMENT	Yes	Klystron filament heater supply
Filament_Timeout	3	AIM_V_FILTM00VRD	Yes	Fast IC filament-watchdog override
Forced_Fault	4	AIM_V_FRCDFLT	No — test input	Fast IC forced-fault test stimulus
Fault_Reset	5	AIM_V_FLTRESET	Yes	Fast IC arc latch reset
Beam_Abort	6	AIM_V_FRCBMABT	Yes	SPEAR3 Machine MPS (injection kicker)

A further bit, AIM_V_RSTBMABT (bit 7), resets the beam-abort latch. Doc I §3.6 tabulates a different set of six (it includes Forced_Fault and relegates Filament_Timeout to a note); the grouping above follows the original Dusatko text.

RF_FAULT backplane line: Open-collector line shared by CLK, RFP, and AIM. Any module asserting RF_FAULT is monitored by AIM (which takes interlock action) and by RFP (which immediately cuts the RF drive to the klystron). AIM can also independently assert RF_FAULT based on arc detection or threshold violations.

Fault file capture (System B) (from rf_states.st,v, M. Laznovsky addition, 2003): On entering a fault

state, 11 RF/IQA signal channels are captured to `/dat/FAULT<channel>_<n>` files by `SNL ss rf_statesFF`. Channel order (per `rf_states.st,v faultroot[]` array, `#else` branch of `#ifdef CF2` since SPEAR3 has no CF2 module): `RfpSI, RfpSQ, RfpCI, RfpCQ, CmbI, CmbQ, Iqa1Amp, Iqa2Amp, Gvf, Aim, Iqa3Amp`. `NUMFILES=11` is the channel count (not a buffer depth). These are RF/IQA signals — distinct from the arc voltage data captured in System A (12-ch AIM hardware `HISBUF`).

Sources: [R53] §2.8; [R16] (fault file handling code); `rfApp/src/db/p2RfAimDef.h,v` (register map, drawing 340-307); [R20] (AIM status monitoring). For complete AIM/Fast IC architecture and signal details, see Doc I §2–§3.

5.6 Feedback Loop Architecture

The legacy LLRF system implements multiple feedback loops, some inherited from PEP-II and some SPEAR3-specific:

Active in SPEAR3:

1. **Direct (Wideband) RF Feedback Loop** — Reduces the effective cavity impedance seen by the beam, suppressing the Robinson instability [R47] that would otherwise limit the storable current under heavy beam loading [R48]. Analog feedback at baseband, ~800 kHz bandwidth ($\approx 1.25 \mu\text{s}$ response) [R8]. Critical for beam stability. The general theory of this class of controller is treated in [R50] and, for modern digital implementations, in [R59].
2. **Tuner Loop** — EPICS/SNL slow loop controlling the stepper motors to maintain cavity resonance. Implemented in `rf_tuner_loop.st,v` (§17.3).
3. **HVPS Voltage Regulation Loop** — Regulates klystron cathode voltage via the PLC/analog-regulator SIG HI chain to the Enerpro SCR firing angle. Implemented across `rf_hvps_loop.st,v` (SNL) and PLC ladder logic (§10.4).
4. **DAC Control Loop** — Manages drive power and gap voltage setpoints through the RFP octal DACs. Implemented in `rf_dac_loop.st,v`.
5. **Ripple Loop** — Implemented in the RFP using an AGERE DSP1610 DSP IC [R53] §2.4, and *is* used in SPEAR3 to regulate constant phase and amplitude. **However**, the HVPS power-supply ripple-cancellation feature — the loop's original PEP-II purpose — is not implemented: per Dusatko, "This ripple remove feature is not implemented." The DSP1610 hardware is present and the loop runs, but only for general amplitude/phase regulation. SPEAR3-specific ripple DSP firmware is present in the source tree (`rfApp/src/dsp/, sp3ripple.s,v`).

NOT active in SPEAR3 (PEP-II only, module not installed):

- Comb (Narrowband) RF Feedback Loop — PEP-II multi-bunch stabilization at revolution harmonics; the two CFM modules that implement it are absent from the SPEAR3 crate
- Gap Voltage Feed-Forward (GVF/GAP) — PEP-II ion-clearing-gap transient compensation with LFB interface; module absent. SPEAR3 has no ion clearing gap, so the station reference amplitude and phase are instead supplied by a pair of RFP-resident DACs driven by a slow EPICS loop [R53] §2.4

Sources: [R2] (complete loop architecture); [R8] (feedback loop description); [R53] §2.4; [R42] Fox et al. operational review.

5.7 Communication Architecture

The VXI crate communicates with all external controllers over a **single Allen-Bradley Remote I/O (RIO) serial link**. The VXI slot-1 module is an **Allen-Bradley 6008-SV1R VMEbus Remote I/O scanner** (a VME card adapted to VXI through an HP E1407A VME-to-VXI adapter) and acts as the link master. The




Figure 10: Communication architecture below the VXI IOC.

PLCs and the stepper chassis do **not** appear as peers on a Data Highway+ network; they appear as RIO *adapters* ("racks") through their DCM modules.

The link provides ~1 Hz supervisory communication (setpoints, readbacks, status). Fast feedback (the direct RF loop) operates entirely within the RFP module at analog speeds. Fast interlock signals bypass the link completely and travel on hardwired/fiber paths to the Fast Interlock Chassis and AIM.

5.7.1 Remote I/O Adapter and Card Map

Rack sizes are declared in the IOC boot file `iocBoot/b132-iocrf/config.ab,v`; the adapter and card assignments come from `rfApp/Db/rf_ab_4cv.substitutions,v` (the 4-cavity SPEAR3 configuration instantiated by `srfl.substitutions,v`).

Adapter (rack)	Size	Device	EPICS component	Cards
1	Full	SLC-500 HVPS PLC (1747-DCM)	HVPSDCM	0, 2, 4, 6, 8, 10, 12, 14 (+ summary)
2	3/4	Stepper chassis 340-315 (4 × 1746-HSTP1)	CAV1TUNR...CAV4TUNR	0, 2, 4, 6 (one per cavity, + summary)
3	1/4	RF MPS PLC-5 (1771-DCM)	STNDCM	0

The RF MPS 1771-DCM exposes eight data tables `STNDCM:T0 ... STNDCM:T7`; EPICS records read them with device types `AB-1771DCM BI`, `AB-1771DCM AI` I to F, and `AB-1771DCM AI-13 bit raw`. Communication health for each adapter is summarised into `$(S):STNDCM:SUMY:MODU`, `$(S):HVPSDCM:SUMY`, and `$(S):CAVTUNR:SUMY`, all of which feed the station alarm tree.

slot:	0	1	2	3	4	5	6	7	8	9	10	11	12
	B132-IOCRf	AB Scanner	Clock	empty	RF Processing	MPS Shutoff	Link Passthru	IQA1	empty	IQA2	empty	IQA3	Arc Interlock
	IOC VxWorks PowerPC	6008-SV1R RIO scanner	CLK		RFP	SPEAR MPS in + orbit interlock	ripple-link passthrough	Klystron fwd/refl		Cavity refl.		Cavity probe	AIM

Figure 11: VXI crate slot map. Elma 13-slot chassis, SLAC EEIP accepted 2019, label B132-101-11-24. Slots 3, 8 and 10 are empty: the gap-voltage feed-forward module and the two comb-filter modules that PEP-II carries are not required by SPEAR3.

Note: Doc I §5.7 and §6.4 carry the same assignment.

Sources: `spear-rf-code-legacy/iocBoot/b132-iocrf/config.ab,v`; `spear-rf-code-legacy/rfApp/Db/rf_ab_4CV.substitutions,v`; `spear-rf-code-legacy/allenBradley/documentation/allenBradley.html,v` — all collected as [R60]; [R53] §2.2; [R5] §2.1; [R20].

5.8 CLK (Clock and RF Reference Distribution) Module

The Clock module in VXI slot 2 is the master timing and RF reference source for the entire LLRF system. It was originally designed for PEP-II and modified for SPEAR3 frequencies. [R53] §§2.3, 3.0

5.8.1 VXI Crate Physical Layout

The 13-slot VXI crate (Elma chassis, SLAC EEIP accepted 2019, label B132-101-11-24) is laid out as follows, per the head revision of `rfApp/DbIoc/srf1.substitutions,v` (slot-name strings shown in quotes are the literal values in that file):

Slots 3, 8 and 10 are empty. The gap voltage feed-forward (GVF) module and the two comb-filter modules that PEP-II carries in slots 3, 5 and 6 are not required by SPEAR3 [R53] §2.0. Slot names in the box are the literal strings from the substitution file ("B132-IOCRf", "AB Scanner", "Clock", "RF Processing", "MPS Shutoff", "Link Passthru", "IQA1", "IQA2", "IQA3", "Arc Interlock").

Evolution since 2004. The Dusatko reference [R53] describes the crate as originally commissioned, when the SPEAR3 station drove **two** cavities and carried **two** IQA modules, with **slot 5 = RF AMP** (a Mini-Circuits ZFL-500HLN amplifier module added because cable losses put the incoming 476.3 MHz below the clock's +9.0 dBm minimum) and **slot 6 = MPS INTLK**. In the present four-cavity configuration those two functions have exchanged slots — slot 5 is the MPS Shutoff module and slot 6 is the "Link Passthru" module — and a third IQA has been added in slot 11. Both slot-5 and slot-6 modules pass the backplane ripple-link signal through from IQA-1 (slot 7) to the RFP (slot 4) [R53] §§2.5–2.6.

Open item: whether the RF-amplifier function described in [R53] §2.5 is still present (folded into the slot-6 Link Passthru module) or has been removed because the input level is now adequate has not been established from documentation. Field verification required — see §20.2.




Figure 12: Clock module top-level inputs and outputs.

5.8.2 System Timing Parameters

From [R53] §3.0, Tables 1 and 2 (Dusatko v1.2). **The SPEAR3 and PEP-II clocks use different division ratios**, so each column carries its own multiplier — they are not two evaluations of one formula.

Parameter	SPEAR3	PEP-II
Storage Ring RF	476.309 MHz	476.000 MHz
RF Tuning Range	± 200 PPM	± 100 PPM
Ring Circumference	234.126 m	2199.33 m
Number of RF Buckets (h)	372	3492
Fiducial Rate (f_{RF} / h)	1.28040 MHz	136.312 kHz
LO Frequency	471.1874 MHz ($\text{RF} \times 92/93$)	471.0928 MHz ($\text{RF} \times 96/97$)
CLK40	40.9728 MHz ($32 \times \text{fiducial}$)	39.2579 MHz ($288 \times \text{fiducial}$)
CLK20	20.4864 MHz ($16 \times \text{fiducial}$)	19.6289 MHz ($144 \times \text{fiducial}$)
CLK10	10.2432 MHz ($8 \times \text{fiducial}$)	9.8145 MHz ($72 \times \text{fiducial}$)
PLL40 Ref Clock	5.1216 MHz ($\text{RF}/93$)	4.9072 MHz ($\text{RF}/97$)
IF ($= f_{\text{RF}} - f_{\text{LO}}$)	5.1216 MHz ($f_{\text{RF}}/93$)	4.9072 MHz ($f_{\text{RF}}/97$)

Note on the RF frequency in this table: 476.309 MHz is the value the clock module was *designed* to ($= 1.28040 \text{ MHz} \times 372$), not a present-day readback. The station's actual operating frequency drifts by tens of kHz with ring circumference (§4.1); the clock's ± 200 PPM ($\approx \pm 95$ kHz) pull range accommodates this.

5.8.3 Clock Module Signals (Top-Level I/O)

Signal descriptions [R53] §§2.3, 3.0:

- **476.3 MHz RF FANOUT** — Input from SPEAR3 timing system (minimum +9.0 dBm required); amplified to +14.0 dBm and fanned out to RFP and other modules; PKZ impedance-controlled connectors
- **471.187 MHz LO** — Phase-locked local oscillator ($= f_{\text{RF}} \times 92/93$); 4 copies at +14.0 dBm on front-panel PKZ connectors distributed to all three IQA modules for downconversion to 5.122 MHz IF




Figure 13: Clock module internal architecture.

- **CLK40** — 40.972 MHz system clock; output on VXibus backplane ECLTRG0 (bussed to all modules via P2); runs RFP and IQA digital logic; a delay vernier adjusts backplane timing skew
- **CLK20** — 20.486 MHz; output on ECLTRG1; drives IQA ADC quadrature sampling
- **CLK10** — 10.243 MHz; output on TTLTRG0; runs AIM fault/control logic and is also the reference for PLL471
- **TCLK** — 1.280 MHz turn clock (50% duty cycle); generated by ÷372 ECL counter locked to fiducial; output on TTLTRG1; not used by any SPEAR3 module (GAP module absent) but retained for diagnostics
- **TSYNC** — Programmable synchronization pulse derived from fiducial; width and delay are software-controlled via VXI registers; used by IQA and other modules to synchronize internal state machines; output on TTLTRG3
- **RF_FAULT** — Open-collector backplane fault line; asserted by clock when RF input is lost or PLL loses lock; monitored by AIM and RFP

5.8.4 Clock Module Architecture

Both PLLs and the RF input/fanout circuitry are housed in an **ovenized thermal enclosure** on the PCB to minimize phase noise, jitter, and frequency drift.

5.8.5 Changes Made to Adapt Clock for SPEAR3

From [R53] §3.1 and [R54] (W. Ross, "PEP-II/SPEAR3 LLRF System Clock Module Revision 2", 1 September 2001):

Item	Change for SPEAR3
PLL40 Ref prescaler	Division ratio changed to $\div 93$
PLL40 VCXO	Changed to Connor-Winfield HV51-400P (40.972 MHz center, ± 200 PPM, TTL output — level-shift circuitry added to produce pseudo-ECL)
PLL471 feedback divider	Changed to $\div 23$ (external $\div 2$ + Q3236 internal $\div 23$; effective ratio 92/93 from 476.3 MHz)
Turn Counter	Division ratio changed to $\div 372$
Configuration ID	DIP switch changed to indicate SPEAR3 model; IOC software verifies Config ID at boot

Sources: [R53] (Dusatko, "The SPEAR3 Low Level RF System Description," v1.2, 4 May 2004; updated 29 January 2016); [R54] (W. Ross, "PEP-II/SPEAR3 LLRF System Clock Module Revision 2," 1 September 2001).

6 Klystron and Drive System

6.1 Klystron

The SPEAR3 klystron is a **Marconi** 476 MHz CW klystron located in Building B132. It is a single-beam tube with a non-full-power collector, meaning collector power must be actively managed to avoid thermal damage.

Note on tube provenance and rating. PEP-II klystrons were procured from more than one source — some were built at SLAC, others by Marconi. **The tube currently installed at SPEAR3 is a Marconi unit rated 1.5 MW**, and the HVPS (-90 kV / 27 A / 2.5 MW) and the rest of the RF system were sized for that rating. The 2004 SPEAR3 RF system paper [R1] describes the station as originally installed with a 1.2 MW klystron, and the PEP-II development papers [R43], [R44] describe the SLAC-built 1.2 MW tube; those figures refer to the original PEP-II production tube, not to the unit now in service.

Parameter	Value
Frequency	~ 476.3 MHz (follows the ring; §4.1)
Manufacturer	Marconi
Rated Output Power	~ 1.5 MW
Operating Output Power	~ 800 kW typical
Cathode Voltage	≈ -72 to -75 kV typical; -90 kV maximum (HVPS rating)
Cathode Current	≈ 19 – 22 A typical; 27 A maximum (HVPS rating)
Perveance	≈ 1 μperv (Child–Langmuir $I = P \cdot V^{3/2}$, $P \approx 10$ – 6) [R56]
Drive Power	~ 29 W
Gain	~ 44.4 dB (800 kW / 29 W)
Collector type	Non-full-power (requires collector power protection)

Collector Power Protection: Because the klystron has a non-full-power collector, the collector dissipation (cathode power minus RF output power) must be monitored. In the legacy system, this is implemented through:

1. Software monitoring in `rf_hvps_loop.st,v` comparing `klystron_forward_power` vs `max_klystron_forward_power`; on excess, the HVPS voltage is reduced
2. An MPS hardware limit using the RF detector module in the Fast Interlock Chassis, fed from a coupled sample of klystron forward power (front-panel J16, "DETECTED KLYSTRON POWER")
3. The RF MPS PLC monitors HVPS V and I, computes collector power (`{STN}:KLYSCOLLPLC:POWER`), and removes the MPS permit if the limit is exceeded — turning off both the HVPS and the drive power




Figure 14: Marconi klystron installed in Building B132 — 476 MHz CW klystron rated ~1.5 MW, showing the input waveguide, output waveguide, collector cooling, and solenoid focusing magnets



Figure 15: Klystron filament control chassis — manages the klystron heater/filament power and sequencing during startup and shutdown. The legacy chassis uses a motor-driven variac feeding a 10:1 step-down toroidal isolation transformer and a solid-state relay; it is enabled by the AIM `Klys_Filament_On` signal (§5.5) and its variac position is commanded through Allen-Bradley I/O [R5] §13.1

Sources: [R5] §4.1, §4.5, §13.1; [R17]; [R43] (PEP-II prototype klystron); [R44] (PEP-II 1.2 MW production klystron); [R56] (perveance).

6.2 Drive Amplifier

The drive amplifier (KAW2051M12) boosts the LLRF drive signal to ~29 W (44.6 dBm) at the station RF frequency (~476.3 MHz) to drive the klystron input.




Figure 16: RF drive amplifier (KAW2051M12) in the B132 electronics rack — amplifies the LLRF drive signal to ~29 W (44.6 dBm) at ~476.3 MHz to drive the klystron input

Sources: [R32] (drive amplifier datasheet); [R5] §4.4.

7 Waveguide Distribution Network

7.1 Network Topology

The klystron output feeds a waveguide network that distributes RF power equally to 4 cavities:

Each magic-tee splits power equally between two outputs (P2 and P3 ports). The P4 port (difference port) receives the sum of equal reflected power from the two cavities and directs it to a waveguide load.

7.2 Monitored RF Signals

The system monitors 24 RF signals at various points in the waveguide network. Key signals include:

- Klystron forward and reflected power (signals 1, 2)
- Each cavity's forward power, reflected power, and probe signal (signals 9–14, 17–22)
- Waveguide load powers (signals 7–8, 15–16, 23–24)
- Station reference and klystron drive (signals 5, 6 — 5 = klystron drive power, 6 = station reference power)
- Circulator load forward and reflected power (signals 3, 4)

Sources: [R5] §4.2, §4.6 (complete 24-signal table); [R33].




Figure 17: Waveguide distribution network from klystron to cavities. Each magic-tee splits power equally between its P2 and P3 ports; the P4 difference port receives the sum of equal reflected power from the two cavities and directs it to a waveguide load.




Figure 18: AFT circulator — positioned between the klystron output and the magic-tee splitter network; routes reflected power from the load network away from the klystron to protect it from reflected energy




Figure 19: Magic-tee power splitter and bellows network on the SPEAR3 tunnel roof — the two-stage magic-tee arrangement divides RF power equally among all four cavities; flexible bellows sections accommodate thermal expansion in the waveguide runs




Figure 20: Waveguide distribution network routing RF power from the klystron output through the circulator, magic-tee splitters, and into the tunnel toward the four RF cavities



Figure 21: Water-cooled waveguide load — absorbs circulator dump power and magic-tee difference-port reflected power; water cooling carries away dissipated RF energy



Figure 22: High-conductivity water (HCW) cooling station behind the booster — supplies cooling water to the waveguide loads, absorbing reflected and dump power from the RF distribution network

8 RF Cavities and Tuner Assemblies

8.1 Cavity Specifications

Four single-cell, HOM-damped copper cavities (PEP-II HER type) are installed in the SPEAR3 storage ring tunnel. The design is Rimmer's PEP-II cavity [R45], rated for continuous operation at 476 MHz with up to 150 kW wall dissipation under heavy beam loading, with three rectangular waveguide stubs and broadband loads damping the higher-order modes [R46]. Each cavity provides:

- Accelerating gap voltage: ~712 kV (operating)
- Resonant frequency: tuned to the station RF frequency (~476.3 MHz), tuner-adjustable
- 3 HOM (Higher-Order Mode) loads per cavity for beam stability
- Ceramic window for RF power transmission
- Internal probe for field amplitude and phase monitoring

Each cavity has waveguide window viewports on either side of the ceramic window, providing mounting points for arc detection sensors.




Figure 23: PEP-II bare single-cell RF cavity — copper cavity body prior to installation of HOM dampers, tuner assembly, and waveguide couplers; the SPEAR3 cavities are of this same design

8.2 Tuner Mechanical Assembly

Each cavity has an individual stepper motor tuner that adjusts the cavity resonant frequency by varying the insertion depth of a mechanical plunger:

Component / parameter	Specification	Source
Motor	Superior Electric SLO-SYN M093-FC11 (NEMA 34D)	[R30]
Motor driver (in service)	Superior Electric SLO-SYN SS2000MD4-M PWM translator, one per motor (obsolete part)	[R29]

Component / parameter	Specification	Source
Motor controller (in service)	Allen-Bradley 1746-HSTP1 stepper module, one per cavity, in chassis 340-315	devSmAB1746HSTP1.c
Motor controller (procured, not yet installed)	Galil DMC-4143 Rev 1.3h, 4-axis	[R34], [R35]
Position feedback	Linear potentiometer on each tuner assembly (indication only — not used to close the loop)	[R36]
Step resolution	0.003175 mm/step (1.27 mm/rev $\div$ 400 steps/rev)	rf_cav.db,v DIST
Slew velocity	3 mm/s (VELO), acceleration 0.5 mm/s ² (ACCL)	rf_cav.db,v
Software travel limits	−29.5 mm (DRVL) to +18 mm (DRVH)	rf_cav.db,v
Retry deadband	0.015875 mm (exactly 5 steps)	rf_cav.db,v
Loop rate	2 Hz, 4 independent instances of rf_tuner_loop.st,v	[R18]

Full analysis of the tuner control loop \u2014 inner phase loop, outer (disabled) load-angle loop, calibration polynomial, and failure modes \u2014 is in Doc T [R57]. See also §17.




Figure 24: RF cavity assembly — cavity body with waveguide coupler, HOM damper waveguide stubs, and tuner plunger installed




Figure 25: Labeled RF cavity assembly — identifying the accelerating cell, input coupler, HOM damper ports, movable tuner plunger, probe port, and ceramic RF window




Figure 26: Movable tuner plunger assembly mounted below an RF cavity — the SLO-SYN stepper motor drives the plunger in/out to shift the cavity resonant frequency and hold it at the station RF frequency under varying beam loading



Figure 27: HOM (Higher-Order Mode) load at an E-plane mitre bend in the waveguide stub — absorbs parasitic cavity modes that would otherwise cause beam instability



Figure 28: HOM load at an H-plane mitre bend — the three HOM loads per cavity (E-mitre, H-mitre, and plate) together damp all significant parasitic resonances above the fundamental accelerating mode




Figure 29: Water-cooled HOM load plate — dissipates HOM power as heat, carried away by the high-conductivity water cooling system; each cavity has one of these plates in addition to the E- and H-mitre loads




Figure 30: Four RF cavities installed in the SPEAR3 storage ring tunnel (outward view, tuner side) — showing the complete cavity row with waveguide distribution network and interconnecting bellows runs visible

Part III

POWER SYSTEMS

9 High-Voltage Power Supply — Power Section

9.1 Architecture Overview

The HVPS is a 12-pulse thyristor phase-controlled rectifier based on the PEP-II design (SLAC, 1997) [R6]. It delivers negative-polarity DC high voltage to the klystron cathode. The power section is located in Building B514; the control system is in Building B118.

Two complete HVPS units exist: **SPEAR1** and **SPEAR2**. Both are maintained in operating condition and connect to the klystron through a switch-over tank. At any time **one unit is energized and the other is completely switched off** — this is not a warm-standby arrangement. The roles are exchanged at the two scheduled accelerator downs each year (April and August), which equalizes run-time and gives maintenance access to the off-duty unit. Either SPEAR1 or SPEAR2 may be the active unit.

9.2 Power Conversion Chain

Note on the T0 rating. Four different figures for the phase-shifting transformer are in circulation. The authority is **NWL's own electrical schematic** for the unit, EI-730-790-00-C0 / NWL # 39308 [R70], whose input block reads verbatim **"INPUT 2750 KVA 3 PHASE / 12.5 KV AT 127 AMPS RMS"**. The two figures are internally consistent: $2750 \text{ kVA} \div (\sqrt{3} \times 12.5 \text{ kV}) = 127.0 \text{ A}$.

Source	Figure	Assessment
EI-730-790-00-C0 [R70]	2750 kVA, 127 A at 12.5 kV	Manufacturer's nameplate — use this
PS-341-360-01 §1.5 [R22]	"350 kVA"	Decimal error; far too small to pass 2.5 MW
SD-730-790-01-C1 [R9]	"3000 KVA"	Rounded label on the SLAC system sheet
J. Sebek [R56]	3.5 MVA, $\Rightarrow$ 162 A/phase	Reasoned estimate made without access to [R70]

Sebek's 162 A/phase follows arithmetically from his 3.5 MVA assumption and does not survive it. His **$\approx 113 \text{ A}$ typical** operating current is independent of that assumption and remains valid, sitting comfortably below the 127 A rating at a $\sim 2.5 \text{ MW}$ operating point.

9.3 Key Component Specifications

Component	Specification	Source
Phase-shift transformer T0	2750 kVA , 12.5 kV at 127 A RMS — the manufacturer's nameplate rating from NWL's own schematic [R70]. Extended delta; 12.47 kV delta primary / dual wye $\pm 15^\circ$ secondary at 12.91 kV RMS φ – φ . The SLAC top-level schematic labels the source "12.5KV 3PH 3000 KVA" (a rounded figure)	EI-730-790-00-C0 [R70]; sd7307900101.pdf [R9] — see note in §9.2
Rectifier transformers T1, T2	1.5 MVA each, open wye primary / dual wye secondary	SD-730-790-01-C1 [R9]; [R22] §1.9

Component	Specification	Source
Transformer secondaries	T1-S1 = T1-S2 = T2-S1 = 21.0 kV RMS φ - φ ; T2-S2 = 10.5 kV RMS	[R56]
Series DC stage taps	−26 kV, −52 kV, −77 kV, −90 kV (cumulative, as labelled on the schematic)	SD-730-790-01-C1 [R9]
SCR stacks (phase control)	12 stacks $\times$ 14 Powerex T8K7 (8 kV, 700 A) = 168 thyristors. The schematic labels the thyristor-controlled rectifier assembly "40KV 80A"	[R56]; SD-730-790-01-C1 [R9]
Thyristor snubbers / sharing	0.047 μ F across each thyristor; 0.015 μ F R-C snubber per stack; MOVs plus $\approx$ 20 M Ω sharing resistor per thyristor ($\approx$ 280 M Ω per stack)	[R56]
Filter inductors L1, L2	0.3 H, 85 A full load, 0.38 Ω DC resistance	[R56]; labelled "FILTER INDUCTOR" on SD-730-790-01-C1 [R9]
Secondary rectifiers	4 six-pulse main bridges in series, "RECTIFIERS 30KV 30A"; 4 filter bridges, "FILTER RECTIFIERS 30KV 3A AVG"	SD-730-790-01-C1 [R9]; [R22] §§3.4–3.5
Filter capacitors	"CAPACITORS 8uFD 30KV" — 8 μF per stage $\times$ 4 series stages ($\approx$ 2 μ F net), fed from a 105% secondary tap	SD-730-790-01-C1 [R9]; [R56]
Filter series resistors	"FILTER RESISTORS 500 OHMS 1KW" — 8 total, two per stage, in oil	SD-730-790-01-C1 [R9]; [R22] §3.8
Additional output capacitor	0.22 μ F across the HVPS output (not shown on the top-level schematic)	[R56]
Crowbar SCRs (SCR13–16)	4 stacks in series, 6 thyristors per stack with 5 M Ω sharing resistors. The schematic labels the crowbar assembly "CROWBAR 40KV 80A" (per-stack device rating); the oil-to-oil feed-through bushings are separately rated 100 kV DC with 80 kA peak fault current	SD-730-790-01-C1 [R9]; [R22] §§5.3, 8.1; [R6]; [R56]
Cable termination inductors	350 μH, 40 A as built — labelled "350 UHY 40A" on the Grounding Tank drawing, where they are designated L1 and L2 . Each is shunted by a 25 kV / 100 A diode and a 30 nF / 37 kV capacitor. <i>SLAC-PUB-7591 [R6] describes "small 200 μhy inductors in the termination tank" — that is the 1997 design figure; the as-built value is 350 μH.</i>	SD-730-790-05-C1 [R62]; [R6]

Component	Specification	Source
Output voltage divider	Two identical dividers, each five 20 MΩ resistors in series (100 MΩ) into two 1 MΩ resistors in parallel (500 kΩ) — R1–R7 and R11–R17 on WD-730-794-04-C0 [R71], in its "TRANSFORMER TANK WD-730-792-01" section. Each feeds a coaxial run (VOLTAGE 1 via J7, VOLTAGE 2 via J8) to TS-3 "VOLTAGE MONITORS" as DC-VOLTAGE #1 and #2. The 500 kΩ bottom leg is loaded by the regulator board's $\approx$ 10.5 kΩ input , which dominates it; the resulting end-to-end scale factor is $R_{\text{load}}/R_{\text{div}} = 10^4/10^8 = 1 \times 10^{-4}$, i.e. $\approx$ 10,000:1 (9.1 V at 91 kV) [R72]. Independently confirmed by the PS Monitor Board output labelled "+ Voltage 10 kV/V"	WD-730-794-04-C0 [R71]; [R72]; SD-730-793-12-C3 [R61]
Output HV cable	Mil-C-17/81-0001 (formerly RG-220), $\approx$ 101–103 pF/m; $\approx$ 10 m HVPS $\rightarrow$ transfer tank, < 50 m transfer tank $\rightarrow$ termination tank	[R56]
Regulator card	PC-237-230 (SD-237-230-14-C1), "PEP II RF System — Enerpro Voltage and Current Regulator Board"	sd2372301401.pdf

9.3.1 SCR Trigger and Monitor Electronics (SD-730-793 series)

The SD-730-793-xx drawings are **printed-circuit-board schematics for the trigger, interlock and monitoring electronics**, not power-assembly drawings. Verified identities:

Drawing	Title	Role
SD-730-793-03-C4	2MW Klystron PS 12 kV SCR Driver Board (M. Nguyen, 23 MAY 02)	Gate drive to the phase-control thyristor stacks. Opto-isolated 6N-139 input; CD4047B astable plus CD4528 monostables; MIC-4451 drivers into IXFH12N90 MOSFETs and a 60T/60T/60T pulse transformer. On-drawing timing diagram: TP1 = 50 μs $\pm$ 5%, TP2 = 16 μs $\pm$ 1 μs (adj. by R2), TP4–TP5 = 5 μs / 5 μs / 18 μs $\pm$ 5%
SD-730-793-04-C2	2MW Klystron Power Supply SCR Crowbar Trigger Board (M. Nguyen, 10-JUN-02)	Crowbar gate drive. Same 6N-139 / CD4047B / CD4538 / MIC-4451 / IXFH12N90 / 60T pulse-transformer topology, but on a millisecond envelope: TP1 = 50 ms (adj. by R1), TP2 = 5 ms, TP3 = 44 μs (adj. by R2), TP4–TP5 = 3 $\times$ 5 μs optical SCR trigger . A second output, J1 (SIP4) "Output Plug to Old Slave Trigger Bd" , driven by MIC-4427s, fires the slave boards so all four crowbar stacks trigger together
SD-730-793-07-C2	SCR Control Driver — Right Side Trigger Interconnect Bd	Carries J1 BNC "TRANSFORMER ARC TRIGGER" and J2 HFBR-2412 "F.O SCR ENABLE" receiver; drives $\pm$ A/ $\pm$ B/ $\pm$ C SCR trigger outputs; exchanges the COMMANDS bus (+12V PWR, 24V FAULT/ENABLE, FO SCR ENABLE, CB ENABLE, SLAVE CB TRIG, PLC FORCE CB, SLAVE CB OFF) with the left-side board

Drawing	Title	Role
SD-730-793-08-C1	SCR Control Driver — Left Side Trigger Interconnect Bd	Carries J1 BNC "KLYSTRON ARC TRIGGER" , J2 HFBR-2412 "F.O KLYSTRON CROWBAR" receiver and J3 HFBR-1412 "F.O STATUS" transmitter; MONITORING bus M1 (SCR ENABLE MON, CB TRIG MON, CB MONITOR, KLYS ARC MON, SCR MONITOR, KLYS CB MON)
SD-730-793-12-C3	2MW Klystron PS Monitor Board	Conditions the HVPS voltage and current monitors; outputs BNC1 "+ Voltage 10 kV/V" , BNC2 "+ Current 5A/V" , and a BNC3 "CROWBAR" input; isolated ± 15 V rails via two NMH2415S DC-DC converters
SD-730-793-13-C1	2MW Klystron Power Supply Optical SCR Trigger Board	Generates the gate pulse train through a 60T/60T/60T pulse transformer; power connector P1 carries +240 V , +120 V , GND , +5 V , AC OUT — matching the 240 V first pulse / 120 V subsequent pulses described in §9.6

These three fiber-optic ports — SCR ENABLE (right board), KLYSTRON CROWBAR (left board) and STATUS (left board) — are the B118 ↔ B514 fiber set referred to throughout §2.1, §15 and §19.1.

The crowbar SCRs were converted to optically triggered devices. SD-730-793-04-C2 carries two notes verbatim: "1. This board is used to drive the new optical SCR." and "2. For the old conventional SCR, replace resistors R3 and R37 with 78.70K, 1% Tol." R3 and R37 are the timing resistors of the two 5 μ s monostables (24.9 k Ω as built for optical SCRs). Anyone working on a crowbar trigger board must first establish which SCR type is installed in that stack. See also §20.2 G17.

Boards **-03**, **-04** and **-13** share the same **4DB-P107-06** power connector with the same pinout (+240 V, +120 V, GND, +5 V, AC OUT $\times 2$), confirming that the two-level 240 V / 120 V gate-drive scheme of §9.6 is used on all three.

Two generations of crowbar trigger board exist. sd7307940400.pdf is **SD-730-794-04-C0**, "SCR Crowbar Trigger Board", R. Cassel 11/08/99 — an earlier design using +15 V logic, a 6N-138 optocoupler, discrete IRFD9120/IRFD110 gate drivers and IXYTH12N90 switches, with R3/R4 = 147 k Ω . It was superseded by SD-730-793-04-C2 (2002), which uses +12 V logic, a 6N-139, MIC-4451 drivers and IXFH12N90 switches with R3 = 24.9 k Ω . The "Old Slave Trigger Bd" referred to on the 2002 sheet is most likely a board of this 1999 vintage. **Component values are not interchangeable between the two generations.**

Sources: All schematic PDFs in hvps/documentation/schematics/ [R9]; [R6] (PEP-II HVPS architecture); [R22] (power supply specification); [R56] (J. Sebek, HVPS hazards note).

9.4 Monitoring Signals (B514 → B118)

Four analog monitoring signals are sent from the HVPS power section to the B118 control room and are wired to a four-channel oscilloscope in the Hoffman Box area (see §18.5):

Signal	Purpose	Sensor
HVPS Output Voltage	DC voltage monitoring and regulation feedback	$\approx 10,000:1$ resistive divider (§9.3)

Signal	Purpose	Sensor
HVPS Output Current	DC current monitoring	Danfysik UltraStab DC-CT in the Termination Tank; output goes to both Slot-9 1746-NI4 Input 3 and the PS Monitor Board [R25]
Inductor 2 Voltage	T2 firing circuit timing verification (sawtooth)	Inductor tap
Transformer 1 Phase Current	T1 firing circuit health monitoring	Transformer CT

Two further sensors in the Termination Tank feed protection rather than monitoring: a **3.333 mΩ (15 A = 50 mV) shunt** in the HV return cable, wired via TS-6 20/21 to BNC-12 as the klystron arc trigger; and a **Pearson CT-110** (10 A/V) wide-bandwidth current transformer whose coaxial output feeds J1 of the Left Side Trigger Interconnect Board (SD-730-793-08-C1) and initiates a crowbar trigger on a large enough transient [R25].

Sources: [R23]; [R9]; [R25].

9.5 Stored Energy and Discharge Times

These are the numbers that govern safe access to the HVPS. They are taken directly from the J. Sebek hazards note [R56], which is the authoritative reference for HVPS lock-and-tag planning; the summary below does not replace it.

Component	Value	Stored energy	Time constant	Time to safe (≤ 50 V)
Filter inductor (each of 2)	0.3 H at 85 A	1,084 J	< 0.1 s	< 0.1 s
Phase stack snubber capacitor	0.015 μ F at 18.26 kV	2.5 J	4.2 s	24.8 s
Per-thyristor snubber capacitor	0.047 μ F	40 mJ	0.94 s	3.1 s
Filter capacitors (normal shutdown)	≈ 2 μ F net	8,788 J	< 1 s	< 1 s
Additional output capacitor	0.22 μ F	911 J	< 1 s	< 1 s
Output cables	≈ 0.006 μ F	25 J	< 1 s	< 1 s
Total output capacitance (normal shutdown)	≈ 2.23 μF	9,824 J	< 1 s	< 1 s
Total output capacitance (klystron load removed)	≈ 2.23 μ F	9,824 J	20.9 s	160 s
Filter capacitors (internal HVPS failure isolating them from the main rectifiers)	≈ 2 μ F	8,788 J	640 s	4,890 s $\approx$ 81.5 min

Normal turn-off. When the HVPS controller is commanded off it removes the firing triggers from all thyristor stacks **except the B⁺ and B⁻ stacks**. This simultaneously disables rectification and latches on a short-circuit path through which the filter-inductor current freewheels and decays; the measured inductor voltage reaches zero in about 10 ms. The output capacitors discharge through the klystron itself in well




Figure 31: HVPS power conversion chain, substation to klystron cathode.




Figure 32: PEP-II Klystron Power Supply — annotated circuit schematic showing the complete power conversion chain from the 12.5 kV 3-phase input through the disconnect/breaker, phase-shifting transformer (T0), thyristor-controlled rectifier bridges (40 kV, 80 A), filter inductors, secondary rectifier stages, 8 μ F/30 kV filter capacitors, 500 Ω /1 kW filter resistors, 30 kV/30 A rectifiers, Crowbar, and Termination Tank to the Klystron (90 kV, 27 A). The intermediate DC levels labelled on the power stage outputs (−26 kV, −52 kV, −77 kV, −90 kV) are **cumulative stage tap voltages**, not the klystron operating point — see §4.2. The SPEAR3 HVPS is directly derived from this PEP-II design

under a second (measured decay below 50 V within ~250 ms), because the Child–Langmuir load is highly conductive at high voltage [R56].

The one dangerous case. If an internal failure disconnects the large filter capacitors from the main rectifiers, their only remaining discharge path is the filter-rectifier shunt resistance, and the time to a safe voltage becomes ≈ 81.5 minutes. Any work that opens the main tank must confirm that the capacitors are still connected to the filter rectifiers before contact is made with the output section.

Sources: [R56] (all values, Table 1 and §3); [R6].

9.6 Control Power and Trigger Pulses




Figure 33: HVPS2 main oil tank at Building B514 — this large oil-immersed enclosure houses the phase-shift transformer (T0), the two rectifier transformers (T1, T2), the two filter inductors, four filter capacitors with their eight resistors, and the main and filter diode rectifier stacks. The SCR phase controller and the SCR crowbar are mounted inside it in their own isolated oil tanks with oil-to-oil bushings, so either can be serviced without contaminating the main tank oil [R6]. SPEAR1 is an identical installation

Item	Specification
DC control power	125 V DC from Substation 507, used by the local contactor controller in the switchgear; also feeds its local MPS for transformer tank overpressure, main tank oil temperature, and LCW flow through the oil cooling radiators
AC control power	Three phases of 208 V AC — one for the contactor controller, one for the main-tank oil pump, one for the switchgear compartment light
Thyristor gate trigger pulses	Trains of 16 μ s pulses in 15° bursts; first pulse 240 V, subsequent pulses 120 V. Similar amplitudes fire the crowbar thyristors

Sources: [R56] §2.3–2.4.




Figure 34: Thyristor stack assemblies inside the HVPS2 phase tank, viewed into the side access opening with the cover removed — showing columns of Powerex T8K7 SCR thyristor discs (flat black cylinders) paired on copper bus bar assemblies with gate driver signal wiring; this photo was taken with SPEAR2 drained and accessed during the April 2026 scheduled downtime; SPEAR1 contains identical hardware



Figure 35: HVPS cable switch tank at Building B514 — provides the switchover connection between the SPEAR1 and SPEAR2 HVPS units and the klystron HV cable; allows the active unit to be changed without disconnecting the klystron high-voltage cable



Figure 36: HVPS2 installation at Building B514 — outdoor view from the switchgear area showing the large beige oil-filled power supply enclosures, "SPEAR 2" identification label, and "DANGER HIGH VOLTAGE" placard on the panel door; the cable trays, conduit runs, and grounding conductors are visible overhead; a "DO NOT ENERGIZE" lock-and-tag notice is visible at left (SPEAR2 is the off-duty unit during this April 2026 downtime); SPEAR1 forms an identical installation beside this



Figure 37: HVPS2 main oil tank being accessed from the top during the 2026 HVPS inspection — a rectangular access hatch in the ribbed/bolted steel tank top plate is open, revealing the internal copper bus bar assembly and SCR bridge structures below; three personnel are visible (two engineers working at the access opening, one documenting with a notebook); the orange fiber optic conduit visible at upper left routes the SCR ENABLE, CROWBAR, and STATUS fiber signals to the B118 Hoffman Box

10 HVPS Control System — Hoffman Box (B118)

10.1 Overview

The HVPS control system is housed in a Hoffman NEMA enclosure (the "Hoffman Box") located in Building B118. It contains the PLC, analog regulation electronics, Enerpro SCR firing boards, power supplies, terminal strips, and fiber optic interfaces.

10.2 SLC-500 PLC Hardware Configuration

Slot	Module	Function
0	SLC-500 CPU (AB-1747-L532)	Main processor
1	1747-DCM (DCM-FULL)	Remote I/O adapter — presents the SLC-500 to the VXI 6008-SV1R scanner as RIO rack 1
2	1746-IO8	8-point digital I/O. OUT3 (terminal 5) drives the Ross Grounding Switch coil (120 VAC); also 12 kV and 240 V control



(a) SPEAR1 — the active unit. The door carries the identification label, a DANGER HIGH VOLTAGE placard, the lock-and-tag procedure form and the SLAC HV Switching Order.



(b) SPEAR2 — identical hardware, switched off. The posted oscilloscope trace shows 12-pulse thyristor firing waveforms from HER B-2, circa 2007.

Figure 38: HVPS controller Hoffman enclosures in Building B118. The two units are identical; one is energized and the other completely switched off, with the roles exchanged at each scheduled down.

Slot	Module	Function
3	Thermocouple Module	8-channel temperature sensing (4 channels actively scaled)
4	(empty)	Unused slot
5	1746-OX8	8-point relay output. OUT1 = Contactor On/Off (TS-5 2); OUT2 = Contactor Enable → K4 coil (TS-5 4); also SCR enable, crowbar, fast inhibit
6	1746-IB16	16-point 24 V DC digital input. IN8 = Grounding Tank oil level; IN9 = manual grounding switch aux; IN10 = crowbar tank oil; IN11 = SCR phase tank oil; IN14 = PPS 1; IN15 = PPS 2
7	1746-IV16	16-point 24 V DC digital input. IN0 = Blocking relay; IN1 = Overcurrent; IN2 = Contactor Closed/OK; IN3 = Contactor Ready; IN13 = Ross Ground Relay NO
8	AB-1746-NIO4V	4-channel analog I/O (voltage reference output, phase angle readback)
9	AB-1746-NI4	4-channel analog input. IN3 = Danfysik DC-CT output (HVPS current); also AC current and voltage monitors
10	Input module	Additional inputs (12 channels)
11	Input module	Additional inputs
12	—	Not documented in any available source; assumed empty
13	Output module	Additional outputs (4 channels)

Verification note: slots 0–11 and 13 are documented; **slot 12 is not mentioned in any source examined.** Since an SLC-500 system can span more than one chassis, the physical arrangement of slots 10–13 (single extended chassis vs. a second chassis) should be confirmed in the field. See §20.2. I/O point assignments above are taken from the original PPS wiring note [R25], which traces each signal to its terminal and PLC point.

10.3 Control Functions

The PLC implements the following control functions in ladder logic:

1. **Power-up/power-down sequencing** — Orderly startup of contactors, SCR drives, and HVPS output
2. **Voltage reference generation** — Converts the EPICS setpoint (via VXI → Remote I/O) into the analog reference for the regulator board
3. **SIG HI feedforward** — Computes an approximate SIG HI value for the Enerpro board from the target voltage
4. **Safety interlock monitoring** — Monitors oil levels, temperatures, PPS status, fiber optic signals
5. **Crowbar management** — Arms/disarms crowbar protection, handles crowbar events
6. **Communication** — Exchanges input and output data tables with the VXI IOC over the Remote I/O link (rack 1)

Key PLC Registers:

Register	Purpose
N7:10	Voltage reference output (to analog regulator)
N7:11	Phase angle / SIG HI feedforward

Register	Purpose
N7:100–N7:107	Thermocouple raw readings
N7:110–N7:113	Scaled temperature values
I:1 / O:1	Remote I/O data words (VXI interface)

PPS-related ladder rungs (from the original code review in [R25]):

Rung	Function
0002	In series with master-ready → Close Contactor (0:5/1)
0014	PPS 1 → sets the emergency-off bits
0015	PPS 1 in parallel with PPS 2 → sets B3:1 "PPS ON"
0016	PPS 1 in series with PPS 2 (and other conditions) → energizes the Ross Grounding Switch relay coil
0017	In series with Touch Panel Enable and Emergency Off Clear → OX8 OUT2. <i>The rung is labelled "Crowbar On" in the PLC listing, but [R25] concludes the label is wrong and that this rung actually drives Contactor Enable / the K4 coil.</i>
0068	PPS 2 in series with the touch-panel key enable → Bias Power (120 VAC to the Kepco supplies)

Sources: [R26] (PLC ladder logic); [R27] (PLC symbol database); [R25] (rung and I/O point analysis — original, J. Sebek); [R37]; [R38]; [R39].

10.4 Analog Regulation

The voltage regulation loop is a **summing** arrangement, not a simple cascade: the PLC supplies both a feedforward estimate of SIG HI *and* the reference for an analog error amplifier, and the Enerpro SIG HI input is the sum of the two [R40].

The analog regulator card (PC-237-230, drawing SD-237-230-14-C1) compares the PLC reference with the HVPS output voltage feedback and generates a bipolar error signal; that error is weighted and added to the PLC's unipolar feedforward output to form SIG HI. Power-line harmonics are clearly visible on the error signal in normal operation [R40].

Sources: [R40] (Enerpro board integration note — original, J. Sebek); [R12] (regulator card schematic); [R13] (voltage divider schematic).

10.5 Terminal Strips and External Connections

Internal wiring in the Hoffman Box is organised on numbered terminal strips (reference drawing WD-730-790-02-C6 [R15]). The strips identified in the original PPS wiring trace [R25] are:

Terminal strip	Function	External cable
TS-2	Control power supply distribution — system common, $\pm$ rails, status	Internal

Terminal strip	Function	External cable
TS-3	Voltage Monitor. Drawn on WD-730-790-02-C6 [R63] directly against a block titled "PEP2 RF SYSTEM KLY PS MONITOR BD SD-730-793-12" and labelled VOLTAGE MONITOR. Terminals: DC VOLTAGE *1, DC VOLTAGE *2, COM, VOLTS, AMPS, COM, −15 V, +15 V, CURRENT 5A/V	Internal
TS-4	Transformer interlocks	To HVPS tanks
TS-5	Contactors controls, 15 terminals (B118 → Switchgear)	Belden 83715 (15C #16 Teflon)
TS-6	Grounding tank / Termination Tank, 21 terminals (B118 → B132)	Belden 83709 (9C #16 Teflon) + Belden 83715
TS-7	Power distribution	Internal
TS-8	PPS permits — PPS 1 on terminal 1, PPS 2 on terminal 3, common on terminal 6	From PPS GOB1208PNE connector

PPS status indication is *not* on a terminal strip: the four external status LEDs (two green, two red) on the outside of the Hoffman Box are wired to an **AMP 8-pin connector, J2** [R25].

Confirmed by direct drawing reading (September 2026). WD-730-790-02-C6 [R63] draws the four LEDs adjacent to the AMP-8PIN J2 / AMP-8PINH F2 connectors and labels them individually: **PPS1 LED1 GRN, PPS2 LED2 GRN, PPS3 LED3 RED, PPS4 LED4 RED**. The **PPS GOB1208PNE** connector appears alongside them on the same sheet.

Verification note: TS-1 has not been identified in any source examined, and the terminal-by-terminal content of TS-2, TS-3, TS-4 and TS-7 has not been transcribed. TS-5, TS-6 and TS-8 are fully traced in [R25]. Completing the inventory requires reading WD-730-790-02-C6 directly — see §20.2.

Sources: [R25] (original PPS wiring trace, J. Sebek); [R15] (WD-730-790-02-C6).




Figure 39: HVPS controller Hoffman Box interior (SPEAR1) — the SLC-500 PLC rack (centre, CPU and I/O modules in slots 0 through 9+, labelled "SPEAR 1 RFHVPS"), four blue switching power supplies PS-1 to PS-4 (120 V $\times$ 2, 240 V and 5 V rails), the Enerpro FCOG6100 SCR firing board (dark blue PCB, lower centre), the analog regulation board (green PCB), and terminal strips TS-1 to TS-6 in the lower section; the BNC monitoring output panel is at lower right.




Figure 40: HVPS analog voltage regulation loop. The analog regulator card compares the PLC reference with the HVPS output voltage feedback and generates a *bipolar* error signal; that error is weighted and added to the PLC's *unipolar* feedforward output to form SIG HI. Power-line harmonics are clearly visible on the error signal in normal operation.

11 Enerpro SCR Firing System

11.1 Overview

The installed firing system is an **Enerpro FCOG6100 Rev K three-phase firing circuit paired with an FCOAUX60 Rev D auxiliary firing board**. The FCOG6100 is a *six-pulse* board; the FCOAUX60 provides the 30°-delayed second set of triggers that turns the pair into a 12-pulse firing system for the two six-pulse bridges. The board set receives a control voltage (SIG HI) from the summing junction described in §10.4 and converts it into a firing angle, phase-locked to the AC line through phase reference signals.

Do not confuse with the upgrade. The **Enerpro FCOG1200** is a genuine 12-pulse board and is the *replacement* selected for the HVPS controller upgrade; it is not installed. Everything in this section describes the FCOG6100 + FCOAUX60 set that is in service today. §11.4 tabulates the differences.

11.2 Current Hardware

Board	Model	Revision	Serial Numbers	Schematic
Main firing boards	Enerpro FCOG6100	Rev. K	41506, 50470, 30045	Enerpro E128; SLAC SD- 237-230-12-R0 [R13]
Auxiliary firing boards	Enerpro FCOAUX60	Rev D	03198, 03813, 1694	—

Three sets are held (SPEAR1, SPEAR2, and the test stand). Serial numbers are from the original Enerpro integration note [R40].

11.2.1 The regulator board and how SIG HI is actually formed

The SIG HI control voltage handed to the Enerpro board is produced by the SLAC-designed regulator card **SD-237-230-14-C1** (board designation PC-237-230). Its internal architecture is documented in detail by J. Sebek [R72], and three features of it are operationally important.

(a) **It is a minimum-select, not a sum.** The board has two analog control chains — one for the negative output *voltage*, one for the positive input *current* — processed through identical signal-conditioning and error-amplifier stages. They are combined through a **non-linear diode "summing junction"** in which the **anodes of two diodes are tied together**. The *lower* of the two cathode voltages wins and sets the common anode voltage, which becomes the control voltage sent to the Enerpro board. A 15 V DC supply through a 10 k Ω resistor keeps the conducting diode biased, and a **10 V Zener** clamps the anode. In other words the two loops compete and **whichever demands less output takes control** — the classic voltage-or-current-limit arrangement.

(b) **The AC current loop is saturated by design and never takes control.** The current-loop reference at **J4-2 (IL1)** is supplied from the Enerpro board's own regulated +5 V reference. Against a typical measured AC current sense of ≈ 2.2 V DC, the resulting summing-junction current drives the OP77 error amplifier hard against its $\approx +14$ V rail — above the 10 V Zener clamp — so the current chain can never win the diode select. Sebek's assessment: "*it probably is better to just eliminate this circuit which is designed to never be used in the feedback control of the Enerpro.*" **Treat the HVPS as voltage-regulated only.**

(c) **The board measures AC input current, not HVPS output current.** The regulator senses the **average input AC phase current** via the **300:5 current transformers** on the NWL transformer input [R70], full-wave rectified, paralleled and terminated in a **0.5 Ω burden resistor** [R67]. The **HVPS output current**

is **measured separately** by the Danfysik DC current transducer in the termination tank (§9.4). These are two different quantities and are frequently conflated.

Signal path summary

Signal	Path
Voltage reference (set-point)	AB Slot-8 Output 0 → J4-1 / J4-7. <i>On the board schematic this input is confusingly labelled "POS. VOLTAGE LIMIT COMMAND"; it is the reference voltage input, not a limit</i> [R72]
HV readback	Voltage dividers (§9.3) → J1A / J1B "NEG. VOLTAGE SENSE" → INA117 → error amplifier
Voltage monitor out	BUF634 → 1 k Ω → J3-1 → AB Slot-8 Input 0
Current monitor out	BUF634 → J3-2 → AB Slot-9 In-1
Current reference	Enerpro +5 V reference → J4-2 (IL1)
Control voltage out	Diode minimum-select → J4-3 SIG-HI → Enerpro SIG HI input

Loop dynamics The voltage input network is a single-pole low-pass with $\tau = 0.01$ s, i.e. a corner at **15.9 Hz**. The error amplifier ($R_{FB1} = 10.0$ k Ω , $C_{FB1} = 2.0$ μ F, $C_{FB2} = 1.0$ nF) contributes a **pure integrator**, a zero at **7.96 Hz** and a second pole at **15.9 kHz**. The system is therefore **Type 1** — no steady-state error between setpoint and readback — with an integrator gain of about -5×10^{-3} [R72].

Protection thresholds The over-voltage comparator's trip level is set by a potentiometer over **2 V to 12 V**, corresponding to HVPS output voltages of **20 kV to 120 kV**. Trip states latch in a **CD4044B**. The as-set values for both the over-voltage and over-current thresholds are **not recorded anywhere in this repository** — see §20.2 G23.

Test points

TP	Measures
TP1	Output of the current difference amplifier
TP2	Output of the over-current comparator
TP4	Inverted voltage difference of the negative voltage sense
TP5	Output of the inverting error amplifier
TP8	Output of the over-voltage comparator
TP9	Inverted input of the voltage reference
TP10	Over-voltage threshold setting
TP11	Over-current threshold setting
TP12	Inverted reference value generated by the Enerpro board

11.3 Phase References

Enerpro firing boards normally take their phase references from the *rectifier transformer secondaries*. The SPEAR3 HVPS cannot do this: there are no accessible secondary references, so the timing is instead derived

from **monitor windings on the legs of the phase-shifting transformer T0**. Those windings lead one rectifier transformer primary by 15° and lag the other by 15° — they are not in phase with either bridge.

Measured characteristics of these references, on both SPEAR1 and SPEAR2 [R40]:

Property	Value
Waveform	Sinusoidal, $\approx$ 190 V peak-to-peak
Source impedance at the HVPS	500 Ω
Voltage ratio of the monitor windings	$\approx$ 100:1 (125 V φ – φ for 12.5 kV φ – φ), 5 A RMS rating [R22] §2.2

On the installed FCOG6100 these three references enter through **connector J5** as off-board phase references and are scaled by the on-board resistors **R37, R38 and R39** (J5-1 = R37 = phase A, J5-3 = R38 = phase B, J5-5 = R39 = phase C). Inside the board the references are pulled to +5 V DC through 15 k Ω resistors in RN1, divided by RC networks, and squared up by LM324 comparators in the phase-detection circuitry [R40].

Resistor value — standard vs. SLAC. The Enerpro schematic [R13] gives R31–R39 as **1.9 M Ω , ½ W, 1%, RN70** in its parts list, and Note 10 states *”FOR OFF-BOARD PHASE REFERENCES: INSTALL R37-R39 AND J5. OMIT R31-R33 AND T1.”* SLAC's boards have **R37–R39 changed to 200 k Ω** to suit the $\approx$ 190 Vpk-pk monitor-winding reference, which is much lower than the line voltages the standard 1.9 M Ω value assumes; Sebek works the Thevenin equivalent using 200.5 k Ω (200 k Ω plus the 500 Ω source impedance) [R40]. Both values are correct for their respective contexts and must not be interchanged.

Connector roles on the FCOG6100 (from the schematic notes [R13]):

Connector	Role
J5	Off-board phase references (Note 10) — the path used at SPEAR3
J7	Provided for test reference inputs (Note 11)
J8	Cable to the FCOAUX60 auxiliary board, for gating paralleled SCRs (Note 12)
J10	50/60 Hz jack (added at revision J)
J1/P1, J2/P2	Gate drive: +A/+B/+C for line-to-load SCRs; –A/–B/–C for load-to-line SCRs

Two on-board jumper blocks configure the board: **PP1 phase reference selection** (positions 1,2,3 open + 4,5,6 closed = 0° ; the reverse = -30°) and **PP1 gate pulse profile selection** (120° burst / $2 \times 30^\circ$ bursts / $2 \times 60^\circ$ spaced pulses). The SIG HI input path is buffered by U6 with span (R42) and bias (R43) trim; Note 18 records that R52 = 150 k Ω suits $0 \text{ V} < \text{SIG HI} < 5.0 \text{ V}$ while R52 = 249 k Ω suits $0.9 \text{ V} < \text{SIG HI} < 5.9 \text{ V}$.

The ”Phase Reference Adapter” is an upgrade item, not legacy hardware. The FCOG1200 has no place for input resistors between its J7 connector and the phase-detection circuitry, so a small adapter board is being designed for the upgrade: three inputs, **six** resistors, six outputs — $3 \times 576 \text{ k}\Omega$ to J7 pins 1–3 and $3 \times 200 \text{ k}\Omega$ to J7 pins 4–6, with Enerpro replacing RN4A–C with 66.5 k Ω and RN4D–F with 287 k Ω so that one triplet is advanced and the other retarded by 15° . The mating connector is TE 3-640440-8 (Enerpro C2MTAPLG08). None of this exists in the installed system [R58].

11.4 Legacy vs. Upgrade Firing Board

	Installed (legacy)	Selected for upgrade
Board(s)	FCOG6100 Rev K (6-pulse) + FCOAUX60 Rev D (30° delay)	FCOG1200 Rev L (native 12-pulse)
Phase reference entry	J5, with on-board R37–R39 = 200 k Ω	J7, via a custom external adapter (§11.3)
Phase shift to match $\pm 15^\circ$ references	Provided by the FCOAUX60	Provided by modified RN4 resistors + matched 0.033 μ F caps
Auto-balance	Not used	On-board trimpot adjustment only (no independent bridge monitoring available)
SIG HI input	Terminated into an inverting op-amp input held at +5 V DC (R49/U6)	High-impedance buffer input, nominal 0.8–5.8 V range
Status	In service; obsolete, limited vendor support	Not yet procured/installed

Sources: [R40] (Enerpro modifications note — original, J. Sebek); [R58] (phase reference adapter note — original, J. Sebek); [R28] (Enerpro manuals and schematics); [R22] §2.2 (monitor winding specification).

12 Arc Protection and Crowbar System

12.1 Four-Layer Protection Architecture

The HVPS implements a 4-layer arc protection system to protect the klystron from destructive energy discharge during arcs. **The response times below distinguish signal latency from physical response** — the two differ by orders of magnitude, and it is the physical response that bounds the protection:

Layer	Protection	Signal latency	Physical response	Mechanism
1	SCR firing inhibit	< 1 μ s	4–8 ms	Fiber-optic SCR ENABLE signal removed. The phase-control thyristors can only stop conducting at an AC zero crossing, so complete interruption of primary current takes 4–8 ms depending on when in the cycle the arc occurs. Meanwhile the primary filter inductor limits the rate of rise of fault current, and bypassing the inductor (latching on one phase leg) dissipates its stored energy safely [R6]
2	Crowbar firing	< 1 μ s	$\approx$ 10 μs	Fiber-optic CROWBAR signal fires 4 series-connected crowbar SCR stacks, shorting the HVPS output. The crowbar has a delay of approximately 10 μ s before it conducts current [R6]
3	Filter capacitor isolation	—	Passive (instantaneous)	500 Ω series isolation resistors, in the PEP-II secondary rectifier / filter capacitor arrangement, limit how much of the 8.8 kJ stored in the filter capacitors can reach an arc

Layer	Protection	Signal la- tency	Physical re- sponse	Mechanism
4	Cable ter- mination inductors	—	Passive (in- stantaneous)	The termination-tank inductors limit the rate of rise of cable discharge current into the klystron and force a current zero. SLAC-PUB-7591 gives 200 μ H for the PEP-II design; the as-built SPEAR3 Grounding Tank drawing labels them "350 UHY 40A" (§9.3)

Layers 1 and 2 are actively commanded — in the legacy system by the **Fast Interlock Chassis 340-308** and, on a slower supervisory path, by the **SLC-500 HVPS PLC**. Layers 3 and 4 are passive properties of the circuit topology. (The *Interface Chassis* that will command layers 1 and 2 after the upgrade does not exist in the legacy system.)

12.2 Klystron Arc Energy Budget

The design objective is set by what a klystron gun can survive: the energy delivered into an arc should not exceed **60 J**, equivalently an I^2t of **40 A² s** [R6]. The four-layer architecture achieves:

Condition	Energy reaching the klystron
Crowbar operating normally	< 5 J
Crowbar disabled or failed	< 20–40 J (still inside the 60 J limit)

This is the essential point of the PEP-II design: because the stored energy is isolated by the rectifier/resistor/capacitor arrangement rather than by a series dropping resistor, **no single-point failure — including total failure of the crowbar — destroys the klystron**. Conventional supplies of this class rely on a fast crowbar plus a 10–50 Ω series resistor, which both wastes power and leaves the tube unprotected if the crowbar fails [R6].

Sources: [R6] (Cassel & Nguyen, SLAC-PUB-7591 — protection philosophy, crowbar delay, primary interruption time, energy limits); HVPS schematics [R9]; [R56] (stored energy inventory, §9.5).

Part IV

PROTECTION AND SAFETY SYSTEMS

The SPEAR3 RF station employs a multi-layer protection architecture in which five distinct actors operate in parallel, each addressing a different threat class at a different speed. At the fastest level, the **Fast Interlock Chassis 340-308** (B132) provides hardware protection against arc breakdown and RF reflected power excursions with no CPU or firmware in the trip path — its comparator-to-fiber latency is under a microsecond, though the physical response it commands takes $\approx 10 \mu\text{s}$ (crowbar) to 4–8 ms (SCR turn-off); see §12.1. The **RF MPS PLC** (Allen-Bradley PLC-5 with 1771 I/O, B132) provides equipment protection on a ~ 10 ms timescale, monitoring klystron collector power, cavity reflected power, vacuum, and cooling. The **SLC-500 HVPS PLC** (B118) monitors the HVPS internals (oil, crowbar, transformer arc, overvoltage) and drives the supervisory SCR enable relay on a ~ 10 –20 ms cycle. Sitting above all hardware protection, the **SNL state machine** (`rf_states.st,v`) provides orderly shutdown sequencing, fault recording, and operator state management at the ~ 1 s timescale. Personnel safety is enforced by two complementary PPS chains — both interfaced through the SLC-500 PLC — that control the HV vacuum contactor and the Ross grounding switch respectively.

This part of Doc L summarizes the three protection subsystems (PPS, RF MPS, and Fast IC / interlock chain). For the complete interlock architecture — including full signal flow diagrams, per-actor input/output tables, fault timeline examples, compliance analysis, and detailed fault data access procedures — see Doc I [R73].

13 Personnel Protection System (PPS) Interface

13.1 Overview

The PPS interface controls two critical safety functions: the HV vacuum contactor (which connects 12.47 kV AC power to the HVPS) and the Ross grounding switch (which grounds the HVPS output for safe access).

! KEY COMPLIANCE ISSUE: In the legacy system, both PPS chains pass through the SLC-500 PLC inside the Hoffman Box. This places a programmable logic controller in the personnel safety chain — a design that does not meet modern PPS standards.

13.2 Legacy PPS Chain 1: HV Contactor

13.3 Legacy PPS Chain 2: Ross Grounding Switch

Note: rung 0016 puts PPS 1 and PPS 2 **in series** (together with other conditions) to energize the Ross switch coil, so removing *either* PPS signal grounds the HV bus. Rung 0015 puts them in parallel to set the “PPS ON” status bit B3:1 [R25].

Caveat from the original source: [R25] states that the assignment of the PPS 1 and PPS 2 enables to pin pairs E–F and G–H, and of the readbacks to A–B and C–D, is an assumption that had not yet been confirmed with the PPS group. Treat the pin lettering as provisional until verified — see §20.2.

13.4 Identified Issues




Figure 41: The two legacy PPS chains.

Issue	Severity	Details
PLC in PPS chain	Critical	Both PPS chains route through SLC-500 PLC ladder logic
PPS wiring exposed	High	PPS wires terminate on TS-5, TS-6 and TS-8 inside the HVPS controller enclosure, co-located with non-PPS wiring
Ross switch PLC dependency	High	Ross switch coil is driven by a PLC 120 VAC output (Slot-2 IO8 OUT3), with no hardware PPS element in series
K4/RR relay label swap	Medium	Drawing WD-730-794-02-C0 labels RR as the PPS relay and K4 as the reset relay. [R25] shows the two labels are swapped: K4 is the relay that opens the contactor and disables the controller on a PPS fault, while RR acts as a reset for the TX latch. The drawing also omits the K4 NO and 86 NC contacts that belong between wire BB and the MX coil. <i>Original engineering finding by J. Sebek.</i>
Contactor re-close delay	Low	Because K4 removes all control power from the contactor controller, capacitor C6 must recharge before K3 can re-energize — this is why the contactor takes several seconds to re-close after a PPS enable is restored [R25]

Issue	Severity	Details
Hardware obsolescence	High	SLC-500 and 1746 modules are end-of-life

13.5 Relay Chain Details (Contactor Disconnect Panel)

Component	Function	Type
K4	PPS Control Relay — energized from OX8 OUT2 with the PPS common as its return; two NO contacts, one interrupting controller control power and one in series with the MX coil	Relay
MX	Remote Control Relay, 24 V DC [R69] — must be energized for K1 (and hence the L2 closing coil) and stays energized to hold L1	Relay
RR	Remote Reset Relay, 24 V DC [R69] — its NC contact is in the TX latch chain; energizing RR clears a latched TX overcurrent trip	Relay
IP	Interposing Relay, 24 V DC [R69] — added at revision 2 of the original LBL drawing alongside 27, MX and RR. Not described in any derived note; presence at SPEAR3 unconfirmed	Relay
27	Under Voltage Relay [R69]	Relay
01 / LT	Local Control Switch — Trip [R69]	Switch
M	Main operating and holding coils [R69]	Coil
TX	Auxiliary tripping relay — summarizes the eight overcurrent protection relays (instantaneous 50A/B/C/N and time 51A/B/C/N) and latches; must be de-energized for L1 to hold	Relay
L2	Closing coil — high-power coil that initially closes the vacuum contactor, fired from the stored-energy capacitor bank	Coil
L1	Holding Coil — maintains the vacuum contactor closed once L2 has closed it	Coil
S4, S5	Two spare auxiliary contact sets on the HQ3, brought out to TB2 terminals 15–17 and 18–20 in NO / COM / NC order [R66], [R69]. S5 is the PPS contact readback — see §13.2.1 for the four-drawing trace. On the Contactor Disconnect panel [R67] the six auxiliary sets are labelled by function: S1 BLOCKING RELAY, S2 OVERCURRENT, S3 CONTACTOR, S4 CLOSE READY, S5 "CONTACTS PPS", S6 TEMP	Contact
Vacuum Contactor	Ross Eng. Model HQ3 , P/N 813203 — connects 12.47 kV AC to HVPS. Switchgear rating on the original LBL drawing: 14.5 kV, 400 A, 3-pole , behind 50E fuses in 400 A holders with 50/5 CTs [R69]	HV contactor
Controller	Ross Eng. HCA-1-A , P/N 820360 — contactor controller / energy-storage driver ([R65] system view; [R66] internal schematic)	Controller

Opening timing — from the drawing's own sequence of operation [R65]

Stage	Time
Hold-in after loss of AC control voltage	$\geq$ 170 ms
L1 holding solenoid dropout	within 1 cycle ($\approx$ 17 ms)
HV contacts clear	a further $\frac{1}{2}$ – 1 cycle , nominally at the first current zero
Worst case, loss of control power $\rightarrow$ 12.47 kV interrupted	$\approx$ 200 ms
Recharge before reclose is possible	a few seconds (K2 ready relay waits on the MT1 voltage sensor)

This is not a fast interlock. Chain 1 removes primary AC power on a $\sim$ 200 ms timescale. It is a personnel-safety isolation, not a machine-protection trip; the fast paths (crowbar $\approx$ 10 μ s, SCR gate removal) are what protect the klystron.

The blocking relay defeats opening on a large fault by design. The original LBL drawing annotates BR verbatim: *"BLOCKING RELAY \u2014 PREVENT VAC CONTACTOR TRIP WHEN FAULT CURRENT EXCEEDS 2000 AMPS"* [R69]. The vacuum contactor is not rated to interrupt full fault current, so above 2000 A the BR holds it closed and the upstream **50E fuses** clear the fault instead. Opening the contactor into a large fault would destroy it. This is why GP-439-704-02-C1 states that when BR is closed, "MX and TX local off are bypassed and contactor cannot open immediately even if AC is lost".


Stored-energy hazard in the HCA-1-A driver [R66] The driver holds its closing energy at **300–400 V DC** (C1–C7, 4800 μ F, 450 V). Opening the driver door dumps both capacitors **within 5 seconds**. If that automatic dump does not operate, the drawing's Note 1 applies: decay to 80 V takes about **5 minutes** and to 40 V about **10 minutes**, so **wait at least 5 minutes after removing power and then short both capacitors** before touching live parts.

Sources: [R25] (detailed wiring and switchgear theory of operation — original, J. Sebek); [R14]; [R15]; switchgear schematics GP 439-704-02-C1, WD-730-794-02-C0, rossEngr713203.

13.5.1 The PPS contact readback — complete trace

This path is established by cross-reading four drawings. Each supplies one link, and together they form an unbroken chain:

Link	Drawing	What it establishes
1	Ross 713203 E-1 [R66]	The HQ3 contactor brings out a spare auxiliary contact set S5 on TB2-18 (NO) / TB2-19 (COM) / TB2-20 (NC)
2	ID-308-801-06-C1 [R68]	TB2-18, TB2-19 and TB2-20 carry wires 20, 21 and 22
3	GP-439-704-02-C1 [R65]	Wires 20, 21, 22 are the ones labelled "PPS (CONTACTOR)" , landing on TB3-22, TB3-23, TB3-24
4	WD-730-790-01-C3 [R67]	The Contactor Disconnect panel labels one auxiliary contact set "CONTACTS PPS"



Links 1–3 are unambiguous and mutually consistent. The dashed final hop is corroborative only: the GOB1208PNE pin pairing is recorded as an unconfirmed assumption and remains a field-verification item.

Figure 42: PPS contact readback trace across four drawings.

Caveats. Link 4 is corroborative rather than load-bearing: on [R67] the contact-set labels sit beside their symbols and the row alignment is not certain at the available scan resolution, so the specific pairing of "CONTACTS PPS" to a numbered terminal group on that sheet should not be relied on. Links 1–3 are unambiguous and mutually consistent. Separately, J. Sebek records the **GOB1208PNE pin pairing itself** (E–F / G–H for permits, A–B / C–D for readbacks) as an **unconfirmed assumption** [R25] — that last hop remains a field-verification item.

13.6 PPS Dual-Chain Interaction and Roles

The two PPS chains are **not redundant** — they perform complementary safety functions that must operate in the correct sequence:

	Chain 1 — HV Vacuum Contactor	Chain 2 — Ross Grounding Switch
Safety function	Disconnect 12.47 kV AC primary power from HVPS	Ground the HVPS HV output bus for safe personnel access
Operating state	Coil energized → contactor CLOSED (12.47 kV connected)	Coil energized → switch held OPEN (HV bus not grounded)
Safe-access state	PPS 1 removed → K4 drops → L1 drops → contactor spring-opens → 12.47 kV disconnected	PPS 2 removed → 120 VAC removed → switch spring-closes → HV bus grounded
Readback	S5 NC auxiliary contact closed = contactor OPEN = 12.47 kV removed	Ross switch NC auxiliary contact closed = switch GROUNDED = HV bus grounded
Fail-safe direction	Lose power → contactor opens → safe	Lose power → switch closes to ground → safe

Operational Sequence for Safe Access:

Personnel access to the HVPS area requires **both** chains to be in their safe state, in the correct order:

1. PPS 1 removed → Rung 0017 drops → contactor opens → 12.47 kV disconnected
2. HVPS residual energy dissipates (capacitor bank discharges through load circuits)
3. PPS 2 removed → Rung 0016 drops → Ross switch closes → HV bus grounded
4. PPS readbacks A-B and C-D loop complete → machine PPS confirms both chains safe
5. Personnel entry permitted

Restore sequence reverses the above (grounding switch opens before contactor closes).

Critical: Closing the grounding switch (Chain 2) onto a live HV bus (Chain 1 still closed) would produce a catastrophic high-energy arc fault. The machine PPS system enforces the correct sequencing through its permitting logic.

Compliance Comparison:

	Chain 1	Chain 2
PLC dependency	PPS 1 routes through SLC-500 Rung 0017	PPS 2 routes through SLC-500 Rung 0016
Hardware fail-safe	Present — OX8 relay input side wired to PPS 1 (24VDC). K4 cannot energize without PPS 1 even if PLC closes relay contact.	Absent — IO8 OUT3 drives 120 VAC to Ross coil. PLC failure energized could hold switch open without PPS 2.
Primary compliance risk	Low (hardware series PPS voltage provides physical enforcement)	Higher — PLC failure-energized scenario leaves HV bus ungrounded

Chain 2's spring-return (fail-safe toward grounded) mitigates total PPS loss, but a PLC output staying energized despite PPS removal is not protected against by any hardware means. This is the primary driver for the planned upgrade to direct PPS control through the Interface Chassis. See `pps/HoffmanBoxPPSWiring.docx` for the upgrade architecture.

For the complete signal-chain details, compliance assessment, and all relay/wiring details, see Doc I §6.8.

Sources: [R25]; `pps/HoffmanBoxPPSWiring.docx`.

14 RF Machine Protection System (MPS)

14.1 Overview

The RF MPS provides equipment/machine protection — distinct from the personnel-safety PPS. It monitors klystron operating parameters and RF station conditions, removing permits to protect equipment from damage.

14.2 Hardware Evolution

Era	Platform	Status
In service	Allen-Bradley PLC-5 with 1771-series I/O; 1771-DCM Remote I/O adapter (rack 3)	Obsolete, no vendor support, but this is the platform currently protecting the station

Era	Platform	Status
Prepared re-placement	Allen-Bradley ControlLogix 1756 (Rockwell conversion kit)	Hardware assembled, software written, tested on SPEAR3 without RF power. Not yet in service; will be commissioned as part of the LLRF upgrade [R5] §7.3

Throughout this document the RF MPS is described as the PLC-5. Where a statement applies to the future ControlLogix platform it is marked explicitly.

14.3 Protection Functions

The RF MPS monitors and protects against:

- Excessive klystron collector power (cathode power minus RF output)
- Excessive reflected power at any cavity
- Waveguide arc conditions (via interlock chassis inputs)
- Loss of cooling water
- Klystron vacuum excursion
- HVPS fault conditions

When any protection condition is triggered, the RF MPS PLC relay simultaneously drives three protective outputs (the "three-path architecture"; see Doc I §5.3–§5.4):

- **Path A:** MPS relay → hardwired to Fast Interlock Chassis → SCR ENABLE removed + CROWBAR fired → hardware HVPS kill (fiber signal < 1 μ s after relay assertion; crowbar conducts $\approx$ 10 μ s later, primary current interrupted within 4–8 ms — §12.1)
- **Path B:** Remote I/O permit bit removed → modulated RF drive cut to klystron (~10 ms)
- **Path C:** Slot 5 VXI backplane RF_FAULT asserted → EPICS alarm chain → orderly shutdown

Note: The **SLC-500 HVPS PLC** (B118) is a **separate, independent actor** in the protection hierarchy — it is **not** one of the three paths above. It monitors HVPS-internal conditions (oil, crowbar, transformer arc, overvoltage) and independently drives a supervisory SCR enable relay on a ~10–20 ms cycle. See Doc I §1.1–§1.2 for the complete five-actor architecture.

14.4 MPS Wiring

33 MPS wiring diagrams (wd3403300200 through wd3403303400) describe the complete MPS signal chain from multiple trip sources to HVPS and crowbar outputs.

Sources: MPS wiring diagrams [R21]; [R5] §7; Doc I §5.

15 Interlock Architecture and Signal Chain

15.1 Overview

The interlock system spans multiple hardware layers, from fast analog hardware interlocks to slow PLC-monitored conditions:

Layer	Speed	Hardware	Function
Fast analog	$< 1 \mu\text{s}$ (signal); $\approx 10 \mu\text{s}$ crowbar, 4–8 ms SCR (§12.1)	Fast Interlock Chassis 340-308	Arc detection, reflected power limits
PLC hardware	~ 10 ms	RF MPS PLC-5	Equipment protection calculations
PLC software	~ 10 – 20 ms	SLC-500 (HVPS)	HVPS sequencing and monitoring
EPICS supervisory	~ 1 s	VXI IOC / SNL	State machine, operator interface

15.2 Interlock Chassis

These are two different units. The **Fast Interlock Chassis 340-308** is the trip-decision element described below. The **Local Control Chassis** is a separate chassis that gathers a portion of the station's hardwired interlock and control wiring and connects it to the Fast Interlock Chassis [R5] §2.1. The two names are not synonyms.

The Fast Interlock Chassis in B132 receives and summarizes hardware interlock signals:

- Arc detection inputs from waveguide fiber optic sensors
- Reflected power monitor inputs
- RF MPS PLC permit (hardwired relay input) — removal triggers SCR ENABLE + CROWBAR
- HVPS status fiber optic signals — the B514 power section STATUS fiber goes directly to the Fast IC (populating HVPSON bit in FISTAT A16 register) and to B118 SLC-500 Slot 6 IB16. This signal is **informational only**: HVPSON=0 gates arc voltage history buffer readback in devP2RfAim.c but does **NOT** cause a Fast IC hardware trip.

Signal routing: The SPEAR MPS beam permit and orbit interlock are **not** inputs to the Fast Interlock Chassis. They wire directly to the back connector of **VXI Slot 5 (MPS Shutoff module)**. Removal of either permit causes Slot 5 to assert RF_FAULT on the VXI P2 backplane (immediate RF drive cut; no immediate hardware HVPS shutdown). The RF_FAULT assertion propagates through the EPICS alarm chain (STN:VXI:LTCH → STNPARK:SUMPY:STAT → STNOFF:SUMPY:STAT → fault_stnoff), and the SNL state machine performs an orderly HVPS shutdown ~ 6 s later via s_go_off. However, the RF drive cutoff typically initiates a **collector overpower cascade** (see Doc I §4.6): the klystron collector absorbs full cathode power → KLYSCOLLPLC:POWER exceeds trip limit → RF MPS PLC fires Path A → Fast IC removes SCR ENABLE + CROWBAR → hardware HVPS kill in ~ 20 – 30 ms in practice. See Doc I §4.2, §4.5, §4.6 for details.

It reports summarized interlock status to the VXI crate through the ARC/Interlock Module (AIM). See Doc I §1.2 for the complete signal flow diagram.

15.3 Complete Trip Chain

For complete fault timeline examples and three-path architecture details, see Doc I §8.

Sources: [R5] §17; [R16].


**Figure 43:** Complete trip chain, ordered by response time.



Figure 44: SLAC PEP-II Fast Interlock Chassis 340-308 in the B132 electronics rack — front panel showing FAULT RESET, LAMENT TIMEOUT, and BEAM ABORT controls (left cluster); 12-channel test port (TEST CH.); CH.1–CH.12 INPUT MONITOR test points (center); HVPS ON, SOLENOID ON, and FILAMENT ON status indicators; and J16 DETECTED KLYSTRON POWER coaxial input; the chassis provides sub-microsecond hardware protection by monitoring RF detector inputs and asserting SCR ENABLE removal and CROWBAR firing via fiber optic to the B514 HVPS on fault conditions

Part V

CONTROL SOFTWARE AND INSTRUMENTATION

16 EPICS IOC and SNL Software Architecture

16.1 IOC Platform

The VXI crate Slot 0 processor runs VxWorks RTOS with an EPICS IOC. The IOC hosts 6 SNL (State Notation Language) programs compiled into a single rfSeq library:

Program	Lines	Instances	Authors	Function
rf_states.st,v	2,227	1	R.C. Sass, M. Laznovsky, S. Allison	Master station state machine
rf_calib.st,v	3,345	1	R. Claus	Calibration sequences
rf_tuner_loop.st,v	555	4 (per cavity)	—	Cavity tuner motor control
rf_hvps_loop.st,v	343	1	—	HVPS supervisory control
rf_dac_loop.st,v	290	1	S. Allison	Drive/gap voltage DAC control
rf_msgs.st,v	352	1	—	Message logging, TAXI monitoring

Plus 11 header/macro files (1,111 lines) defining PV names, status codes, and control macros.

Sources: Legacy source code in `spear-rf-code-legacy/rfApp/src/seq/` [R16]–[R20]. The line and state counts in the table above are taken from `spear-rf-code-legacy/codeReviewTechnicalNotes/05-snl-state-machines.md`; only RCS ,v archives are present in the repository, so they could not be recounted from working files (§21).

16.2 rf_states.st — Master Station State Machine

Primary States: OFF (0) → PARK (1) → TUNE (2) → ON_FM (3) → ON_CW (4)

State architecture: 3 concurrent state sets:

1. **ss rf_states** — Main state machine with 5 primary states + 17 transition states
2. **ss rf_statesLP** — Loop protection (concurrent monitoring)
3. **ss rf_statesFF** — Fault file capture (asynchronous)

Total: 23 states across 3 concurrent state sets.

State transitions:

- OFF → PARK: Operator command; initializes VXI modules, loads DSP firmware
- PARK → TUNE: Operator command; enables drive power, engages direct feedback loop
- TUNE → ON_FM: Enables comb and ripple loops (PEP-II modes)
- TUNE → ON_CW (direct): Bypasses ON_FM, goes straight to full power
- Any → OFF: Fault or operator shutdown; orderly disengagement of all loops

16.3 rf_hvps_loop.st — HVPS Supervisory Control

States: init → off → proc (processing/conditioning) → on

Processing mode carefully ramps HVPS voltage while monitoring cavity vacuum. If vacuum exceeds limits, voltage is reduced. This is used during cavity conditioning and post-trip recovery.

16 status codes (from source): The HVPS reports status via integer codes that the SNL program interprets for operator display and automated responses.

16.4 rf_tuner_loop.st — Cavity Tuner Control

Runs as 4 instances (one per cavity) via CAV macro substitution. Implements a slow feedback loop that maintains cavity resonant frequency by:

1. Reading cavity phase angle (from IQA module)
2. Comparing against setpoint (optimal detuning for current beam current)
3. Commanding stepper motor moves via AB 1746-HSTP1 controller

5 SNL states, 2 control algorithms (phase-feedback-based position tuning for resonance maintenance, and position homing for park/on transitions) plus a loop-off monitoring state.

16.5 rf_dac_loop.st — Drive/Gap Voltage DAC Control

Manages the RFP module's octal DACs that control drive power and gap voltage setpoints. The loop operates differently depending on whether the direct feedback loop is on or off, and transitions between TUNE and OPERATE modes.

! ELIMINATED IN UPGRADE: This program is entirely replaced by the LLRF9 internal vector modulator control.

16.6 rf_calib.st — Calibration Sequences

The largest SNL program (3,345 lines) implements 28 calibration measurement states including:

- IQA module amplitude/phase calibration
- Klystron gain measurement
- Cavity tuner characterization
- Feedback loop gain optimization

16.7 rf_msgs.st — Message Logging

Monitors CAMAC TAXI communication errors, VXI module health, and system messages. Reports status to EPICS archiver.

17 Tuner Control System

17.1 Configuration Currently in Service

Component	Detail
Controllers	Allen-Bradley 1746-HSTP1 stepper modules (4 units) in chassis 340-315, SN08

Component	Detail
Drivers	Superior Electric SLO-SYN SS2000MD4-M PWM step drive translators (one per motor)
Motors	Superior Electric SLO-SYN M093-FC11 (NEMA 34D, 4 units)
Communication	Allen-Bradley Remote I/O, adapter (rack) 2, from the VXI 6008-SV1R scanner
Software	<code>rf_tuner_loop.st,v</code> (SNL, 4 instances, 2 Hz)
Position feedback	Linear potentiometer per tuner — indication only

17.2 Planned Upgrade Configuration (not yet installed)

Component	Detail
Controller	Galil DMC-4143 Rev 1.3h 4-axis motion controller in a new SLAC-built chassis
Motors	Same SLO-SYN M093-FC11 (retained)
Communication	Ethernet (with heartbeat monitoring)
Position Feedback	Linear potentiometers on each tuner (retained)

Status. The Galil controller has been procured and developed on the bench. In August 2025 it was connected to the installed cavity tuner motors and successfully drove them [R34]; the session log records firmware DMC4143 Rev 1.3h, amplifier AMP1 43547 Rev 4, and a series of manual jog and speed tests. **It has not been installed as the operating controller and is not in the control loop.** It is expected to go online when the LLRF upgrade project completes. Until then the 1746-HSTP1 / SS2000MD4 chain in §17.1 is the system of record.

17.3 Tuner Motion Parameters

Values below are from the deployed EPICS steppermotor record (`rf_cav.db,v`, device type AB-1746HSTP1) and are the numbers the loop actually runs with. See §8.2 for the mechanical assembly and [R57] for the full control-loop analysis.

Parameter	Value	Record field
Step resolution	0.003175 mm/step (1.27 mm/rev ÷ 400 steps/rev)	DIST
Slew velocity	3 mm/s	VELO
Acceleration	0.5 mm/s ²	ACCL
Upper travel limit	+18 mm	DRVH
Lower travel limit	−29.5 mm	DRVL
Retry deadband	0.015875 mm (5 steps)	RDBD
Engineering units	mm	EGU
Loop rate	2 Hz	<code>rf_tuner_loop.st,v</code>

Parameter	Value	Record field
Phase deadband (design)	0.25°	rf_cav.db,v INPB (commented out in the DB source)
Phase-to-position conversion	0.020–0.030 mm/°	rf_cav.db,v INPC (commented out; restored by autosave)
Maximum move per cycle	1 mm	rf_cav.db,v INPD (commented out; restored by autosave)

Important operational caveat: the deadband, conversion factor and per-cycle clamp are **commented out in the database source** and default to zero on a cold start without autosave — in which case the computed move is always zero and the tuner does not respond. In normal operation these values are restored by autosave. The outer load-angle (cavity voltage) loop is likewise structurally clamped to zero and is not active in SPEAR3. Both behaviours are analysed in [R57] §§4.2, 5.3, 10.2.

Sources: [R29]; [R30]; [R31]; [R34]; [R35]; [R36]; [R5] §10; [R57] (tuner control system analysis); spear-rf-code-legacy/rfApp/Db/rf_cav.db,v.



Figure 45: Allen-Bradley Cavity Tuner Motor Driver chassis (SLAC 340-315, SN08) in the B132 electronics rack — showing the SLC adapter module (leftmost, with COMM FAULT indicator and STATUS showing RUN/fault) followed by four AB 1746-HSTP1 STEPPER modules (each with RUN, CCW, CW, ERR, FLT indicators; green RUN lights confirm active communication), plus one additional STEPPER module at far right. This chassis is the motion controller currently driving all four cavity tuners; it is to be replaced by the Galil DMC-4143 when the LLRF upgrade project completes



Figure 46: Allen-Bradley Cavity Tuner Motor Driver chassis (SLAC 340-315, SN08) — closed front panel view showing the rack-mounted chassis faceplate with designation label, SLAC EEIP Accepted sticker, and two green power-health LEDs (+24V and +5V both illuminated); the chassis occupies approximately four rack units; slot position labels 08–13 from the adjacent rack frame are visible; the interior modules (SLC adapter and four 1746-HSTP1 stepper controllers) are shown in Figure 17-1

18 Diagnostics, Calibration and Monitoring

18.1 RF Signal Monitoring

24 RF signals are monitored across the waveguide network (see §7.2 for complete table). In the legacy system, these are measured by the VXI IQA modules. In the upgrade, they will be distributed across LLRF9 units and the Waveform Buffer System.

18.2 HVPS Monitoring

4 analog monitoring signals from B514 to B118 (see §9.4). Additionally, the PLC monitors:

- 8 thermocouple channels (4 actively scaled to engineering units)
- Oil level switches (main tank, phase tank, crowbar tank)
- Contactor and grounding switch status
- All fiber optic signal states

18.3 Fault Recording

Legacy fault file system: On any fault triggering a station trip, the VXI IOC captures 11 signal channels to /dat/FAULT<channel>_<N> files (channels in capture order: RfpSI, RfpSQ, RfpCI, RfpCQ, CmbI, CmbQ, Iqa1Amp, Iqa2Amp, Gvf, Aim, Iqa3Amp). NUMFILES = 11 in rf_states.st,v is the channel count; for SPEAR3 the CF2 module is not installed, so the #else branch of #ifdef CF2 applies, giving CmbI/CmbQ (comb filter channels) in place of Cf2I/Cf2Q. The eleventh channel (IQA-3) is only captured when the IOC startup script sets the IQA3MACROS environment variable; iocBoot/b132-iocrf/st.cmd,v does set it (IQA3MACROS=R=SRF1), so all 11 channels are written on SPEAR3. Otherwise only 10 are.

The suffix **N** is the fault slot number, which cycles **1 to 15** (`NUMFAULTS = 15`) and is published as `{STN}:STN:FAULT:NUM`; the corresponding event timestamps are in `{STN}:STN:FAULT:TIME1` through `TIME15`. Capture works by temporarily redirecting each module's history-buffer filename and size records (`MODU.AHFS`, `MODU.AHSZ`), triggering the dump (`MODU.GAHS`), waiting on the status field (`MODU.ASTT`), then restoring the previous filenames and sizes. These files preserve pre-fault waveforms for post-mortem analysis.

18.4 Calibration Data

Calibration sequences are implemented in `rf_calib.st,v` (28 measurement states). Key calibrations include:

- RF signal amplitude and phase calibration against known references
- Klystron gain curve measurement
- Cavity detuning characterization
- Tuner motor step-to-frequency conversion factors

Sources: [R19]; [R24]; [R18].

18.5 Fault Data Availability and Analysis

Four data sources capture fault event information at different time scales. Full access procedures and a step-by-step analysis guide are provided in Doc I Part X (§10.1–10.6). Summary:

Source	What It Captures	Storage Location	Access
AIM Hardware History Buffer	12 arc channel voltage waveforms + HVPS voltage; continuous ADC ring buffer, freezes on fault	VXI AIM on-board memory; exported to <code>IOC /dat/aimHist.dat</code>	Read <code>{STN}:STN:AIM:ARCLTDSTT</code> PV for latched arc channel bits; see Doc I §10.2
SNL Fault Files (<code>/dat/FAULT*_N</code>)	11 RF/IQA channels: RFP I/Q, comb I/Q, IQA amplitude waveforms, GVF and AIM snapshots	VxWorks <code>/dat/</code> directory on B132 VXI IOC; slot number N cycles 1–15 (<code>NUMFAULTS = 15</code>)	Read <code>{STN}:STN:FAULT:NUM</code> for the current slot and <code>{STN}:STN:FAULT:TIME1...TIME15</code> for the event timestamps; transfer via NFS/FTP; see Doc I §10.3
B118 Oscilloscope (4 channels)	CH1: HVPS DC voltage; CH2: HVPS DC current; CH3: Inductor T2 sawtooth voltage; CH4: Transformer T1 AC phase current	Standalone oscilloscope in B118 Hoffman Box area — not connected to EPICS	Direct field observation; single-shot trigger or freeze at fault; export via USB or photograph screen; EPICS scalar readback at 1 Hz via <code>{STN}:HVPS:VOLT</code> and <code>{STN}:HVPS:CURR</code> (Remote I/O AI records); see Doc I §10.4
EPICS Channel Archiver	All EPICS PVs at ~1 Hz, multi-year rolling history	EPICS archiver server (SLAC controls group)	Strip Chart GUI, web interface, or Python Archiver Appliance REST API

Key PVs to check after any fault event (see Doc I Appendix A for full list):

PV	Significance
{STN}:STN:AIM:ARCLTDSTT	Which arc channels fired? (bits 0–3 = cavities, bit 4 = klystron, bit 5 = circulator; all zeros = non-arc fault)
{STN}:HVPSXFORM:ARC:LTCH	HV transformer internal arc
{STN}:HVPS:CROWBAR:LTCH	Crowbar fired
{STN}:STN:MPS:LTCH	RF MPS PLC trip
{STN}:HVPSSTN:SUMY:LTCH	Aggregated HVPS fault summary
{STN}:STN:FAULT:NUM	Fault file slot number (1–15) — use to locate /dat/FAULT*_N
{STN}:STN:FAULT:TIME1 ... TIME15	Timestamp of each stored fault event

Sources: Doc I Part X (§10.1–10.6); §18.2; rfApp/Db/rf_hvps.db (HVPS scalar PV definitions).

Part VI

INTEGRATION AND LEGACY CONSIDERATIONS

19 Cabling and Interconnections

19.1 Major Cable Runs

Cable Run	Cable Type	Conductors	Route
B118 → Switchgear (Contactor)	Belden 83715	15C #16 Teflon	TS-5 to contactor controller
B118 → Termination Tank (Grounding)	Belden 83709 + Belden 83715	9C + 15C #16 Teflon	TS-6 to grounding tank
B118 → B514 (SCR triggers)	Electrical cable pairs	12 pairs	Controller to Phase Tank thyristor stacks
B118 → B514 (Fiber optic)	Fiber optic	SCR ENABLE, CROWBAR, STATUS	Controller to HVPS power section
B132 → Tunnel (RF signals)	Coax cables	Forward, reflected, probe per cavity	LLRF inputs from cavities
B132 → Tunnel (Motor)	Multi-conductor	Stepper motor phase leads + linear potentiometer feedback per cavity	To tuner assemblies

19.2 Connector Types

Interface	Connector	Notes
PPS	GOB1208PNE	Lockable, military-grade
RF signals	SMA/N-type	50Ω coaxial
Fiber optic	HFBR series	Avago/Broadcom
PLC communication	Allen-Bradley Remote I/O (twinaxial "blue hose")	6008-SV1R scanner to 1747-DCM / 1771-DCM adapters
Galil Ethernet	RJ-45	Standard Ethernet

Sources: [R14]; [R15]; [R5] §3.

20 Known Issues, Limitations and Legacy Debt

20.1 Critical Issues

Issue	Cate- gory	Impact	Details
PPS compliance	Safety	Critical	PLC in PPS chain; PPS wires exposed in HVPS controller enclosure
VXI crate obsolescence	Hard- ware	Critical	Custom SLAC modules (RFP, IQA, CLK, AIM) — no replacements available. The whole crate is superseded by two Dimtel LLRF9/476 units in the upgrade [R51], [R52]
SLC-500 PLC end-of-life	Hard- ware	High	Allen-Bradley discontinued; no vendor support
PLC-5 MPS platform	Hard- ware	High	Allen-Bradley discontinued; no vendor support
SLO-SYN driver obsolescence	Hard- ware	Medium	SS2000MD4-M discontinued
VxWorks/SNL software	Soft- ware	High	PEP-II era code (1997); unsupported OS; no modern development tools

20.2 Documentation Gaps and Items Requiring Field Verification

#	Gap	Impact	Notes
G1	K4/RR relay label error	Medium	Drawing WD-730-794-02-C0 has the RR and K4 labels swapped, and omits the K4 NO / 86 NC contacts between wire BB and the MX coil. Analysed and corrected in [R25]; as-built drawings still show the incorrect labels (§13.4)
G2	Manual grounding switch contact type	Low	Inconsistency between WD-730-794-06-C0 (NO) and SD-730-790-05-C1 (NC) for the "mushroom" switch auxiliary contact monitored on Slot-6 IN9. Field verification required [R25]
G3	MPS trip logic completeness	Medium	33 MPS wiring diagrams exist ([R21]) but a consolidated trip logic truth table has not been assembled
G4	Operational setpoints and limits	High	Alarm limits, tuner deadbands, safe operating envelopes not systematically captured. Some of the tuner values are known to be autosave-dependent (§17.3)
G5	Terminal strip inventory incomplete	Medium	TS-5, TS-6 and TS-8 are fully traced in [R25]. TS-1 has not been identified at all, and TS-2/TS-3/TS-4/TS-7 are named but not transcribed terminal-by-terminal. Requires reading WD-730-790-02-C6 directly (§10.5)
G6	SLC-500 slot 12	Low	No source documents slot 12, and the 0–13 span implies more than one chassis. Physical arrangement of slots 10–13 needs field confirmation (§10.2)
G7	IQA per-connector channel map	Medium	The IQA-1/2/3 functional split is established, but which of the 8 RF inputs on each module carries which signal has not been recovered. Take from [R33] and confirm in the field (§5.4)

#	Gap	Impact	Notes
G8	Fate of the VXI slot-5 RF amplifier	Low	[R53] documents an RF amplifier module in slot 5 (added because the incoming 476.3 MHz was below the clock's +9.0 dBm minimum). The present crate has MPS Shutoff in slot 5 and Link Passthru in slot 6. Whether the amplifier function survives, and where, is undocumented (§5.8.1)
G9	PPS connector pin lettering	Medium	[R25] states that the assignment of PPS 1 / PPS 2 enables to pin pairs E–F and G–H, and readbacks to A–B and C–D, is an unconfirmed assumption. Needs confirmation with the PPS group (§13.3)
G10	PPS connector part number	Low	Originally a Burndy circular 8-pin; possibly now a Souriau Trim Trio equivalent (GOB1208PNE). Exact current part number requires field verification [R25]
G11	Local Control Chassis	Medium	Named in [R5] §2.1 and present in B132, but its I/O list, drawing number and exact relationship to the Fast Interlock Chassis are not documented anywhere (§2.1.1, §15.2)
G12	HVPS regulation specification	Low	SLAC-PUB-7591 [R6] specifies < 0.1% regulation; a later PEP-II slide set states $\pm 0.5\%$. This document follows the published paper (§4.2). The as-measured regulation of the SPEAR3 units has not been recorded
G13	Klystron name-plate data	Low	The installed tube is a Marconi unit rated 1.5 MW (§6.1). Its exact type number, serial number and installation date are not recorded in this repository
G15	sd2372301299.md filename	Low	The note file is named sd2372301299 but the drawing it describes is sd2372301200.pdf (SD-237-230-12-R0). No sd2372301299.pdf exists in the repository
G16	Inductor designator collision	Low	The HVPS primary filter inductors and the termination-tank inductors are both designated L1/L2 on their respective drawings. The designation "L3/L4" for the termination-tank pair does not appear on SD-730-790-05-C1. Use "primary filter inductors" and "termination-tank inductors" to disambiguate
G17	Crowbar SCR type per stack	High	SD-730-793-04-C2 supports both optically triggered and conventional crowbar SCRs, distinguished only by the values of R3 and R37 (24.9 k Ω optical / 78.70 k Ω conventional). Confirm which type is installed in each of the four crowbar stacks and record it, before any board is swapped or re-stuffed
G19	Manual grounding switch contact sense	Medium	WD-730-794-06-C0 wires the NO contact ("NO MANUAL GRN SW"), while SD-730-790-05-C1 shows SW1 with both NC and NO available. WD-730-794-06-C0 is additionally a test stand drawing with no revision entries. Confirm which contact is landed at SPEAR3

#	Gap	Impact	Notes
G20	TS-5 terminal assignment	Medium	The signal <i>names</i> on TS-5 are unambiguous on [R67] (COMMON, ON, PPS COM, PPS, RESET, AUX TRIP, CONTACTOR CLOSED, ENABLE, CONTACTOR READY, PPS), but the drawing's labels sit between terminal rows and disagree in places with J. Sebek's field trace [R25] (which has terminal 7 = Blocking, 9 = Overcurrent where the drawing reads AUX TRIP and CONTACTOR CLOSED). Confirm terminal-by-terminal before rewiring
G21	Cabinet temperature sensor	Low	ID-308-801-06-C1 [R68] annotates the switchgear cabinet temperature sensor "TO BE ADDED LATER" . Confirm whether it was ever installed; if not, the S6 "TEMP" auxiliary contact may be unused
G22	"LOW PRESS SW (SPEAR ONLY)"	Low	The RFPS interlock block on [R68] carries a low-pressure switch annotated "(SPEAR ONLY)" , i.e. an interlock specific to the SPEAR installation rather than PEP-II. Confirm it is present, wired and tested
G23	Regulator board trip thresholds	High	The over-voltage comparator on SD-237-230-14-C1 is potentiometer-set anywhere from 2 V to 12 V , i.e. 20 kV to 120 kV of HVPS output. The over-current threshold is likewise adjustable. Neither as-set value is recorded anywhere in this repository. Measure both (TP10 and TP11), publish the intended values, and confirm the boards are set to them [R72]
G24	Regulator input burden resistor	Low	The AC current-sense burden resistor is given as 0.5 Ω [R67]. Sebek flags this as needing confirmation and suggests measuring between terminals 1 and 2 on TS-4 [R72]

Gap identifiers are stable: a gap that is closed is removed from this table and its number is *not* reused, so the numbering is not contiguous.

20.3 Operational Workarounds

Several operational workarounds are in place due to legacy limitations:

- Manual operator intervention required for some fault recovery sequences that could be automated
- Cavity processing (conditioning) requires careful manual voltage ramping due to limited automation in legacy SNL code. The cavities were originally conditioned off-line on the automated SLAC 476 MHz processing facility [R49], which is not available for in-situ re-conditioning
- PEP-II functions (comb filter, GVF/GAP) are absent from the SPEAR3 crate; the station reference is instead supplied by RFP-resident DACs driven by a slow EPICS loop (§5.6)
- Several tuner loop parameters are commented out in the database source and depend on autosave restore to be non-zero (§17.3)

21 Verification Status

This matrix records how each part of the document was substantiated during the v3.0 verification pass. It is intended to tell a reader how much weight to place on each section, and to direct the remaining review effort.

Legend	Meaning
A	Verified against an original engineering source (drawing, specification, human-authored note, published paper) or against the legacy source code itself
B	Derived from an original source but with an interpretation step that a reviewer should check
C	Line/state counts taken from a repository analysis file rather than recounted from the source itself
F	Requires field verification (listed in §20.2)

Section	Status	Basis
§2.1, §2.1.1 Block diagram and blocks	A/B	srf1.substitutions,v, config.ab,v, rf_ab_4CV.substitutions,v, [R53], [R5]
§3 Physical layout	A	[R5] §3, [R25], [R14]
§4.1 RF parameters	A	[R53] Table 1, [R8], [R55], [R7]
§4.2, §4.3 HVPS parameters	A	[R56], [R6], [R22]
§5.1–§5.2 VXI inventory	A	srf1.substitutions,v lines 103–104, crat_vxi_13slot.template
§5.3 RFP	A/B	[R53] §2.4; PV names verified in rf_fbck.db, rfp.db
§5.4 IQA	A/F	[R53] §2.7; per-connector map outstanding (G7)
§5.5 AIM	A	[R53] §2.8, p2RfAimDef.h,v, rf_states.st,v
§5.6 Feedback loops	A	[R53] §2.4, [R8]
§5.7, §5.7.1 Communication	A	config.ab,v, rf_ab_4CV.substitutions,v, allenBradley.html,v
§5.8 CLK module	A	[R53] §§2.3, 3.0–3.1; [R54]
§6 Klystron and drive	A/F	[R5], [R56]; nameplate outstanding (G13)
§7 Waveguide network	B	[R5] §4.2, §4.6; [R33]
§8 Cavities and tuners	A	[R7], [R57], rf_cav.db,v
§9.1–§9.4 HVPS power section	A	[R6], [R22], [R56], hvps/documentation/schematics/
§9.5 Stored energy	A	[R56] Table 1
§9.6 Control power and triggers	A	[R56] §2.3–2.4
§10.1–§10.4 HVPS controller	A/B	[R25], [R40], [R26], [R27]
§10.5 Terminal strips	A/F	[R25]; inventory incomplete (G5)
§11 Enerpro	A	[R40], [R58] — both original J. Sebek notes
§12 Arc protection	A	[R6]
§13 PPS	A/F	[R25]; pin lettering unconfirmed (G9)
§14 RF MPS	B/F	[R5] §7, [R21], Doc I §5; trip truth table outstanding (G3)
§15 Interlock chain	B	Doc I §§1–5; [R5] §2.1

Section	Status	Basis
§16 SNL software	C	Line counts and state counts from <code>spear-rf-code-legacy/codeReviewTechnicalNotes/05-snl-state-machines.md</code> ; only RCS ,v archives are present in the repository, so working-file line counts could not be recounted directly
§17 Tuner control	A	<code>rf_cav.db,v</code> , [R34], [R57]
§18 Diagnostics	A	<code>rf_states.st,v</code> , <code>st.cmd,v</code> , Doc I Part X
§19 Cabling	B	[R14], [R15], [R25]
§20 Known issues	A/B	Consolidated from the above

21.1 Appendix A — Source Document Reference Index

All references cited in this document, organized by reference number. Web-accessible copies are tagged [W*n*] in the right-hand column and listed with their URLs in §A.4.

21.1.1 A.1 Published Papers and Conference Proceedings

Ref	Citation	Web
[R1]	McIntosh, P. et al., "The SPEAR3 RF System," SLAC-PUB-10983 , EPAC 2004, Lucerne. OSTI 839730, DOI: 10.2172/839730. <i>Describes the station as installed in 2003 with a 1.2 MW klystron and four 476.3 MHz HOM-damped copper cavities at a design 3.2 MV (800 kV/cavity).</i>	[W1], [W2]
[R2]	Corredoura, P., "Architecture and Performance of the PEP-II Low-Level RF System," SLAC-PUB-8124 , PAC 1999. OSTI 10204, DOI: 10.2172/10204. <i>Not to be confused with SLAC-PUB-8498, which is [R3].</i>	[W3], [W4]
[R3]	Corredoura, P., Allison, S., Ross, W., Sass, R., Tighe, R., "Experience with the PEP-II RF System at High Beam Currents," SLAC-PUB-8498 , EPAC 2000, arXiv:physics/0007029	[W5]
[R6]	Cassel, R. and Nguyen, M.N., "A Unique Power Supply for the PEP II Klystron at SLAC," SLAC-PUB-7591 , PAC 1997. DOI: 10.1109/PAC.1997.753249. <i>Authoritative for HVPS topology, crowbar delay ($\approx 10 \mu\text{s}$), primary interruption time (4–8 ms), regulation ($<0.1\%$), ripple ($<1\%$ p-p, $<0.2\%$ RMS above 60 kV), and klystron arc energy limits.</i>	[W6]
[R41]	Ziomek, C. and Corredoura, P., "Digital I/Q Demodulator," Proc. PAC 1995	—
[R42]	Fox, J. et al., "Longitudinal Feedback System for PEP-II," Phys. Rev. ST Accel. Beams 13, 052802 (2010)	—
[R43]	Fowkes, W.R. et al., "PEP-II Prototype Klystron," SLAC-PUB-6093, April 1993	[W14]
[R44]	Fowkes, W.R. et al., "1.2 MW Klystron for Asymmetric Storage Ring B Factory," SLAC-PUB-6778, March 1995	[W13]
[R45]	Rimmer, R.A., "RF Cavity Development for the PEP-II B Factory," LBL-33360, November 1992. OSTI 7066243. <i>Cavity design basis for the four SPEAR3 cavities (§8.1).</i>	[W7]
[R46]	Rimmer, R.A. et al., "High-Power Testing of the First PEP-II RF Cavity," SLAC-PUB-7210 / LBNL-38147 / UCRL-JC-126198, EPAC'96, June 1996. OSTI 505666. <i>150 kW wall dissipation, three rectangular HOM waveguides and broadband loads — the arrangement described in §8.1.</i>	[W8]

Ref	Citation	Web
[R47]	Robinson, K.W., "Stability of Beam in Radiofrequency System," CEA Report CEAL-1010, February 1964. OSTI 4075988, DOI: 10.2172/4075988. <i>Origin of the Robinson stability criterion that motivates the direct loop (§5.6).</i>	[W9], [W17]
[R48]	Boussard, D., "Control of Cavities with High Beam Loading," IEEE Trans. Nucl. Sci. NS-32, PAC 1985. <i>Classical treatment of RF feedback under heavy beam loading (§5.6).</i>	[W10]
[R49]	McIntosh, P., "An Automated 476 MHz RF Cavity Processing Facility at SLAC," SLAC-PUB-10083, July 2003. OSTI 815601, DOI: 10.2172/815601. <i>The facility used to condition the SPEAR3 cavities before installation — relevant to the manual conditioning workaround in §20.3.</i>	[W15], [W16]

21.1.2 A.2 Textbooks and General References

Ref	Citation	Web
[R50]	Wiedemann, H., <i>Particle Accelerator Physics</i> , 4th ed., Springer, 2015. <i>General reference for the beam dynamics summarised in §4.1.</i>	—
[R51]	Dimtel, Inc., "LLRF9 Product Page." <i>The replacement LLRF controller; cited here only to identify what supersedes the VXI system described in §5.</i>	[W11]
[R52]	Dimtel, Inc., "LLRF9/500 Specifications."	[W12]
[R59]	Branlard, J., "Low Level RF for SRF Accelerators," LINAC 2014. <i>Background tutorial on LLRF architectures.</i>	[W18]

21.1.3 A.3 Original Engineering Documents in Repository

Ref	Document	Repository Path
[R4]	LLRF9 Commissioning Tests (J. Sebek, 2021) — source of the ~712 kV/cavity operating gap voltage	11rf/tests/11rf9Tests.pdf, 11rf/tests/11rf9Tests.tex
[R5]	SPEAR3 LLRF Upgrade System Physical Design Report, R2 (28 April 2026) — the authoritative upgrade reference	Designs/docx/SPEAR3_LLRF_PDR_R2.docx; typeset R1 at Designs/tex/doc0-system-design/0_system_design_report.pdf
[R7]	PEP-II RF System Description (Schwarz, PS-340-330-51-R0) — cavity R_s , Q_0 , β	11rf/documentation/legacyArchitecture/ps3403305100.pdf
[R8]	LLRF Feedback Loop Description (Schwarz, PS-340-330-52-R0)	11rf/documentation/legacyArchitecture/ps3403305200.pdf (= feedbackLoopDescriptionps3403305200.pdf)
[R9]	HVPS System Schematic (top-level)	hvps/documentation/schematics/sd7307900101.pdf
[R10]	LLRF Block Diagram (HER configuration)	11rf/documentation/legacyArchitecture/bd3403300000.pdf
[R11]	LLRF Block Diagram (alternative view)	11rf/documentation/legacyArchitecture/bd3403300100.pdf

Ref	Document	Repository Path
[R12]	Analog Regulator Card Schematic	hvps/documentation/schematics/ sd2372301401.pdf
[R13]	Enerpro General Purpose 3-Phase Firing Circuit, PCB PN FCOG6100 — SLAC SD-237-230-12-R0 / Enerpro drawing E128, drawn W.C. Mitchell 9/29/87. <i>This file is not a voltage-divider drawing, despite having been catalogued as one; the dividers are on [R71].</i>	hvps/documentation/schematics/ sd2372301200.pdf
[R14]	Interconnection: B118 ↔ Contactor ↔ Termination Tank	hvps/documentation/wiringDiagrams/ wd7307900103.pdf
[R15]	Hoffman Box Internal Wiring	hvps/documentation/wiringDiagrams/ wd7307900206.pdf
[R16]	Legacy SNL: rf_states.st (master state machine)	spear-rf-code-legacy/rfApp/src/seq/rf_ states.st,v
[R17]	Legacy SNL: rf_hvps_loop.st (HVPS control)	spear-rf-code-legacy/rfApp/src/seq/rf_ hvps_loop.st,v
[R18]	Legacy SNL: rf_tuner_loop.st (tuner control)	spear-rf-code-legacy/rfApp/src/seq/rf_ tuner_loop.st,v
[R19]	Legacy SNL: rf_calib.st (calibration sequences)	spear-rf-code-legacy/rfApp/src/seq/rf_ calib.st,v
[R20]	Legacy SNL: rf_msgs.st (message logging)	spear-rf-code-legacy/rfApp/src/seq/rf_ msgs.st,v
[R21]	MPS Wiring Diagrams (33 drawings)	11rf/documentation/mpsWiringD iagrams/wd3403300200.pdf through wd3403303400.pdf
[R22]	PEP-II HVPS Technical Specification (PS-341-360-01-R2)	hvps/architecture/originalDocuments/ ps3413600102.pdf
[R23]	HVPS Monitor Connections	hvps/documentation/wiringDiagrams/hvpsM onitorConnections.xlsx
[R24]	HVPS Measurements (March 2022)	hvps/documentation/plc/hvpsM easurements20220314.xlsx
[R25]	PPS Wiring in Hoffman Box (J. Sebek) — terminal-by-terminal PPS trace, PLC rung analysis, switchgear theory of operation, K4/RR label finding	pps/HoffmanBoxPPSWiring.docx
[R26]	PLC Ladder Logic Printout (Cassel)	hvps/documentation/plc/CasselPLCCode. pdf
[R27]	PLC Symbol/Label Database (Cassel)	hvps/documentation/plc/CasselSymbolD atabase.pdf
[R28]	Enerpro Schematics and Manuals (12 PDFs)	hvps/controls/enerpro/enerproDocuments/
[R29]	SLO-SYN Stepper Drive Manual	11rf/tuners/SLO-SYN_SS2000MD4M_Step_ Drive_Translator_Manual.pdf

Ref	Document	Repository Path
[R30]	SLO-SYN Motor Specifications	11rf/tuners/SLO-SYN.pdf
[R31]	Galil DMC-41x3 series user manual (covers the DMC-4143)	11rf/tuners/galil/dmc-4103-r13h-manual.pdf; datasheet 11rf/tuners/galil/ds_41x3.pdf
[R32]	Drive Amplifier Datasheet (KAW2051M12)	11rf/driveAmp/KAW2051M12 (7-98-907-012A).pdf
[R33]	Coaxial Cable Interconnection Diagram	11rf/documentation/coaxCables/sd3403300100.pdf
[R34]	Galil bench session log with the installed cavity motors (25 Aug 2025) — records firmware DMC4143 Rev 1.3h, AMP1 43547 Rev 4	11rf/tuners/galil/functioningGalil20250825SwapABToManual.txt; earlier session firstMotion2024.txt
[R35]	Galil Commissioning Documentation	11rf/tuners/galil/GalilCommissioning.docx
[R36]	Cavity Tuner Inspections (June 2023)	11rf/tuners/cavityTunerInspections20230613.docx
[R37]	PLC Operation Notes	hvps/documentation/plc/plcNotesR1.docx
[R38]	PLC Software Discussion	hvps/documentation/plc/PLC software discussion 1.docx
[R39]	PLC Label Database	hvps/documentation/plc/hvpsPlcLabels.xlsx
[R40]	Enerpro Modifications for SLAC HVPS (J. Sebek) — installed FCOG6100/FCOAUX60 identity and serial numbers, phase-reference measurements, SIG HI summing chain	hvps/controls/enerpro/enerproBoardHvps.docx
[R53]	Dusatko, J., <i>The SPEAR3 Low Level RF System Description</i> , v1.2, SLAC ESD, 4 May 2004 (updated 29 January 2016) — authoritative for the VXI crate, CLK, IQA, RFP, AIM and their SPEAR3 modifications	11rf/documentation/legacyArchitecture/SP3_writeup_V1d2.pdf
[R54]	Ross, W., <i>PEP-II/SPEAR3 LLRF System Clock Module Revision 2</i> , SLAC ESD Engineering Document, 1 September 2001	Cited as reference 3 of [R53]; document not held in this repository
[R55]	SPEAR3 RF Physics and Plant (Doc P) — authoritative for beam and cavity physics parameters	Designs/tex/docP-rf-physics/P_rf_physics_and_plant.pdf
[R56]	Sebek, J., <i>SPEAR3 High Voltage Power Supply Hazards</i> — authoritative for HVPS stored energy, discharge times, operating point, transformer ratings, and the T0 rating correction	hvps/documentation/procedures/spear3HvpsHazards.tex
[R57]	SPEAR3 Legacy LLRF Tuner Control System Technical Analysis (Doc T)	Designs/tex/docT-tuner-control/T_tuner_control_analysis.pdf
[R58]	Sebek, J., <i>Enerpro Phase Reference Adapter</i> — the upgrade adapter design (576 k Ω / 200 k Ω into FCOG1200 J7)	hvps/controls/enerpro/enerproPhaseReferenceAdapter.docx

Ref	Document	Repository Path
[R60]	Legacy IOC boot and Remote I/O configuration	spear-rf-code-legacy/iocBoot/b132-iocrf/st.cmd,v, config.ab,v; spear-rf-code-legacy/rfApp/DbIoc/srf1.substitutions,v; spear-rf-code-legacy/rfApp/Db/rf_ab_4CV.substitutions,v; spear-rf-code-legacy/rfApp/src/db/p2RfAimDef.h,v; spear-rf-code-legacy/allenBradley/documentation/allenBradley.html,v
[R61]	SCR trigger, interlock and monitor board schematics (SD-730-793 series) — verified by direct reading of the scanned drawings, September 2026	hvps/documentation/schematics/sd7307930304.pdf, sd7307930402.pdf, sd7307930702.pdf, sd7307930801.pdf, sd7307931203.pdf, sd7307931301.pdf
[R62]	Grounding Tank schematic, SD-730-790-05-C1 (R. Cassel, 2/13/03) — verified by direct reading, September 2026	hvps/documentation/schematics/sd7307900501.pdf
[R63]	Trigger Enclosure Wiring, WD-730-790-02-C6 (R. Cassel / W. Gorecki / S. Lowe; revisions C1–C6, 06/03 to 01/07) — master wiring diagram for the B118 trigger enclosure; verified by direct reading, September 2026	hvps/documentation/wiringDiagrams/wd7307900206.pdf
[R64]	Grounding Tank Wiring, WD-730-794-06-C0 (R. Cassel / W. Gorecki 03/03/2000 / S. Lowe 4/3/00) — test stand configuration, no revisions recorded; verified by direct reading, September 2026	hvps/documentation/wiringDiagrams/wd7307940600.pdf
[R65]	Vacuum Contactor Controller Electrical Schematic, GP-439-704-02-C1 (redrawn to CAD per as-built, 09/25/06) — verified by direct reading, September 2026	hvps/documentation/switchgear/gp4397040201.pdf
[R66]	Ross Engineering 713203 E-1, High Speed Vacuum Contactor Energy Storage Closing & Holding System Schematic (driver HCA-1-A P/N 820360; contactor HQ3 P/N 813203; last revision E, 2-2-83) — verified by direct reading, September 2026	hvps/documentation/switchgear/rossEng713203.pdf
[R67]	Interconnection Wiring, WD-730-790-01-C3 (R. Cassel / W. Gorecki 03/02/2000 / S. Lowe; revisions C1–C3, 08/03 to 10/03) — system-level interconnection between the B118 Hoffman Box, Contactor Disconnect and Termination Tank; verified by direct reading, September 2026	hvps/documentation/wiringDiagrams/wd7307900103.pdf

Ref	Document	Repository Path
[R68]	12.47 kV Vacuum Contactor Controller, Electrical Connection Wiring Diagram, ID-308-801-06-C1 (redrawn to CAD and resized D→E, revised per as-built, 09/25/06; supersedes ID-308-801-06 R0) — the connection-wiring companion to [R65]; verified by direct reading, September 2026	hvps/documentation/switchgear/ id3088010601.pdf
[R69]	12.47 kV Outdoor Metal-Enclosed Combination Vacuum Contactor Controller — Schematic Diagram & General Arrangement, GP-308-500-01-R3 (Lawrence Berkeley Laboratory; A. Tseng / L. Johnson, 6-23-77, revisions 1–3) — the original PEP-era design drawing; authoritative source for the relay device legend; verified by direct reading, September 2026	hvps/documentation/switchgear/ gp3085000103.pdf
[R70]	Klystron Power Supply Electrical Schematic, EI-730-790-00-C0 / NWL # 39308 (NWL Transformers, Bordentown NJ; SLAC issue R. Cassel / W. Gorecki 12/17/02 / J. Olszewski 1/21/03; NWL revisions A–F, 1996–2001) — the transformer manufacturer's own schematic ; authoritative for transformer ratings, monitor windings and oil/pressure protection setpoints; verified by direct reading, September 2026	hvps/documentation/wiringDiagrams/ ei7307900000.pdf
[R71]	SCR Control Driver — Crowbar Interconnecting Cables, WD-730-794-04-C0 (R. Cassel 5/30/00 / W. Gorecki 03/03/2000 / S. Lowe 4/3/00) — contains the ”TRANSFORMER TANK WD-730-792-01” section with both HVPS output voltage dividers, the crowbar trigger transformer T1 feeding SCR1–SCR4 over RG-220, and the CR1–CR4 driver board pinouts; verified by direct reading, September 2026	hvps/documentation/wiringDiagrams/ wd7307940400.pdf
[R72]	Enerpro Voltage and Current Regulator Board Notes — J. Sebek. Detailed circuit analysis of SD-237-230-14-C1: divider loading and transfer functions, error-amplifier pole/zero analysis, the diode minimum-select summing junction, and the finding that the AC current loop is saturated by design	hvps/architecture/designNotes/EnerproV oltageandCurrentRegulatorBoardNotes. docx
[R73]	SPEAR3 RF Station Legacy System Interlock Architecture (Doc I) — companion document; authoritative for the complete legacy interlock signal flow, per-actor input/output tables, fault timelines and fault data access procedures	Designs/tex/docI-interlock- architecture/I_interlock_architecture. pdf

21.1.4 A.4 External Web References

All URLs were checked on 3 September 2026. "Verified" means the page was retrieved and its bibliographic content confirmed to match the citation it supports; "link only" means the URL resolves but the content could not be machine-read (PDF, paywall, or bot challenge) and the citation rests on the corresponding repository copy or OSTI/arXiv record instead.

Ref	URL	Content	Sup-ports	Status
[W1]	https://inspirehep.net/files/945e7ff73cc428af4c018fd1bdb6afa7	McIntosh et al. EPAC04 full text	[R1]	Link only (opaque INSPIRE file hash — prefer [W2])
[W2]	https://www.osti.gov/biblio/839730	OSTI record for SLAC-PUB-10983 (SPEAR3 RF System)	[R1]	Verified
[W3]	https://digital.library.unt.edu/ark:/67531/metadc619632/	Corredoura, PEP-II LLRF Architecture (UNT Digital Library)	[R2]	Link only (bot challenge)
[W4]	https://www.osti.gov/biblio/10204	OSTI record for Corredoura PAC99 — confirms report number SLAC-PUB-8124	[R2]	Verified
[W5]	https://arxiv.org/abs/physics/0007029	Corredoura et al., PEP-II RF at High Beam Currents — confirms report number SLAC-PUB-8498 and the full author list	[R3]	Verified
[W6]	https://ieeexplore.ieee.org/document/753249/	Cassel & Nguyen, PEP-II Klystron Power Supply (IEEE)	[R6]	Link only (paywall)
[W7]	https://www.osti.gov/biblio/7066243	Rimmer, RF Cavity Development for PEP-II (LBL-33360)	[R45]	Verified
[W8]	https://www.osti.gov/biblio/505666	Rimmer et al., High-Power Testing of the First PEP-II RF Cavity	[R46]	Verified
[W9]	https://www.osti.gov/biblio/4075988	Robinson, Stability of Beam in RF System (CEAL-1010)	[R47]	Verified
[W10]	https://proceedings.jacow.org/p85/PDF/PAC1985_1852.PDF	Boussard, Control of Cavities with High Beam Loading	[R48]	Link only (PDF)
[W11]	https://www.dimtel.com/products/llrf9	Dimtel LLRF9 product page	[R51]	Verified

Ref	URL	Content	Sup-ports	Status
[W12]	https://www.dimtel.com/products/specs/11rf9_500	LLRF9/500 specifications	[R52]	Verified
[W13]	https://inspirehep.net/files/dd3ac6684a603446924fb193fcd76a778	Fowkes et al., 1.2 MW Klystron (SLAC-PUB-6093)	[R44]	Link only (opaque INSPIRE file hash)
[W14]	https://s3.cern.ch/inspire-prod-files-e/ede001caff380d3448f21bc3b1d5e351	Fowkes et al., PEP-II Prototype Klystron (SLAC-PUB-6093)	[R43]	Link only (opaque INSPIRE file hash)
[W15]	https://slac.stanford.edu/pubs/slacpubs/10000/slac-pub-10083.pdf	McIntosh, 476 MHz Cavity Processing (SLAC-PUB-10083)	[R49]	Link only (PDF)
[W16]	https://www.osti.gov/biblio/815601	OSTI record for SLAC-PUB-10083	[R49]	Verified
[W17]	https://inspirehep.net/literature/1102529	INSPIRE record for Robinson 1964	[R47]	Verified
[W18]	https://www.desy.de/~branlard/papers/LINAC14/WEIOA06.pdf	Branlard, "Low Level RF for SRF Accelerators," LINAC14	[R59]	Link only (PDF)

Maintenance note: [W1], [W13] and [W14] are content-addressed INSPIRE/CERN file hashes. They are fragile and should be replaced with stable landing-page URLs or repository copies at the next revision.

21.2 Appendix B — Symbol and Notation Conventions

21.2.1 B.1 Frequently Used Symbols

Symbol	Definition	Typical Unit
f_0, ω_0	Cavity resonant frequency	MHz, rad/s
$f_{\text{RF}}, \omega_{\text{RF}}$	RF operating frequency (~476.3 MHz, drifting — §4.1)	MHz, rad/s
$f_{\text{rev}}, \omega_{\text{rev}}$	Revolution frequency (~1.2804 MHz)	MHz, rad/s
f_s, ω_s	Synchrotron frequency (~10.1 kHz — see [R55])	kHz, rad/s
Q_0	Unloaded quality factor (32,000)	dimensionless
Q_L	Loaded quality factor (~6,700)	dimensionless
β	Coupling coefficient = Q_0/Q_{ext} (~3.78)	dimensionless
R_s	Shunt impedance (3.73 M Ω , linac convention)	M Ω
V_{gap}	Gap voltage per cavity (~712 kV operating)	kV
I_b	DC beam current (500 mA design)	mA or A
V_{HV}	HVPS output voltage (≈ -72 – -75 kV typical)	kV
I_{HV}	HVPS output current (≈ 19 – 22 A typical)	A
α	SCR firing angle	degrees

Symbol	Definition	Typical Unit
SIG HI	Enerpro control voltage (proportional to α)	V

21.2.2 B.2 Abbreviations

Abbreviation	Definition
AIM	Arc/Interlock Module (VXI slot 12, SLAC drawing 340-307)
CLK	Clock/RF Distribution module (VXI slot 2)
DCM	Direct Communication Module — an Allen-Bradley Remote I/O adapter (1747-DCM for SLC-500, 1771-DCM for PLC-5)
Fast IC	Fast Interlock Chassis (SLAC drawing 340-308)
GVF / GAP	Gap Voltage Feed-Forward (PEP-II only; module not installed in SPEAR3)
HER	High Energy Ring (PEP-II)
HOM	Higher-Order Mode
HVPS	High-Voltage Power Supply
IQA	IQ/Amplitude detector module (VXI slots 7, 9, 11)
LLRF	Low-Level RF
MPS	Machine Protection System (RF MPS = the station-level equipment protection PLC; SPEAR MPS = the facility system)
PPS	Personnel Protection System
RFP	RF Processor module (VXI slot 4)
RIO	Allen-Bradley Remote I/O — the serial link between the VXI 6008-SV1R scanner and the PLC adapters
SCR	Silicon Controlled Rectifier (thyristor)
SNL	State Notation Language (EPICS)

21.2.3 B.3 Conventions

1. **Shunt impedance convention:** This document uses the **linac convention** ($R_s = V^2/2P$) unless explicitly stated otherwise, giving $R_s = 3.73 \text{ M}\Omega$ per cavity. The accelerator convention ($R_s = V^2/P$) gives values exactly $2\times$ larger ($7.5 \text{ M}\Omega$); the figure of $3.8 \text{ M}\Omega$ that appears in McIntosh [R1] is an accelerator-convention value and must not be mixed with linac-convention formulae.
2. **Phase convention:** Positive phase angles represent phase advance. The synchronous phase φ_s is measured from the zero-crossing of the RF voltage.
3. **Frequency detuning:** $\Delta f = f_0 - f_{\text{RF}}$. Negative detuning ($\Delta f < 0$) means the cavity resonant frequency is below the RF frequency — the normal operating condition for beam loading compensation above transition.
4. **Reference tag format:** [Rn] for numbered references, [Wn] for web references.
5. **Voltage polarity:** HVPS voltages are reported as positive magnitudes unless preceded by a minus sign. The klystron cathode polarity is negative.
6. **Timing statements:** Where an interlock or protection time is quoted, this document distinguishes **signal latency** (comparator to fiber, typically $< 1 \mu\text{s}$) from **physical response** (crowbar conduction $\approx 10 \mu\text{s}$;

SCR primary interruption 4–8 ms). Unqualified "response time" figures in older revisions conflated the two.

7. **Drifting quantities:** The RF frequency and the klystron cathode voltage/current are not fixed (§4). Values quoted for them are typical readbacks with their source identified, not setpoints, and small differences between sources are expected.

End of Document

Document Control:

- This document is the Tier 2 legacy system reference for the SPEAR3 RF system.
- The definitive version is the LaTeX source `Designs/tex/docL-legacy-architecture/L_legacy_system_architecture.tex` in the `spearlegacyLLRF` repository; the PDF is built from it by `Designs/tex/build.ps1`.
- **Provenance:** AI-ASSISTED. Structure and drafting by AI; every technical claim is referenced to an original source document, an engineering drawing read directly, or the legacy source code. Subject to human review and approval by a named engineer.
- **Review status:** Release candidate. §21 records the verification basis for each section; §20.2 lists the open items that still require field verification or transcription of an original drawing before this document can be considered complete.