

# Synchronization in Power Networks



Francesco Bullo

Center for Control,  
Dynamical Systems & Computation  
University of California at Santa Barbara  
<http://motion.me.ucsb.edu>

32nd Annual CNLS Conference, LANL  
Optimization and Control for Smart Grids  
Santa Fe, May 25, 2012

F. Bullo (UCSB)

Synchronization

GeorgiaTech 27apr12

1 / 19

## Outline

1 Models

2 Problem statement

3 Synchronization Tests

4 Case Study

## Acknowledgements



Florian Dörfler



Misha Chertkov



John Simpson-Porco

- 1 F. Dörfler and F. Bullo. Synchronization and transient stability in power networks and non-uniform Kuramoto oscillators. In *Proc ACC*, pages 930–937, Baltimore, MD, USA, June 2010
- 2 F. Dörfler and F. Bullo. On the critical coupling for Kuramoto oscillators. *SIAM J Appl Dyn Sys*, 10(3):1070–1099, 2011
- 3 F. Dörfler and F. Bullo. Synchronization and transient stability in power networks and non-uniform Kuramoto oscillators. *SIAM JCO*, 2012. To appear
- 4 F. Dörfler, M. Chertkov, and F. Bullo. Synchronization assessment in power networks and coupled oscillators. In *Proc CDC*, Maui, HI, USA, December 2012. Submitted
- 5 J. W. Simpson-Porco, F. Dörfler, and F. Bullo. Droop-controlled inverters in microgrids are Kuramoto oscillators. In *IFAC NecSys Workshop*, Santa Barbara, CA, USA, September 2012. Submitted



F. Bullo (UCSB)

Synchronization


GeorgiaTech 27apr12

2 / 19



## Power Generation and Transmission Network



Western US  
(WECC 16-m, 25-b)



New England  
(10-m, 13-b)



①  $n$  generators ■ and  $m$  load buses ●

② admittance matrix  $Y \in \mathbb{C}^{(n+m) \times (n+m)}$ , symmetric, sparse, lossless

**Central task:** generators provide power for loads

**Problems:** stability in face of disturbances, security from cyber attacks

## Mathematical Model of a Power Transmission Network

① power transfer on line  $i \rightsquigarrow j$ :

$$\underbrace{|V_i||V_j||Y_{ij}|}_{a_{ij}=\text{max power transfer}} \cdot \sin(\theta_i - \theta_j)$$

② power balance at node  $i$ :

$$\underbrace{P_i}_{\text{power injection}} = \sum_j a_{ij} \sin(\theta_i - \theta_j)$$



### Structure-Preserving Model [Bergen & Hill '81]

for ■, swing eq with  $P_i > 0$

$$M_i \ddot{\theta}_i + D_i \dot{\theta}_i = P_i - \sum_j a_{ij} \sin(\theta_i - \theta_j)$$

for ●, const  $P_i < 0$  and  $D_i \geq 0$

$$D_i \dot{\theta}_i = P_i - \sum_j a_{ij} \sin(\theta_i - \theta_j)$$



① power transfer on line  $i \rightsquigarrow j$ :

$$\underbrace{|V_i||V_j||Y_{ij}|}_{a_{ij}=\text{max power transfer}} \cdot \sin(\theta_i - \theta_j)$$

② power balance at node  $i$ :

$$\underbrace{P_i}_{\text{power injection}} = \sum_j a_{ij} \sin(\theta_i - \theta_j)$$

## Outline

1 Models

2 Problem statement

3 Synchronization Tests


4 Case Study

- ① power networks are coupled oscillators

$$M_i \ddot{\theta}_i + D_i \dot{\theta}_i = P_i - \sum_j a_{ij} \sin(\theta_i - \theta_j)$$

$$D_i \dot{\theta}_i = P_i - \sum_j a_{ij} \sin(\theta_i - \theta_j)$$

- ② synchronization: coupling strength vs. frequency non-uniformity



- ③ graph theory provides notions of


“coupling/connectivity” and “non-uniformity”

power networks **should** synchronize  
for large “coupling/connectivity” and small “non-uniformity”


## Coupled Oscillators in Technology and Science

Kuramoto model of coupled oscillators:

$$\dot{\theta}_i = \omega_i - \sum_{j=1}^n a_{ij} \sin(\theta_i - \theta_j)$$



- Sync in Josephson junctions [S. Watanabe et. al '97, K. Wiesenfeld et al. '98]
- Sync in a population of fireflies [G.B. Ermentrout '90, Y. Zhou et al. '06]
- Coordination of particle models [R. Sepulchre et al. '07, D. Klein et al. '09]
- Deep-brain stimulation and neuroscience [P.A. Tass '03, E. Brown et al. '04]
- Countless other sync phenomena [A. Winfree '67, S.H. Strogatz '00, J. Acebrón '01]



Determine conditions on the power injections  $(P_1, \dots, P_{n+m})$ , network admittance  $Y$ , and node parameters  $(M_i, D_i)$ , such that:

$$|\theta_i - \theta_j| \text{ bounded and } \dot{\theta}_i = \dot{\theta}_j$$


## Literature

- Classic security analysis:** load flow Jacobian & network theory [S. Sastry et al. '80, A. Arapostathis et al. '81, F. Wu et al '82, M. Ilić '92, ...]
- Broad interest for Complex Networks, Network Science** [Ilić '92, Hill & Chen '06] stability, performance, and robustness of power network ↽ underlying graph properties (topological, algebraic, spectral, etc.)

## Synchronization Notions

$$\dot{\theta}_i = \omega_i - \sum_{j=1}^n a_{ij} \sin(\theta_i - \theta_j)$$

- phase cohesive:  $|\theta_i(t) - \theta_j(t)| < \gamma$  for small  $\gamma < \pi/2$  ... arc invariance
- frequency synchrony:  $\dot{\theta}_i(t) = \dot{\theta}_j(t)$
- phase synchrony:  $\theta_i(t) = \theta_j(t)$



- $\{a_{ij}\}_{\{i,j\} \in \mathcal{E}}$  small &  $|\omega_i - \omega_j|$  large  $\implies$  no synchronization
- $\{a_{ij}\}_{\{i,j\} \in \mathcal{E}}$  large &  $|\omega_i - \omega_j|$  small  $\implies$  cohesive + freq sync

**Challenges:** proper notions of sync, coupling & phase transition

[A. Jadbabaie et al. '04, P. Monzon et al. '06, Sepulchre et al. '07, S.J. Chung et al. '10, J.L. van Hemmen et al. '93, F. de Smet et al. '07, N. Chopra et al. '09, G. Schmidt et al. '09, F. Dörfler et al. '09 & '11, S.J. Chung et al. '10, A. Franci et al. '10, S.Y. Ha et al. '10, D. Aeyels et al. '04, R.E. Mirollo et al. '05, M. Verwoerd et al. '08, L. DeVille '11, ...]

## 1 Models

## 2 Problem statement

## 3 Synchronization Tests

## 4 Case Study

F. Bullo (UCSB)

Synchronization

GeorgiaTech 27apr12

12 / 19

## Sync Tests: Coupling vs. Power Imbalance

$$M_i \ddot{\theta}_i + D_i \dot{\theta}_i = P_i - \sum_j a_{ij} \sin(\theta_i - \theta_j)$$

$$D_i \dot{\theta}_i = P_i - \sum_j a_{ij} \sin(\theta_i - \theta_j)$$

Tight condition for homogeneous graphs ( $a_{ij} = K > 0$ ), trees, graphs with disjoint 3- and 4-cycles, graphs with  $L^\dagger P$  bipolar or symmetric

$$\|L^\dagger P\|_{\infty, \text{graph edges}} < 1 \iff \text{sync}$$

Necessary and sufficient conditions for connected weighted graphs

$$\sum_j a_{ij} \leq |P_i| \Rightarrow \text{no sync} \quad \lambda_2 > \|P\|_{2, \text{all edges}} \Rightarrow \text{sync}$$

sharpest general conditions known to date

**Graph: weights  $a_{ij} > 0$  on edges  $\{i,j\}$ , values  $x_i$  at nodes  $i$**

- adjacency matrix  $A = (a_{ij})$
- degree matrix  $D$  is diagonal with  $d_{ii} = \sum_{j=1}^n a_{ij}$
- Laplacian matrix  $L = L^T = D - A \geq 0$

### Notions of Connectivity

topological: connectivity, average and worst-case path lengths

spectral: second smallest eigenvalue  $\lambda_2$  of  $L$  is “algebraic connectivity”

### Notions of Dissimilarity

$$\|x\|_{\infty, \text{edges}} = \max_{\{i,j\}} |x_i - x_j|, \quad \|x\|_{2, \text{edges}} = (\sum_{\{i,j\}} |x_i - x_j|^2)^{1/2}$$

(graph edges  $\{i,j\} \in \mathcal{E}$ ) or (all edges  $\{i,j\}$  satisfy  $i < j$ )

F. Bullo (UCSB)

Synchronization

GeorgiaTech 27apr12

13 / 19

F. Bullo (UCSB)

Synchronization

GeorgiaTech 27apr12

13 / 19

## A Nearly Exact Synchronization Condition – Accuracy

Randomized power network test cases

with 50 % randomized loads and 33 % randomized generation

Randomized test case (1000 instances)	Correctness of condition: $\ L^\dagger \omega\ _\infty, \text{g. edges} \leq \sin(\gamma)$ $\Rightarrow \max_{\{i,j\} \in \mathcal{E}}  \theta_i^* - \theta_j^*  \leq \gamma$	Accuracy of condition: $\max_{\{i,j\}}  \theta_i^* - \theta_j^* $ – $\arcsin(\ B^T L^\dagger \omega\ _\infty)$	Phase cohesiveness: $\max_{\{i,j\} \in \mathcal{E}}  \theta_i^* - \theta_j^* $
9 bus system	always true	$4.1218 \cdot 10^{-5}$ rad	0.12889 rad
IEEE 14 bus system	always true	$2.7995 \cdot 10^{-4}$ rad	0.16622 rad
IEEE RTS 24	always true	$1.7089 \cdot 10^{-3}$ rad	0.22309 rad
IEEE 30 bus system	always true	$2.6140 \cdot 10^{-4}$ rad	0.1643 rad
New England 39	always true	$6.6355 \cdot 10^{-5}$ rad	0.16821 rad
IEEE 57 bus system	always true	$2.0630 \cdot 10^{-2}$ rad	0.20295 rad
IEEE RTS 96	always true	$2.6076 \cdot 10^{-3}$ rad	0.24593 rad
IEEE 118 bus system	always true	$5.9959 \cdot 10^{-4}$ rad	0.23524 rad
IEEE 300 bus system	always true	$5.2618 \cdot 10^{-4}$ rad	0.43204 rad
Polish 2383 bus system (winter peak 1999/2000)	always true	$4.2183 \cdot 10^{-3}$ rad	0.25144 rad

condition  $\|L^\dagger \omega\|_{\infty, \text{graph edges}} \leq \sin(\gamma)$  is extremely accurate for  $\gamma \leq 25^\circ$

F. Bullo (UCSB)

Synchronization

GeorgiaTech 27apr12

14 / 19

F. Bullo (UCSB)

Synchronization

GeorgiaTech 27apr12

15 / 19

## AC power flow


$$P_i = \sum_{j=1}^n a_{ij} \sin(\theta_i - \theta_j), \quad |\theta_i - \theta_j| < \gamma_{ij}$$

## DC power flow approximation

$$P_i = \sum_{j=1}^n a_{ij}(\delta_i - \delta_j), \quad |\delta_i - \delta_j| < \gamma_{ij}$$

## Novel test

$$P_i = \sum_{j=1}^n a_{ij}(\delta_i - \delta_j), \quad |\delta_i - \delta_j| < \sin(\gamma_{ij})$$

Case Study: Predicting Transition to Instability  
IEEE Reliability Test System '96 (33-m 44-b)

## Optimal power dispatch

$$\text{minimize } \sum (\text{cost})_{i,\text{gen}} P_{i,\text{gen}}$$

$$P_i = \sum_j a_{ij} \sin(\theta_i - \theta_j)$$

$$|\theta_i - \theta_j| \leq (\text{thermal limit})_{ij}$$

$$P_{\text{gen},i} \in (\text{feasible range})_{i,\text{gen}}$$

Power flow: periodically, solve optimal power dispatch problem, &  
real-time perturbations handled via generation adjustments

## 1 Models


## 2 Problem statement

## 3 Synchronization Tests


## 4 Case Study

Case Study: Predicting Transition to Instability  
IEEE Reliability Test System '96 (33-m 44-b)

Two contingencies:



- 1) generator 323 is tripped
- 2) increase loads & generation



Continuously increase loads:

- ⇒ condition  $\|B^T L^\dagger \omega\|_\infty \leq \sin(\gamma)$  predicts that thermal limit  $\gamma^*$  of line {121, 325} is violated at 22.23 % of additional loading
- ⇒ line {121, 325} is tripped at 22.24% of additional loading

## Conclusions

### Summary:

- ① connection between power networks and coupled Kuramoto oscillators
- ② necessary and sufficient sync conditions
- ③ sharp sync conditions

### Ongoing and future work:

- ① general proof for sharp conditions
- ② more detailed & stochastic models
- ③ region of attraction

2012 IFAC NecSys Workshop, Santa Barbara  
CDC 2012, Maui Hawaii: Tutorial Session on Coupled Oscillators