Date: 2019/12/08

4789043408-SAR-2 System Performance Check-2450MHz-Head 20190614-Head

Communication System: UID 0, CW (0); Communication System Band: D2450 (2450.0 MHz);

Frequency: 2450 MHz;

Medium parameters used: f = 2450 MHz; σ = 1.813 S/m; ϵ_r = 39.90; ρ = 1000 kg/m³

Phantom section: Flat Section

DASY Configuration:

Probe: EX3DV4 - SN7383; ConvF(7.72, 7.72, 7.72); Calibrated: 2018/12/19;

Sensor-Surface: 3mm (Mechanical Surface Detection), z = 1.0, 31.0

Electronics: DAE3 Sn427; Calibrated: 2018/12/11

Phantom: ELI v5.0; Type: QDOVA002AA; Serial: 1235

• DASY52 52.8.8(1222); SEMCAD X 14.6.10(7331)

Configuration/D2450V2/Area Scan (6x9x1): Measurement grid: dx=12mm, dy=12mm Maximum value of SAR (measured) = 16.9 W/kg

Configuration/D2450V2/Zoom Scan (7x7x7)/Cube 0: Measurement grid: dx=5mm,


dy=5mm, dz=5mm

Reference Value = 81.29 V/m; Power Drift = 0.14 dB

Peak SAR (extrapolated) = 27.4 W/kg

SAR(1 g) = 12.87 W/kg; SAR(10 g) = 5.93 W/kg

Maximum value of SAR (measured) = 17.0 W/kg



0 dB = 17.0 W/kg = 12.30 dBW/kg

Date: 2019/12/07

4789043408-SAR-2 System Performance Check-5250MHz-Head 20190617

Communication System: UID 0, CW (0); Communication System Band: D5GHz (5000.0 -

6000.0 MHz); Frequency: 5250 MHz;

Medium parameters used: f = 5250 MHz; $\sigma = 5.277$ S/m; $\epsilon_r = 35.80$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

DASY Configuration:

Probe: EX3DV4 - SN7383; ConvF(5.73, 5.73, 5.73); Calibrated: 2018/12/19;

Sensor-Surface: 1.4mm (Mechanical Surface Detection), z = 1.0, 25.0

• Electronics: DAE3 Sn427; Calibrated: 2018/12/11

Phantom: SAM; Type: QD000P40CD; Serial: 1805

• DASY52 52.8.8(1222); SEMCAD X 14.6.10(7331)

System Performance Check with D5GHzV2 Dipole (graded grid)/d=10mm, Pin=100mW, f=5250 MHz/Area Scan (6x6x1): Measurement grid: dx=10mm, dy=10mm

Maximum value of SAR (measured) = 14.1 W/kg


System Performance Check with D5GHzV2 Dipole (graded grid)/d=10mm, Pin=100mW, f=5250 MHz/Zoom Scan (4x4x1.4mm, graded), dist=1.4mm (8x8x7)/Cube 0: Measurement grid: dx=4mm, dy=4mm, dz=1.4mm

Reference Value = 70.51 V/m; Power Drift = -0.13 dB

Peak SAR (extrapolated) = 32.1 W/kg

SAR(1 g) = 8.21 W/kg; SAR(10 g) = 2.39 W/kg

Maximum value of SAR (measured) = 19.1 W/kg



0 dB = 19.1 W/kg = 12.80 dBW/kg