



# **Appendix B**

## **Detailed Test Results**

1. Bluetooth
Bluetooth for Body

Test Laboratory: SGS-SAR Lab

## KITCOM Easybreath Bluetooth DH5 39CH Back side 0mm

**DUT: KITCOM Easybreath; Type: 119980; Serial: N/A**

Communication System: UID 0, Bluetooth (0); Frequency: 2441 MHz; Duty Cycle: 1:1

Medium: HSL2450; Medium parameters used:  $f = 2441$  MHz;  $\sigma = 1.807$  S/m;  $\epsilon_r = 39.955$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section

DASY 5 Configuration:

- Probe: EX3DV4 - SN3789; ConvF(7.01, 7.01, 7.01); Calibrated: 2018-02-08;
- Sensor-Surface: 2mm (Mechanical Surface Detection),  $z = -2.0, 31.0$
- Electronics: DAE4 Sn896; Calibrated: 2017-09-27
- Phantom: SAM2; Type: SAM; Serial: 1913
- DASY52 52.8.8(1222); SEMCAD X 14.6.10(7331)

**Configuration/Body/Area Scan (9x9x1):** Measurement grid:  $dx=12$ mm,  $dy=12$ mm

Maximum value of SAR (measured) = 0.212 W/kg


**Configuration/Body/Zoom Scan (7x7x7)/Cube 0:** Measurement grid:  $dx=5$ mm,  $dy=5$ mm,  $dz=5$ mm

Reference Value = 8.655 V/m; Power Drift = 0.13 dB

Peak SAR (extrapolated) = 0.359 W/kg

**SAR(1 g) = 0.167 W/kg; SAR(10 g) = 0.078 W/kg**

Maximum value of SAR (measured) = 0.259 W/kg



0 dB = 0.259 W/kg = -5.87 dBW/kg