REPORT NO: UL-SAR-RP10640830JD04A V3.0

Issue Date:09 April 2015

#### A.3. System Check Test Plots


This appendix contains the following SAR distribution scans.

Scan Reference Number Title	
001	System Performance Check 1900MHz Head 02 03 15
002	System Performance Check 1900MHz Body 10 03 15

001: System Performance Check 1900MHz Head 02 03 15

Date: 2/3/2015

DUT: Dipole 1900 MHz D1900V2; Type: D1900V2; Serial: D1900V2 - SN:540



0 dB = 11.4 W/kg = 10.58 dBW/kg

Communication System: UID 0, CW (0); Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: 1900 MHz HSL Medium parameters used: f = 1900 MHz;  $\sigma = 1.43$  S/m;  $\epsilon_r = 38.814$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section DASY4 Configuration:

- Probe: ET3DV6 SN1528; ConvF(5.19, 5.19, 5.19); Calibrated: 16/4/2014;
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1438; Calibrated: 12/5/2014
- Phantom: SAM (30deg probe tilt) with CRP v5.0; Type: QD000P40CD; Serial: TP:1836
- -; SEMCAD X Version 14.6.10 (7331)

SAR/d=15mm, Pin=250 mW, dist=10.0mm (ET-Probe)/Area Scan (61x61x1): Interpolated grid: dx=1.500 mm, dy=1.500 mm Maximum value of SAR (interpolated) = 11.4 W/kg

SAR/d=15mm, Pin=250 mW, dist=10.0mm (ET-Probe)/Zoom Scan (5x5x7) (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm


Reference Value = 92.52 V/m; Power Drift = 0.02 dB

Peak SAR (extrapolated) = 16.9 W/kg

**SAR(1 g) = 9.78 W/kg; SAR(10 g) = 5.2 W/kg** Maximum value of SAR (measured) = 10.9 W/kg 002: System Performance Check 1900MHz Body 10 03 15

Date: 10/3/2015

DUT: Dipole 1900 MHz; Type: D1900V2; Serial: SN540



0 dB = 11.7 W/kg = 10.67 dBW/kg

Communication System: UID 0, CW (0); Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: 1900 MHz MSL Medium parameters used: f = 1900 MHz;  $\sigma = 1.553$  S/m;  $\epsilon r = 52.358$ ;  $\rho = 1000$  kg/m3

Phantom section: Flat Section DASY4 Configuration:

- Probe: ET3DV6 SN1528; ConvF(4.76, 4.76, 4.76); Calibrated: 16/4/2014;
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1438; Calibrated: 12/5/2014
- Phantom: SAM (30deg probe tilt) with CRP v5.0; Type: QD000P40CD; Serial: TP:1836
- -; SEMCAD X Version 14.6.10 (7331)

SAR/d=15mm, Pin=250 mW, dist=10.0mm (ET-Probe) 2/Area Scan (61x61x1): Interpolated grid: dx=1.500 mm, dy=1.500 mm Maximum value of SAR (interpolated) = 11.7 W/kg

SAR/d=15mm, Pin=250 mW, dist=10.0mm (ET-Probe) 2/Zoom Scan (5x5x7) (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm

Reference Value = 91.90 V/m; Power Drift = 0.07 dB

Peak SAR (extrapolated) = 16.1 W/kg

SAR(1 g) = 9.87 W/kg; SAR(10 g) = 5.35 W/kgMaximum value of SAR (measured) = 11.0 W/kg

#### A.4. SAR Test Plots


This appendix contains the following system validation distribution scans.

Scan Reference Number	Title
001	Touch Left PCS 1900 CH661
002	Tilt Left PCS 1900 CH661
003	Touch Right PCS 1900 CH661
004	Touch Right PCS 1900 CH661
005	Front Open of EUT Facing Phantom GPRS 1900 2Tx CH661
006	Back Open of EUT Facing Phantom GPRS 1900 2Tx CH661
007	Front Closed of EUT Facing Phantom GPRS 1900 2Tx CH661
008	Back Closed of EUT Facing Phantom GPRS 1900 2Tx CH661
009	Front Open of EUT Facing Phantom PCS 1900 CH661
010	Back Open of EUT Facing Phantom PCS 1900 CH661
011	Front Closed of EUT Facing Phantom PCS 1900 CH661
012	Back Closed of EUT Facing Phantom PCS 1900 CH661

001: Touch Left PCS 1900 CH661

Date: 2/3/2015

DUT: Panasonic; Type: 401PM; Serial: 004401221425016



0 dB = 0.494 W/kg = -3.06 dBW/kg

Communication System: UID 0, Generic GSM (0); Frequency: 1880 MHz; Duty Cycle: 1:8.30042

Medium: 1900 MHz HSL Medium parameters used (interpolated): f = 1880 MHz;  $\sigma = 1.411$  S/m;  $\epsilon_r = 38.905$ ;  $\rho = 1000$  kg/m<sup>3</sup> Phantom section: Left Section

**DASY4** Configuration:

- Probe: ET3DV6 SN1528; ConvF(5.19, 5.19, 5.19); Calibrated: 16/4/2014;
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1438; Calibrated: 12/5/2014
- Phantom: SAM (30deg probe tilt) with CRP v5.0; Type: QD000P40CD; Serial: TP:1836
- -; SEMCAD X Version 14.6.10 (7331)

Configuration/Touch Left - Middle/Area Scan (61x161x1): Interpolated grid: dx=1.500 mm, dy=1.500 mm

Maximum value of SAR (interpolated) = 0.536 W/kg

Configuration/Touch Left - Middle/Zoom Scan (5x5x7) (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm

Reference Value = 15.97 V/m; Power Drift = 0.01 dB

Peak SAR (extrapolated) = 0.683 W/kg


SAR(1 g) = 0.453 W/kg; SAR(10 g) = 0.277 W/kg

Maximum value of SAR (measured) = 0.494 W/kg

002: Tilt Left PCS 1900 CH661

Date: 2/3/2015

DUT: Panasonic; Type: 401PM; Serial: 004401221425016



0 dB = 0.343 W/kg = -4.65 dBW/kg

Communication System: UID 0, Generic GSM (0); Frequency: 1880 MHz; Duty Cycle: 1:8.30042

Medium: 1900 MHz HSL Medium parameters used (interpolated): f = 1880 MHz;  $\sigma = 1.411$  S/m;  $\epsilon_r = 38.905$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Left Section

**DASY4** Configuration:

- Probe: ET3DV6 SN1528; ConvF(5.19, 5.19, 5.19); Calibrated: 16/4/2014;
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1438; Calibrated: 12/5/2014
- Phantom: SAM (30deg probe tilt) with CRP v5.0; Type: QD000P40CD; Serial: TP:1836
- -; SEMCAD X Version 14.6.10 (7331)

Configuration/Tilt Left - Middle/Area Scan (61x161x1): Interpolated grid: dx=1.500 mm, dy=1.500 mm

Maximum value of SAR (interpolated) = 0.357 W/kg

Configuration/Tilt Left - Middle/Zoom Scan (5x5x7) (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm


Reference Value = 5.448 V/m; Power Drift = -0.05 dB

Peak SAR (extrapolated) = 0.454 W/kg

SAR(1 g) = 0.315 W/kg; SAR(10 g) = 0.193 W/kg Maximum value of SAR (measured) = 0.343 W/kg 003: Touch Right PCS 1900 CH661

Date: 2/3/2015

DUT: Panasonic; Type: 401PM; Serial: 004401221425016



0 dB = 0.518 W/kg = -2.86 dBW/kg

Communication System: UID 0, Generic GSM (0); Frequency: 1880 MHz; Duty Cycle: 1:8.30042

Medium: 1900 MHz HSL Medium parameters used (interpolated): f = 1880 MHz;  $\sigma = 1.411$  S/m;  $\epsilon_r = 38.905$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Right Section

DASY4 Configuration:

- Probe: ET3DV6 SN1528; ConvF(5.19, 5.19, 5.19); Calibrated: 16/4/2014;
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1438; Calibrated: 12/5/2014
- Phantom: SAM (30deg probe tilt) with CRP v5.0; Type: QD000P40CD; Serial: TP:1836
- -; SEMCAD X Version 14.6.10 (7331)

Configuration/Touch Right - Middle/Area Scan (61x161x1): Interpolated grid: dx=1.500 mm, dy=1.500 mm

Maximum value of SAR (interpolated) = 0.538 W/kg

Configuration/Touch Right - Middle/Zoom Scan (5x5x7) (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm


Reference Value = 18.99 V/m; Power Drift = -0.01 dB

Peak SAR (extrapolated) = 0.641 W/kg

SAR(1 g) = 0.483 W/kg; SAR(10 g) = 0.318 W/kg Maximum value of SAR (measured) = 0.518 W/kg 004: Touch Right PCS 1900 CH661

Date: 2/3/2015

DUT: Panasonic; Type: 401PM; Serial: 004401221425016



0 dB = 0.286 W/kg = -5.44 dBW/kg

Communication System: UID 0, Generic GSM (0); Frequency: 1880 MHz; Duty Cycle: 1:8.30042

Medium: 1900 MHz HSL Medium parameters used (interpolated): f = 1880 MHz;  $\sigma = 1.411$  S/m;  $\epsilon_r = 38.905$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Right Section

DASY4 Configuration:

- Probe: ET3DV6 SN1528; ConvF(5.19, 5.19, 5.19); Calibrated: 16/4/2014;
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1438; Calibrated: 12/5/2014
- Phantom: SAM (30deg probe tilt) with CRP v5.0; Type: QD000P40CD; Serial: TP:1836
- -; SEMCAD X Version 14.6.10 (7331)

Configuration/Tilt Right - Middle/Area Scan (61x161x1): Interpolated grid: dx=1.500 mm, dy=1.500 mm

Maximum value of SAR (interpolated) = 0.302 W/kg

Configuration/Tilt Right - Middle/Zoom Scan (5x5x7) (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm


Reference Value = 4.498 V/m; Power Drift = -0.00 dB

Peak SAR (extrapolated) = 0.375 W/kg

SAR(1 g) = 0.267 W/kg; SAR(10 g) = 0.168 W/kg Maximum value of SAR (measured) = 0.286 W/kg 005: Front Open of EUT Facing Phantom GPRS 1900 2Tx CH661

Date: 10/3/2015

DUT: Panasonic; Type: 401PM; Serial: 004401221425016



0 dB = 0.282 W/kg = -5.49 dBW/kg

Communication System: UID 0, GPRS 2Tx (0); Frequency: 1880 MHz; Duty Cycle: 1:4.00037

Medium: 1900 MHz MSL Medium parameters used (interpolated): f = 1880 MHz;  $\sigma = 1.532$  S/m;  $\epsilon_r = 52.412$ ;  $\rho = 1000$  kg/m<sup>3</sup> Phantom section: Flat Section

DASY4 Configuration:

- Probe: ET3DV6 SN1528; ConvF(4.76, 4.76, 4.76); Calibrated: 16/4/2014;
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1438; Calibrated: 12/5/2014
- Phantom: SAM (30deg probe tilt) with CRP v5.0; Type: QD000P40CD; Serial: TP:1836
- -; SEMCAD X Version 14.6.10 (7331)

Configuration/Front Open - Middle/Area Scan (61x151x1): Interpolated grid: dx=1.500 mm, dy=1.500 mm

Maximum value of SAR (interpolated) = 0.282 W/kg

Configuration/Front Open - Middle/Zoom Scan (5x5x7) (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm


Reference Value = 8.304 V/m; Power Drift = -0.01 dB

Peak SAR (extrapolated) = 0.381 W/kg

SAR(1 g) = 0.256 W/kg; SAR(10 g) = 0.165 W/kg Maximum value of SAR (measured) = 0.275 W/kg 006: Back Open of EUT Facing Phantom GPRS 1900 2Tx CH661

Date: 10/3/2015

DUT: Panasonic; Type: 401PM; Serial: 004401221425016



0 dB = 0.550 W/kg = -2.60 dBW/kg

Communication System: UID 0, GPRS 2Tx (0); Frequency: 1880 MHz; Duty Cycle: 1:4.00037

Medium: 1900 MHz MSL Medium parameters used (interpolated): f = 1880 MHz;  $\sigma = 1.532$  S/m;  $\epsilon_r = 52.412$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section

DASY4 Configuration:

- Probe: ET3DV6 SN1528; ConvF(4.76, 4.76, 4.76); Calibrated: 16/4/2014;
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1438; Calibrated: 12/5/2014
- Phantom: SAM (30deg probe tilt) with CRP v5.0; Type: QD000P40CD; Serial: TP:1836
- -; SEMCAD X Version 14.6.10 (7331)

Configuration/Back Open - Middle/Area Scan (61x151x1): Interpolated grid: dx=1.500 mm, dy=1.500 mm Maximum value of SAR (interpolated) = 0.550 W/kg

Configuration/Back Open - Middle/Zoom Scan (5x5x7) (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm Reference Value = 5.206 V/m; Power Drift = 0.02 dB

Peak SAR (extrapolated) = 0.768 W/kg


SAR(1 g) = 0.482 W/kg; SAR(10 g) = 0.279 W/kg

Maximum value of SAR (measured) = 0.531 W/kg

007: Front Closed of EUT Facing Phantom GPRS 1900 2Tx CH661

Date: 10/3/2015

DUT: Panasonic; Type: 401PM; Serial: 004401221425016



0 dB = 0.350 W/kg = -4.56 dBW/kg

Communication System: UID 0, GPRS 2Tx (0); Frequency: 1880 MHz; Duty Cycle: 1:4.00037

Medium: 1900 MHz MSL Medium parameters used (interpolated): f = 1880 MHz;  $\sigma = 1.532$  S/m;  $\epsilon_r = 52.412$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section

DASY4 Configuration:

- Probe: ET3DV6 SN1528; ConvF(4.76, 4.76, 4.76); Calibrated: 16/4/2014;
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1438; Calibrated: 12/5/2014
- Phantom: SAM (30deg probe tilt) with CRP v5.0; Type: QD000P40CD; Serial: TP:1836
- -; SEMCAD X Version 14.6.10 (7331)

Configuration/Front Closed - Middle 2/Area Scan (61x101x1): Interpolated grid: dx=1.500 mm, dy=1.500 mm

Maximum value of SAR (interpolated) = 0.350 W/kg

Configuration/Front Closed - Middle 2/Zoom Scan (5x5x7) (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm


Reference Value = 11.79 V/m; Power Drift = -0.02 dB

Peak SAR (extrapolated) = 0.452 W/kg

SAR(1 g) = 0.315 W/kg; SAR(10 g) = 0.200 W/kg Maximum value of SAR (measured) = 0.339 W/kg 008: Back Closed of EUT Facing Phantom GPRS 1900 2Tx CH661

Date: 10/3/2015

DUT: Panasonic; Type: 401PM; Serial: 004401221425016



0 dB = 0.499 W/kg = -3.02 dBW/kg

Communication System: UID 0, GPRS 2Tx (0); Frequency: 1880 MHz; Duty Cycle: 1:4.00037

Medium: 1900 MHz MSL Medium parameters used (interpolated): f = 1880 MHz;  $\sigma = 1.532$  S/m;  $\epsilon_r = 52.412$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section

DASY4 Configuration:

- Probe: ET3DV6 SN1528; ConvF(4.76, 4.76, 4.76); Calibrated: 16/4/2014;
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1438; Calibrated: 12/5/2014
- Phantom: SAM (30deg probe tilt) with CRP v5.0; Type: QD000P40CD; Serial: TP:1836
- -; SEMCAD X Version 14.6.10 (7331)

**Configuration/Back Closed - Middle/Area Scan (61x101x1):** Interpolated grid: dx=1.500 mm, dy=1.500 mm Maximum value of SAR (interpolated) = 0.499 W/kg

Configuration/Back Closed - Middle/Zoom Scan (5x5x7) (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm


Reference Value = 13.38 V/m; Power Drift = -0.07 dB

Peak SAR (extrapolated) = 0.711 W/kg

SAR(1 g) = 0.424 W/kg; SAR(10 g) = 0.239 W/kg Maximum value of SAR (measured) = 0.471 W/kg 009: Front Open of EUT Facing Phantom PCS 1900 CH661

Date: 10/3/2015

DUT: Panasonic; Type: 401PM; Serial: 004401221425016



0 dB = 0.244 W/kg = -6.12 dBW/kg

Communication System: UID 0, Generic GSM (0); Frequency: 1880 MHz; Duty Cycle: 1:8.30042

Medium: 1900 MHz MSL Medium parameters used (interpolated): f = 1880 MHz;  $\sigma$  = 1.532 S/m;  $\epsilon_r$  = 52.412;  $\rho$  = 1000 kg/m<sup>3</sup> Phantom section: Flat Section

**DASY4** Configuration:

- Probe: ET3DV6 SN1528; ConvF(4.76, 4.76, 4.76); Calibrated: 16/4/2014;
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1438; Calibrated: 12/5/2014
- Phantom: SAM (30deg probe tilt) with CRP v5.0; Type: QD000P40CD; Serial: TP:1836
- -; SEMCAD X Version 14.6.10 (7331)

Configuration/Front Open - Middle/Area Scan (61x151x1): Interpolated grid: dx=1.500 mm, dy=1.500 mm Maximum value of SAR (interpolated) = 0.244 W/kg

Configuration/Front Open - Middle/Zoom Scan (5x5x7) (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm


Reference Value = 4.849 V/m; Power Drift = 0.00 dB

Peak SAR (extrapolated) = 0.318 W/kg

SAR(1 g) = 0.215 W/kg; SAR(10 g) = 0.139 W/kg Maximum value of SAR (measured) = 0.232 W/kg 010: Back Open of EUT Facing Phantom PCS 1900 CH661

Date: 10/3/2015

DUT: Panasonic; Type: 401PM; Serial: 004401221425016



0 dB = 0.453 W/kg = -3.44 dBW/kg

Communication System: UID 0, Generic GSM (0); Frequency: 1880 MHz; Duty Cycle: 1:8.30042

Medium: 1900 MHz MSL Medium parameters used (interpolated): f = 1880 MHz;  $\sigma = 1.532$  S/m;  $\epsilon_r = 52.412$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section

DASY4 Configuration:

- Probe: ET3DV6 SN1528; ConvF(4.76, 4.76, 4.76); Calibrated: 16/4/2014;
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1438; Calibrated: 12/5/2014
- Phantom: SAM (30deg probe tilt) with CRP v5.0; Type: QD000P40CD; Serial: TP:1836
- -; SEMCAD X Version 14.6.10 (7331)

Configuration/Back Open - Middle/Area Scan (61x151x1): Interpolated grid: dx=1.500 mm, dy=1.500 mm Maximum value of SAR (interpolated) = 0.453 W/kg

Configuration/Back Open - Middle/Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm


Reference Value = 10.35 V/m; Power Drift = -0.04 dB

Peak SAR (extrapolated) = 0.637 W/kg

SAR(1 g) = 0.398 W/kg; SAR(10 g) = 0.230 W/kg Maximum value of SAR (measured) = 0.437 W/kg 011: Front Closed of EUT Facing Phantom PCS 1900 CH661

Date: 10/3/2015

DUT: Panasonic; Type: 401PM; Serial: 004401221425016



0 dB = 0.294 W/kg = -5.32 dBW/kg

Communication System: UID 0, Generic GSM (0); Frequency: 1880 MHz; Duty Cycle: 1:8.30042

Medium: 1900 MHz MSL Medium parameters used (interpolated): f = 1880 MHz;  $\sigma = 1.532$  S/m;  $\epsilon_r = 52.412$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section

DASY4 Configuration:

- Probe: ET3DV6 SN1528; ConvF(4.76, 4.76, 4.76); Calibrated: 16/4/2014;
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1438; Calibrated: 12/5/2014
- Phantom: SAM (30deg probe tilt) with CRP v5.0; Type: QD000P40CD; Serial: TP:1836
- -; SEMCAD X Version 14.6.10 (7331)

Configuration/Front Closed - Middle/Area Scan (61x101x1): Interpolated grid: dx=1.500 mm, dy=1.500 mm

Maximum value of SAR (interpolated) = 0.294 W/kg

Configuration/Front Closed - Middle/Zoom Scan (5x5x7) (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm


Reference Value = 5.754 V/m; Power Drift = -0.07 dB

Peak SAR (extrapolated) = 0.379 W/kg

**SAR(1 g) = 0.260 W/kg; SAR(10 g) = 0.164 W/kg** Maximum value of SAR (measured) = 0.282 W/kg 012: Back Closed of EUT Facing Phantom PCS 1900 CH661

Date: 10/3/2015

DUT: Panasonic; Type: 401PM; Serial: 004401221425016



0 dB = 0.403 W/kg = -3.94 dBW/kg

Communication System: UID 0, Generic GSM (0); Frequency: 1880 MHz; Duty Cycle: 1:8.30042

Medium: 1900 MHz MSL Medium parameters used (interpolated): f = 1880 MHz;  $\sigma = 1.532$  S/m;  $\epsilon_r = 52.412$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section

DASY4 Configuration:

- Probe: ET3DV6 SN1528; ConvF(4.76, 4.76, 4.76); Calibrated: 16/4/2014;
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1438; Calibrated: 12/5/2014
- Phantom: SAM (30deg probe tilt) with CRP v5.0; Type: QD000P40CD; Serial: TP:1836
- -; SEMCAD X Version 14.6.10 (7331)

Configuration/Back Closed - Middle/Area Scan (61x101x1): Interpolated grid: dx=1.500 mm, dy=1.500 mm Maximum value of SAR (interpolated) = 0.403 W/kg

Configuration/Back Closed - Middle/Zoom Scan (5x5x7) (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm

Reference Value = 9.088 V/m; Power Drift = -0.04 dB

Peak SAR (extrapolated) = 0.585 W/kg

SAR(1 g) = 0.346 W/kg; SAR(10 g) = 0.194 W/kg

Maximum value of SAR (measured) = 0.388 W/kg

#### A.5. Calibration Certificate for E-Field Probe

This section contains the calibration certificates and data for the Probe(s) used, which are not included in the total number of pages for this report.

Cheeked

Calibration Laboratory of Schmid & Partner Engineering AG Zeughausstrasse 43, 8004 Zurich, Switzerland





Schweizerischer Kalibrierdienst Service suisse d'étalonnage Servizio svizzero di taratura Swiss Calibration Service

Accredited by the Swiss Accreditation Service (SAS)

The Swiss Accreditation Service is one of the signatories to the EA Multilateral Agreement for the recognition of calibration certificates

Client

**UL RFI UK** 

Accreditation No.: SCS 108

A1185

Certificate No: ET3-1528\_Apr14

## **CALIBRATION CERTIFICATE**

Object

ET3DV6 - SN:1528

Calibration procedure(s)

QA CAL-01.v9, QA CAL-23.v5, QA CAL-25.v6 Calibration procedure for dosimetric E-field probes

Calibration date:

April 16, 2014

This calibration certificate documents the traceability to national standards, which realize the physical units of measurements (SI). The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature (22 ± 3)°C and humidity < 70%.

Calibration Equipment used (M&TE critical for calibration)

Primary Standards	ID	Cal Date (Certificate No.)	Scheduled Calibration
Power meter E4419B	GB41293874	03-Apr-14 (No. 217-01911)	Apr-15
Power sensor E4412A	MY41498087	03-Apr-14 (No. 217-01911)	Apr-15
Reference 3 dB Attenuator	SN: S5054 (3c)	03-Apr-14 (No. 217-01915)	Apr-15
Reference 20 dB Attenuator	SN: S5277 (20x)	03-Apr-14 (No. 217-01919)	Apr-15
Reference 30 dB Attenuator	SN: S5129 (30b)	03-Apr-14 (No. 217-01920)	Apr-15
Reference Probe ES3DV2	SN: 3013	30-Dec-13 (No. ES3-3013_Dec13)	Dec-14
DAE4	SN: 660	13-Dec-13 (No. DAE4-660_Dec13)_	Dec-14
Secondary Standards	ID	Check Date (in house)	Scheduled Check
RF generator HP 8648C	US3642U01700	4-Aug-99 (in house check Apr-13)	In house check: Apr-16
Network Analyzer HP 8753E	US37390585	18-Oct-01 (in house check Oct-13)	In house check: Oct-14

Issued: April 16, 2014

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.

# Calibration Laboratory of Schmid & Partner

Engineering AG
Zeughausstrasse 43, 8004 Zurich, Switzerland





S Schweizerischer Kalibrierdienst
C Service suisse d'étalonnage
Servizio svizzero di taratura
Swiss Calibration Service

Accreditation No.: SCS 108

Accredited by the Swiss Accreditation Service (SAS)

The Swiss Accreditation Service is one of the signatories to the EA Multilateral Agreement for the recognition of calibration certificates

#### Glossary:

TSL tissue simulating liquid
NORMx,y,z sensitivity in free space
ConvF sensitivity in TSL / NORMx,y,z
DCP diode compression point

CF crest factor (1/duty\_cycle) of the RF signal modulation dependent linearization parameters

Polarization  $\varphi$   $\varphi$  rotation around probe axis

Polarization 9 9 rotation around an axis that is in the plane normal to probe axis (at measurement center),

i.e., 9 = 0 is normal to probe axis

Connector Angle information used in DASY system to align probe sensor X to the robot coordinate system

#### **Calibration is Performed According to the Following Standards:**

- a) IEEE Std 1528-2013, "IEEE Recommended Practice for Determining the Peak Spatial-Averaged Specific Absorption Rate (SAR) in the Human Head from Wireless Communications Devices: Measurement Techniques", June 2013
- b) IEC 62209-1, "Procedure to measure the Specific Absorption Rate (SAR) for hand-held devices used in close proximity to the ear (frequency range of 300 MHz to 3 GHz)", February 2005

#### **Methods Applied and Interpretation of Parameters:**

- NORMx,y,z: Assessed for E-field polarization θ = 0 (f ≤ 900 MHz in TEM-cell; f > 1800 MHz: R22 waveguide).
   NORMx,y,z are only intermediate values, i.e., the uncertainties of NORMx,y,z does not affect the E²-field uncertainty inside TSL (see below ConvF).
- NORM(f)x,y,z = NORMx,y,z \* frequency\_response (see Frequency Response Chart). This linearization is implemented in DASY4 software versions later than 4.2. The uncertainty of the frequency response is included in the stated uncertainty of ConvF.
- DCPx,y,z: DCP are numerical linearization parameters assessed based on the data of power sweep with CW signal (no uncertainty required). DCP does not depend on frequency nor media.
- PAR: PAR is the Peak to Average Ratio that is not calibrated but determined based on the signal characteristics
- Ax,y,z; Bx,y,z; Cx,y,z; Dx,y,z; VRx,y,z: A, B, C, D are numerical linearization parameters assessed based on the data of power sweep for specific modulation signal. The parameters do not depend on frequency nor media. VR is the maximum calibration range expressed in RMS voltage across the diode.
- ConvF and Boundary Effect Parameters: Assessed in flat phantom using E-field (or Temperature Transfer Standard for f ≤ 800 MHz) and inside waveguide using analytical field distributions based on power measurements for f > 800 MHz. The same setups are used for assessment of the parameters applied for boundary compensation (alpha, depth) of which typical uncertainty values are given. These parameters are used in DASY4 software to improve probe accuracy close to the boundary. The sensitivity in TSL corresponds to NORMx,y,z \* ConvF whereby the uncertainty corresponds to that given for ConvF. A frequency dependent ConvF is used in DASY version 4.4 and higher which allows extending the validity from ± 50 MHz to ± 100 MHz
- Spherical isotropy (3D deviation from isotropy): in a field of low gradients realized using a flat phantom exposed by a patch antenna.
- Sensor Offset: The sensor offset corresponds to the offset of virtual measurement center from the probe tip (on probe axis). No tolerance required.
- Connector Angle: The angle is assessed using the information gained by determining the NORMx (no uncertainty required).

Certificate No: ET3-1528\_Apr14 Page 2 of 11

# Probe ET3DV6

SN:1528

Calibrated:

Manufactured: March 21, 2000 April 16, 2014

Calibrated for DASY/EASY Systems

(Note: non-compatible with DASY2 system!)

# DASY/EASY - Parameters of Probe: ET3DV6 - SN:1528

#### **Basic Calibration Parameters**

	Sensor X	Sensor Y	Sensor Z	Unc (k=2)
Norm (μV/(V/m) <sup>2</sup> ) <sup>A</sup>	1.44	1.85	1.59	± 10.1 %
DCP (mV) <sup>B</sup>	97.4	100.0	102.2	

#### **Modulation Calibration Parameters**

UID	Communication System Name		Α	В	С	D	VR	Unc <sup>⊨</sup>
			dB	dB√μV		dB	mV	(k=2)
0	CW	X	0.0	0.0	1.0	0.00	232.7	±3.5 %
		Y	0.0	0.0	1.0		229.2	
		Z	0.0	0.0	1.0		230.2	

The reported uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor k=2, which for a normal distribution corresponds to a coverage probability of approximately 95%.

B Numerical linearization parameter: uncertainty not required.

A The uncertainties of NormX,Y,Z do not affect the E2-field uncertainty inside TSL (see Pages 5 and 6).

E Uncertainty is determined using the max. deviation from linear response applying rectangular distribution and is expressed for the square of the field value.

ET3DV6- SN:1528

## DASY/EASY - Parameters of Probe: ET3DV6 - SN:1528

April 16, 2014

#### **Calibration Parameter Determined in Head Tissue Simulating Media**

f (MHz) <sup>C</sup>	Relative Permittivity <sup>F</sup>	Conductivity (S/m) F	ConvF X	ConvF Y	ConvF Z	Alpha <sup>G</sup>	Depth <sup>G</sup> (mm)	Unct. (k=2)
750	41.9	0.89	6.48	6.48	6.48	0.28	3.00	± 12.0 %
835	41.5	0.90	6.24	6.24	6.24	0.31	3.00	± 12.0 %
900	41.5	0.97	6.06	6.06	6.06	0.32	3.00	± 12.0 %
1450	40.5	1.20	5.44	5.44	5.44	0.42	3.00	± 12.0 %
1750	40.1	1.37	5.25	5.25	5.25	0.80	2.14	± 12.0 %
1900	40.0	1.40	5.19	5.19	5.19	0.80	1.98	± 12.0 %
2100	39.8	1.49	5.21	5.21	5.21	0.80	1.97	± 12.0 %
2300	39.5	1.67	4.70	4.70	4.70	0.80	1.81	± 12.0 %
2450	39.2	1.80	4.34	4.34	4.34	0.80	1.65	± 12.0 %

<sup>&</sup>lt;sup>C</sup> Frequency validity of  $\pm$  100 MHz only applies for DASY v4.4 and higher (see Page 2), else it is restricted to  $\pm$  50 MHz. The uncertainty is the RSS of the ConvF uncertainty at calibration frequency and the uncertainty for the indicated frequency band.

F At frequencies below 3 GHz, the validity of tissue parameters (ε and σ) can be relaxed to  $\pm$  10% if liquid compensation formula is applied to

F At frequencies below 3 GHz, the validity of tissue parameters ( $\varepsilon$  and  $\sigma$ ) can be relaxed to  $\pm$  10% if liquid compensation formula is applied to measured SAR values. At frequencies above 3 GHz, the validity of tissue parameters ( $\varepsilon$  and  $\sigma$ ) is restricted to  $\pm$  5%. The uncertainty is the RSS of the ConvF uncertainty for indicated target tissue parameters.

the ConvF uncertainty for indicated target tissue parameters.

Alpha/Depth are determined during calibration. SPEAG warrants that the remaining deviation due to the boundary effect after compensation is always less than ± 1% for frequencies below 3 GHz and below ± 2% for frequencies between 3-6 GHz at any distance larger than half the probe tip diameter from the boundary.

April 16, 2014 ET3DV6-SN:1528

# DASY/EASY - Parameters of Probe: ET3DV6 - SN:1528

#### Calibration Parameter Determined in Body Tissue Simulating Media

f (MHz) <sup>C</sup>	Relative Permittivity <sup>F</sup>	Conductivity (S/m) <sup>F</sup>	ConvF X	ConvF Y	ConvF Z	Alpha <sup>G</sup>	Depth <sup>G</sup> (mm)	Unct. (k=2)
750	55.5	0.96	6.09	6.09	6.09	0.38	2.49	± 12.0 %
835	55.2	0.97	6.03	6.03	6.03	0.56	2.14	± 12.0 %
900	55.0	1.05	5.92	5.92	5.92	0.36	2.87	± 12.0 %
1450	54.0	1.30	5.20	5.20	5.20	0.80	1.52	± 12.0 %
1750	53.4	1.49	4.68	4.68	4.68	0.80	2.41	± 12.0 %
1900	53.3	1.52	4.76	4.76	4.76	0.80	2.37	± 12.0 %
2100	53.2	1.62	4.71	4.71	4.71	0.80	2.18	± 12.0 %
2300	52.9	1.81	4.27	4.27	4.27	0.80	1.57	± 12.0 %
2450	52.7	1.95	4.10	4.10	4.10	0.80	1.37	± 12.0 %

<sup>&</sup>lt;sup>c</sup> Frequency validity of ± 100 MHz only applies for DASY v4.4 and higher (see Page 2), else it is restricted to ± 50 MHz. The uncertainty is the RSS


of the ConvF uncertainty at calibration frequency and the uncertainty for the indicated frequency band.

At frequencies below 3 GHz, the validity of tissue parameters (ε and σ) can be relaxed to ± 10% if liquid compensation formula is applied to measured SAR values. At frequencies above 3 GHz, the validity of tissue parameters ( $\epsilon$  and  $\sigma$ ) is restricted to  $\pm$  5%. The uncertainty is the RSS of

the ConvF uncertainty for indicated target tissue parameters.

Galpha/Depth are determined during calibration. SPEAG warrants that the remaining deviation due to the boundary effect after compensation is always less than ± 1% for frequencies below 3 GHz and below ± 2% for frequencies between 3-6 GHz at any distance larger than half the probe tip diameter from the boundary.

# Frequency Response of E-Field (TEM-Cell:ifi110 EXX, Waveguide: R22)




Uncertainty of Frequency Response of E-field: ± 6.3% (k=2)

April 16, 2014 ET3DV6-SN:1528

# Receiving Pattern ( $\phi$ ), $\vartheta = 0^{\circ}$




f=600 MHz,TEM f=1800 MHz,R22 Tot Tot




Uncertainty of Axial Isotropy Assessment: ± 0.5% (k=2)

ET3DV6- SN:1528 April 16, 2014

# Dynamic Range f(SAR<sub>head</sub>) (TEM cell , f<sub>eval</sub>= 1900 MHz)






Uncertainty of Linearity Assessment: ± 0.6% (k=2)


April 16, 2014


# **Conversion Factor Assessment**



# **Deviation from Isotropy in Liquid**

Error  $(\phi, \vartheta)$ , f = 900 MHz





ET3DV6- SN:1528 April 16, 2014

# DASY/EASY - Parameters of Probe: ET3DV6 - SN:1528

#### **Other Probe Parameters**

Sensor Arrangement	Triangular
Connector Angle (°)	19.2
Mechanical Surface Detection Mode	enabled
Optical Surface Detection Mode	disabled
Probe Overall Length	337 mm
Probe Body Diameter	10 mm
Tip Length	10 mm
Tip Diameter	6.8 mm
Probe Tip to Sensor X Calibration Point	2.7 mm
Probe Tip to Sensor Y Calibration Point	2.7 mm
Probe Tip to Sensor Z Calibration Point	2.7 mm
Recommended Measurement Distance from Surface	4 mm

Certificate No: ET3-1528\_Apr14 Page 11 of 11


#### A.6. Calibration Certificate for Dipole

This section contains the calibration certificates and data for the Dipole(s) used, which are not included in the total number of pages for this report.

#### Calibration Laboratory of

Schmid & Partner **Engineering AG** Zeughausstrasse 43, 8004 Zurich, Switzerland





Schweizerischer Kalibrierdienst Service suisse d'étalonnage Servizio svizzero di taratura **Swiss Calibration Service** 

Accredited by the Swiss Accreditation Service (SAS)

The Swiss Accreditation Service is one of the signatories to the EA Multilateral Agreement for the recognition of calibration certificates

Client

**UL RFI UK** 

Certificate No: D1900V2-540\_Dec14

Accreditation No.: SCS 108

## CALIBRATION CERTIFICATE

D1900V2 - SN: 540 Object

QA CAL-05.v9 Calibration procedure(s)

Calibration procedure for dipole validation kits above 700 MHz

December 08, 2014 Calibration date:

This calibration certificate documents the traceability to national standards, which realize the physical units of measurements (SI). The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature (22 ± 3)°C and humidity < 70%.

Calibration Equipment used (M&TE critical for calibration)

Primary Standards	ID#	Cal Date (Certificate No.)	Scheduled Calibration
Power meter EPM-442A	GB37480704	07-Oct-14 (No. 217-02020)	Oct-15
Power sensor HP 8481A	US37292783	07-Oct-14 (No. 217-02020)	Oct-15
Power sensor HP 8481A	MY41092317	07-Oct-14 (No. 217-02021)	Oct-15
Reference 20 dB Attenuator	SN: 5058 (20k)	03-Apr-14 (No. 217-01918)	Apr-15
Type-N mismatch combination	SN: 5047.2 / 06327	03-Apr-14 (No. 217-01921)	Apr-15
Reference Probe ES3DV3	SN: 3205	30-Dec-13 (No. ES3-3205_Dec13)	Dec-14
DAE4	SN: 601	18-Aug-14 (No. DAE4-601_Aug14)	Aug-15
Secondary Standards	ID#	Check Date (in house)	Scheduled Check
RF generator R&S SMT-06	100005	04-Aug-99 (in house check Oct-13)	In house check: Oct-16
Network Analyzer HP 8753E	US37390585 S4206	18-Oct-01 (in house check Oct-14)	In house check: Oct-15
	Name	Function	Signature
Calibrated by:	Michael Woher	Laboratory Technician	1/11/1

Calibrated by: Michael Weber Laboratory Technician

Approved by: Katja Pokovic Technical Manager

Issued: December 9, 2014

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.

Certificate No: D1900V2-540\_Dec14 Page 1 of 8

#### Calibration Laboratory of

Schmid & Partner
Engineering AG
Zeughausstrasse 43, 8004 Zurich, Switzerland





S

C

Schweizerischer Kalibrierdienst Service suisse d'étalonnage Servizio svizzero di taratura Swiss Calibration Service

Accreditation No.: SCS 108

Accredited by the Swiss Accreditation Service (SAS)

The Swiss Accreditation Service is one of the signatories to the EA Multilateral Agreement for the recognition of calibration certificates

#### Glossary:

TSL tissue simulating liquid

ConvF sensitivity in TSL / NORM x,y,z N/A not applicable or not measured

#### Calibration is Performed According to the Following Standards:

- a) IEEE Std 1528-2013, "IEEE Recommended Practice for Determining the Peak Spatial-Averaged Specific Absorption Rate (SAR) in the Human Head from Wireless Communications Devices: Measurement Techniques", June 2013
- iEC 62209-1, "Procedure to measure the Specific Absorption Rate (SAR) for hand-held devices used in close proximity to the ear (frequency range of 300 MHz to 3 GHz)", February 2005
- c) KDB 865664, "SAR Measurement Requirements for 100 MHz to 6 GHz"

#### Additional Documentation:

d) DASY4/5 System Handbook

#### Methods Applied and Interpretation of Parameters:

- Measurement Conditions: Further details are available from the Validation Report at the end
  of the certificate. All figures stated in the certificate are valid at the frequency indicated.
- Antenna Parameters with TSL: The dipole is mounted with the spacer to position its feed
  point exactly below the center marking of the flat phantom section, with the arms oriented
  parallel to the body axis.
- Feed Point Impedance and Return Loss: These parameters are measured with the dipole positioned under the liquid filled phantom. The impedance stated is transformed from the measurement at the SMA connector to the feed point. The Return Loss ensures low reflected power. No uncertainty required.
- Electrical Delay: One-way delay between the SMA connector and the antenna feed point.
   No uncertainty required.
- SAR measured: SAR measured at the stated antenna input power.
- SAR normalized: SAR as measured, normalized to an input power of 1 W at the antenna connector.
- SAR for nominal TSL parameters: The measured TSL parameters are used to calculate the nominal SAR result.

The reported uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor k=2, which for a normal distribution corresponds to a coverage probability of approximately 95%.

Certificate No: D1900V2-540\_Dec14 Page 2 of 8

## **Measurement Conditions**

DASY system configuration, as far as not given on page 1.

DASY Version	DASY5	V52.8.8
Extrapolation	Advanced Extrapolation	
Phantom	Modular Flat Phantom	
Distance Dipole Center - TSL	10 mm	with Spacer
Zoom Scan Resolution	dx, $dy$ , $dz = 5 mm$	
Frequency	1900 MHz ± 1 MHz	

## **Head TSL parameters**

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Head TSL parameters	22.0 °C	40.0	1.40 mho/m
Measured Head TSL parameters	(22.0 ± 0.2) °C	39.6 ± 6 %	1.38 mho/m ± 6 %
Head TSL temperature change during test	< 0.5 °C		****

#### SAR result with Head TSL

SAR averaged over 1 cm <sup>3</sup> (1 g) of Head TSL	Condition	
SAR measured	250 mW input power	9.97 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	40.1 W/kg ± 17.0 % (k=2)

SAR averaged over 10 cm <sup>3</sup> (10 g) of Head TSL	condition	
SAR measured	250 mW input power	5.21 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	20.9 W/kg ± 16.5 % (k=2)

## **Body TSL parameters**

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Body TSL parameters	22.0 °C	53.3	1.52 mho/m
Measured Body TSL parameters	(22.0 ± 0.2) °C	53.3 ± 6 %	1.50 mho/m ± 6 %
Body TSL temperature change during test	< 0.5 °C		2222

## SAR result with Body TSL

SAR averaged over 1 cm <sup>3</sup> (1 g) of Body TSL	Condition	
SAR measured	250 mW input power	9,91 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	40.0 W/kg ± 17.0 % (k=2)

SAR averaged over 10 cm <sup>3</sup> (10 g) of Body TSL	condition	
SAR measured	250 mW input power	5.25 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	21.1 W/kg ± 16.5 % (k=2)

Certificate No: D1900V2-540\_Dec14 Page 3 of 8

# Appendix (Additional assessments outside the scope of SCS108)

#### Antenna Parameters with Head TSL

Impedance, transformed to feed point	53.3 Ω + 4.9 jΩ
Return Loss	- 24.9 dB

#### Antenna Parameters with Body TSL

Impedance, transformed to feed point	$48.7 \Omega + 5.7 j\Omega$	
Return Loss	- 24.6 dB	

#### General Antenna Parameters and Design

Electrical Delay (one direction)	1.199 ns
Liectifical Delay (offe direction)	W. W

After long term use with 100W radiated power, only a slight warming of the dipole near the feedpoint can be measured.

The dipole is made of standard semirigid coaxial cable. The center conductor of the feeding line is directly connected to the second arm of the dipole. The antenna is therefore short-circuited for DC-signals. On some of the dipoles, small end caps are added to the dipole arms in order to improve matching when loaded according to the position as explained in the "Measurement Conditions" paragraph. The SAR data are not affected by this change. The overall dipole length is still according to the Standard.

No excessive force must be applied to the dipole arms, because they might bend or the soldered connections near the feedpoint may be damaged.

#### **Additional EUT Data**

Manufactured by	SPEAG	
Manufactured on	July 26, 2001	

Certificate No: D1900V2-540\_Dec14 Page 4 of 8

#### **DASY5 Validation Report for Head TSL**

Date: 08.12.2014

Test Laboratory: SPEAG, Zurich, Switzerland

## DUT: Dipole 1900 MHz; Type: D1900V2; Serial: D1900V2 - SN: 540

Communication System: UID 0 - CW; Frequency: 1900 MHz

Medium parameters used: f = 1900 MHz;  $\sigma = 1.38 \text{ S/m}$ ;  $\varepsilon_r = 39.6$ ;  $\rho = 1000 \text{ kg/m}^3$ 

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

#### DASY52 Configuration:

Probe: ES3DV3 - SN3205; ConvF(5.06, 5.06, 5.06); Calibrated: 30.12.2013;

Sensor-Surface: 3mm (Mechanical Surface Detection)

Electronics: DAE4 Sn601; Calibrated: 18.08.2014

Phantom: Flat Phantom 5.0 (front); Type: QD000P50AA; Serial: 1001

DASY52 52.8.8(1222); SEMCAD X 14.6.10(7331)

# Dipole Calibration for Head Tissue/Pin=250 mW, d=10mm/Zoom Scan (7x7x7)/Cube 0:


Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 98.55 V/m; Power Drift = 0.01 dB

Peak SAR (extrapolated) = 18.4 W/kg


SAR(1 g) = 9.97 W/kg; SAR(10 g) = 5.21 W/kg

Maximum value of SAR (measured) = 12.7 W/kg



0 dB = 12.7 W/kg = 11.04 dBW/kg

# Impedance Measurement Plot for Head TSL



#### **DASY5 Validation Report for Body TSL**

Date: 08.12.2014

Test Laboratory: SPEAG, Zurich, Switzerland

## DUT: Dipole 1900 MHz; Type: D1900V2; Serial: D1900V2 - SN: 540

Communication System: UID 0 - CW; Frequency: 1900 MHz

Medium parameters used: f = 1900 MHz;  $\sigma = 1.5 \text{ S/m}$ ;  $\epsilon_r = 53.3$ ;  $\rho = 1000 \text{ kg/m}^3$ 

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

#### DASY52 Configuration:

Probe: ES3DV3 - SN3205; ConvF(4.76, 4.76, 4.76); Calibrated: 30.12.2013;

Sensor-Surface: 3mm (Mechanical Surface Detection)

Electronics: DAE4 Sn601; Calibrated: 18.08.2014

Phantom: Flat Phantom 5.0 (back); Type: QD000P50AA; Serial: 1002

DASY52 52.8.8(1222); SEMCAD X 14.6.10(7331)

# Dipole Calibration for Body Tissue/Pin=250 mW, d=10mm/Zoom Scan (7x7x7)/Cube 0:


Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 94.59 V/m; Power Drift = -0.00 dB

Peak SAR (extrapolated) = 17.2 W/kg


SAR(1 g) = 9.91 W/kg; SAR(10 g) = 5.25 W/kg

Maximum value of SAR (measured) = 12.4 W/kg



0 dB = 12.4 W/kg = 10.93 dBW/kg

# Impedance Measurement Plot for Body TSL



#### A.7. Tissues-Equivalent Media Recipes

The body mixture consists of water, Polysorbate (Tween 20) and salt. Visual inspection is made to ensure air bubbles are not trapped during the mixing process. The mixture is calibrated to obtain proper dielectric constant (permittivity) and conductivity of the tissue.

Ingredient	Frequency 1900 MHz	
(% by weight)	Head	Body
De-Ionized Water	55.40	71.50
Polysorbate 20	44.22	28.00
Salt	0.38	0.50