## System Check Head 1750MHz 140530

#### **DUT: D1750V2-1068**

Communication System: CW; Frequency: 1750 MHz; Duty Cycle: 1:1

Medium: HSL\_1750\_140530 Medium parameters used: f = 1750 MHz;  $\sigma = 1.409$  S/m;  $\epsilon_r = 39.382$ ;  $\rho = 1.409$  S/m;  $\epsilon_r = 39.382$ ;  $\epsilon_r = 39.3$ 

Date: 2014/5/30

 $1000 \text{ kg/m}^3$ 

Ambient Temperature: 23.6 °C; Liquid Temperature: 22.6 °C

### DASY5 Configuration:

- Probe: ES3DV3 SN3270; ConvF(5.26, 5.26, 5.26); Calibrated: 2013/9/24;
- Sensor-Surface: 3mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1279; Calibrated: 2014/1/30
- Phantom: SAM-Right; Type: QD 000 P40 C; Serial: TP-1446
- Measurement SW: DASY52, Version 52.8 (7); SEMCAD X Version 14.6.10 (7164)

## Configuration/Pin=250mW/Area Scan (61x61x1): Interpolated grid: dx=1.500 mm, dy=1.500 mm

Maximum value of SAR (interpolated) = 10.8 W/kg

### Configuration/Pin=250mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm,


dy=8mm, dz=5mm

Reference Value = 83.031 V/m; Power Drift = 0.06 dB

Peak SAR (extrapolated) = 14.1 W/kg

SAR(1 g) = 8.85 W/kg; SAR(10 g) = 5.12 W/kg

Maximum value of SAR (measured) = 10.7 W/kg



0 dB = 10.7 W/kg = 10.29 dBW/kg

## System Check Head 1900MHz 140529

#### DUT: D1900V2-5d041

Communication System: CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: HSL\_1900\_140529 Medium parameters used: f=1900 MHz;  $\sigma=1.436$  S/m;  $\epsilon_r=41.511;$   $\rho=1.436$  MHz;  $\sigma=1.436$  S/m;  $\epsilon_r=41.511;$   $\epsilon_r$ 

Date: 2014/5/29

 $1000 \text{ kg/m}^3$ 

Ambient Temperature: 23.5 °C; Liquid Temperature: 22.5 °C

### DASY5 Configuration:

- Probe: EX3DV4 SN3954; ConvF(8.13, 8.13, 8.13); Calibrated: 2013/11/4;
- Sensor-Surface: 2mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1279; Calibrated: 2014/1/30
- Phantom: SAM-Right; Type: QD 000 P40 C; Serial: TP-1446
- Measurement SW: DASY52, Version 52.8 (7); SEMCAD X Version 14.6.10 (7164)

## Configuration/Pin=250mW/Area Scan (61x61x1): Interpolated grid: dx=1.500 mm, dy=1.500 mm

Maximum value of SAR (interpolated) = 13.3 W/kg

### Configuration/Pin=250mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm,


dy=8mm, dz=5mm

Reference Value = 96.662 V/m; Power Drift = 0.02 dB

Peak SAR (extrapolated) = 17.0 W/kg

SAR(1 g) = 9.45 W/kg; SAR(10 g) = 4.94 W/kg

Maximum value of SAR (measured) = 13.4 W/kg



0 dB = 13.4 W/kg = 11.27 dBW/kg

### System Check Body 1750MHz 140527

#### **DUT: D1750V2-1068**

Communication System: CW; Frequency: 1750 MHz; Duty Cycle: 1:1

Medium: MSL\_1750\_140527 Medium parameters used: f=1750 MHz;  $\sigma=1.518$  S/m;  $\epsilon_r=52.095;$   $\rho=1.518$  MHz;  $\sigma=1.518$  S/m;  $\epsilon_r=52.095;$   $\epsilon_r=52.095;$   $\epsilon_r=52.095;$   $\epsilon_r=52.095;$  MHz;  $\epsilon_r=52.095;$   $\epsilon_r=52.095$ 

Date: 2014/5/27

 $= 1000 \text{ kg/m}^3$ 

Ambient Temperature: 23.4 °C; Liquid Temperature: 22.4 °C

### DASY5 Configuration:

- Probe: ES3DV3 SN3270; ConvF(4.91, 4.91, 4.91); Calibrated: 2013/9/24;
- Sensor-Surface: 3mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn778: Calibrated: 2013/8/21
- Phantom: SAM-Left; Type: QD 000 P40 C; Serial: TP-1478
- Measurement SW: DASY52, Version 52.8 (7); SEMCAD X Version 14.6.10 (7164)

## Configuration/Pin=250mW/Area Scan (61x61x1): Interpolated grid: dx=1.500 mm, dy=1.500 mm

Maximum value of SAR (interpolated) = 10.8 W/kg

### Configuration/Pin=250mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm,


dy=8mm, dz=5mm

Reference Value = 81.115 V/m; Power Drift = 0.02 dB

Peak SAR (extrapolated) = 13.7 W/kg

SAR(1 g) = 8.88 W/kg; SAR(10 g) = 5.17 W/kg

Maximum value of SAR (measured) = 10.7 W/kg



0 dB = 10.7 W/kg = 10.29 dBW/kg

## System Check Body 1750MHz 140527

#### **DUT: D1750V2-1068**

Communication System: CW; Frequency: 1750 MHz; Duty Cycle: 1:1

Medium: MSL\_1750\_140527 Medium parameters used: f = 1750 MHz;  $\sigma = 1.518$  S/m;  $\varepsilon_r = 52.095$ ;  $\rho$ 

Date: 2014/5/27

 $= 1000 \text{ kg/m}^3$ 

Ambient Temperature: 23.4 °C; Liquid Temperature: 22.4 °C

### DASY5 Configuration:

- Probe: EX3DV4 SN3935; ConvF(8.3, 8.3, 8.3); Calibrated: 2013/11/4;
- Sensor-Surface: 2mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1338; Calibrated: 2013/11/5
- Phantom: SAM-Left; Type: QD 000 P40 C; Serial: TP-1478
- Measurement SW: DASY52, Version 52.8 (7); SEMCAD X Version 14.6.10 (7164)

# Configuration/Pin=250mW/Area Scan (61x61x1): Interpolated grid: dx=1.500 mm, dy=1.500 mm

Maximum value of SAR (interpolated) = 12.8 W/kg

## Configuration/Pin=250mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm,


dy=8mm, dz=5mm

Reference Value = 92.981 V/m; Power Drift = -0.06 dB

Peak SAR (extrapolated) = 15.8 W/kg

SAR(1 g) = 9.13 W/kg; SAR(10 g) = 4.9 W/kg

Maximum value of SAR (measured) = 12.8 W/kg



0 dB = 12.8 W/kg = 11.07 dBW/kg

### System Check Body 1900MHz 140529

#### **DUT: D1900V2-5d041**

Communication System: CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: MSL\_1900\_140529 Medium parameters used: f = 1900 MHz;  $\sigma = 1.545$  S/m;  $\varepsilon_r = 51.942$ ;  $\rho$ 

Date: 2014/5/29

 $= 1000 \text{ kg/m}^3$ 

Ambient Temperature: 23.4 °C; Liquid Temperature: 22.4 °C

### DASY5 Configuration:

- Probe: EX3DV4 SN3954; ConvF(7.95, 7.95, 7.95); Calibrated: 2013/11/4;
- Sensor-Surface: 2mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1279; Calibrated: 2014/1/30
- Phantom: SAM-Left; Type: QD 000 P40 C; Serial: TP-1478
- Measurement SW: DASY52, Version 52.8 (7); SEMCAD X Version 14.6.10 (7164)

## Configuration/Pin=250mW/Area Scan (61x61x1): Interpolated grid: dx=1.500 mm, dy=1.500 mm

Maximum value of SAR (interpolated) = 15.8 W/kg

### Configuration/Pin=250mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm,


dy=8mm, dz=5mm

Reference Value = 99.572 V/m; Power Drift = -0.01dB

Peak SAR (extrapolated) = 19.6 W/kg

SAR(1 g) = 10.7 W/kg; SAR(10 g) = 5.52 W/kg

Maximum value of SAR (measured) = 14.9 W/kg



0 dB = 14.9 W/kg = 11.73 dBW/kg