System Check_Body_2450MHz_130403

DUT: D2450V2-SN:736

Communication System: CW; Frequency: 2450 MHz;Duty Cycle: 1:1
Medium: MSL_2450_130403 Medium parameters used: f = 2450 MHz; σ = 1.965 mho/m; ε_r = 51.537; ρ = 1000 kg/m^3
Ambient Temperature：22.6 ℃；Liquid Temperature：21.6 ℃

DASY5 Configuration:
- Probe: ES3DV3 - SN3270; ConvF(4.17, 4.17, 4.17); Calibrated: 2012/9/28;
- Sensor-Surface: 3mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn778; Calibrated: 2012/8/27
- Phantom: ELI 4.0_Front; Type: QDOVA001BB; Serial: 1026
- Measurement SW: DASY52, Version 52.8 (2); SEMCAD X Version 14.6.6 (6477)

Configuration/Pin=250mW/Area Scan (61x61x1): Measurement grid: dx=12mm, dy=12mm
Maximum value of SAR (interpolated) = 19.1 mW/g

Configuration/Pin=250mW/Zoom Scan (7x7x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm, dz=5mm
Reference Value = 93.954 V/m; Power Drift = 0.04 dB
Peak SAR (extrapolated) = 28.509 mW/g
SAR(1 g) = 13.5 mW/g; SAR(10 g) = 6.35 mW/g
Maximum value of SAR (measured) = 17.8 mW/g

0 dB = 17.8 mW/g = 25.01 dB mW/g