

Nemko Test Report:	27180RUS1Rev2
Applicant:	TeleAlarm SA Rue du Pont 23 La Chaux-de-Fonds CH-2300 Switzerland
Equipment Under Test: (E.U.T.)	MIYSD Wireless Smoke Detector (434.01)
FCC Identifier:	W9N-MIYSD
In Accordance With: Tested By:	FCC Part 15, Subpart C and RSS 210, Issue 7 For Low Power Transmitters Operating Periodically In The Band 40.66 - 40.77 MHz And Above 70 MHz Nemko USA, Inc. 802 N. Kealy
	Lewisville, TX 75057-3136
TESTED BY: David Light, Senior	DATE: 24 March 2009
APPROVED BY: Tom Tidwell, Telecon	
ı otal N	lumber of Pages: 17

Nemko USA, Inc. FCC PART 15, SUBPART C and RSS 210. Issue 7
PERIODICALLY OPERATED LOW POWER TRANSMITTERS
EQUIPMENT: MIYSD Wireless Smoke Detector PROJECT NO.: 27180RUS1
(434.01)

TABLE OF CONTENTS

SECTION 1.	SUMMARY OF TEST RESULTS	3
SECTION 2.	EQUIPMENT UNDER TEST (E.U.T.)	5
SECTION 3.	TRANSMISSION REQUIREMENTS	7
SECTION 4.	RADIATED EMISSIONS	9
SECTION 5.	OCCUPIED BANDWIDTH	11
SECTION 6.	BLOCK DIAGRAMS	13
SECTION 7.	TEST EQUIPMENT LIST	15
ΔΝΝΕΥ Δ - ΒΕ	STRICTED RANDS	16

Nemko USA, Inc.

FCC PART 15, SUBPART C and RSS 210. Issue 7

PERIODICALLY OPERATED LOW POWER TRANSMITTERS

EQUIPMENT: MIYSD Wireless Smoke Detector

PROJECT NO.: 27180RUS1

(434.01)

Section 1.	Summary of Te	st Results
------------	---------------	------------

Manufacturer: TeleAlarm SA

Model No.: MIYSD Wireless Smoke Detector (434.01)

0710 (normal operation); 0661 (continuous mode) Serial No.:

General: All measurements are traceable to national standards.

These tests were conducted on a sample of the equipment for the purpose of demonstrating compliance with Part 15, Subpart C, Paragraph 15.231. All tests were conducted using measurement procedure ANSI C63.4-2003. Radiated emissions are made on an open area test site. A description of the test facility is on file with the FCC.

\boxtimes	New Submission	Production Unit
	Class II Permissive Change	Pre-Production Unit

THIS TEST REPORT RELATES ONLY TO THE ITEM(S) TESTED.

THE FOLLOWING DEVIATIONS FROM, ADDITIONS TO, OR EXCLUSIONS FROM THE TEST SPECIFICATIONS HAVE BEEN MADE. See "Summary of Test Data".



Nemko USA Inc. authorizes the above named company to reproduce this report provided it is reproduced in its entirety and for use by the company's employees only.

Any use which a third party makes of this report, or any reliance on or decisions to be made based on it, are the responsibility of such third parties. Nemko USA Inc. accepts no responsibility for damages, if any, suffered by any third party as a result of decisions made or actions based on this report.

This report applies only to the items tested.

Nemko USA, Inc. FCC PART 15, SUBPART C and RSS 210. Issue 7
PERIODICALLY OPERATED LOW POWER TRANSMITTERS

EQUIPMENT: MIYSD Wireless Smoke Detector PROJECT NO.: 27180RUS1

(434.01)

Summary Of Test Data

Name of Test	Paragraph No.	Results
Transmission Requirements	15.231(a), RSS 210 A1.1.1	Complies
Radiated Emissions	15.231(b), RSS 210 A1.1.2	Complies
Occupied Bandwidth	15.231(c), RSS 210 A1.1.3	Complies
Frequency Tolerance	15.231(d)	NA
Alternate Field Strength Requirements	15.231(e)	NA
Powerline Conducted Emissions	15.207, RSS GEN 7.2.2	NA

Footnotes:

- 1) The radio does not operate in the 40.66-40.70 MHz band
- 2) The radio does not operate with regular predetermined transmissions.
- 3) The radio is battery powered.

Nemko USA, Inc. FCC PART 15, SUBPART C and RSS 210. Issue 7 PERIODICALLY OPERATED LOW POWER TRANSMITTERS

EQUIPMENT: MIYSD Wireless Smoke Detector PROJECT NO.: **27180RUS1**

(434.01)

Section 2. Equipment Under Test (E.U.T.)

General Equipment Information

Frequency Range: 434.01 MHz

Operating Frequency(ies) of Sample: 434.01 MHz

Type of Emission: FSK

Emission Designator: F1D

Supply Power Requirement: 9 Vdc battery

Duty Cycle Correction Factor: None

Nemko USA, Inc. FCC PART 15, SUBPART C and RSS 210. Issue 7 PERIODICALLY OPERATED LOW POWER TRANSMITTERS


EQUIPMENT: MIYSD Wireless Smoke Detector PROJECT NO.: **27180RUS1**

(434.01)

Description of E.U.T.

434 MHz wireless smoke detector.

System Diagram



PERIODICALLY OPERATED LOW POWER TRANSMITTERS

PROJECT NO.: 27180RUS1

EQUIPMENT: MIYSD Wireless Smoke Detector

(434.01)

Section 3. Transmission Requirements

NAME OF TEST: Transmission Requirements PARA. NO.: 15.231(a)

TESTED BY: David Light DATE: 24 March 2009

Minimum Standard:

15.231(a) Continuous transmissions such as voice, video or data transmissions are not permitted.

15.231(a)(1) A manually operated transmitter shall employ a switch that will automatically deactivate the transmitter within not more than 5 seconds after being released.

15.231(a)(2) A transmitter activated automatically shall cease transmission within 5 seconds of activation.

15.231(a)(3) Periodic transmissions at regular predetermined intervals are not permitted. However polling or supervisory transmissions to determine system integrity of transmitters used in security or safety applications are allowed if the periodic rate of transmission does not exceed one transmission of not more than one second duration per hour for each transmitter.

15.231(a)(4) Intentional radiators which are employed for radio control purposes during emergencies involving fire, security, and safety of life, when activated to signal an alarm, may operate during the pendency of the alarm.

Test Results: Complies.

Test Data: Compliance was determined by verification of technical

specifications and a functional test on the equipment.


Nemko USA, Inc. FCC PART 15, SUBPART C and RSS 210. Issue 7
PERIODICALLY OPERATED LOW POWER TRANSMITTERS
EQUIPMENT: MIYSD Wireless Smoke Detector PROJECT NO.: 27180RUS1

(434.01)

Rationale for Compliance with Transmission Requirements

15.231(a)(1)	Manual activation	TX deactivation time:			
15.231(a)(2):	Automatic activation	2.5msec.			
15.231(a)(3): Regular, predetermined transmissions Polling or supervisory transmissions		TX rate and duration: 1.7sec. duration once each 24 hour period			
15 221(2)(4) :	Alarm device operating during the pend	ancy of alarm condition			
15.231(a)(4): Non-alarm device Non-alarm device					

Test Data – Transmission Requirements



Date: 24.MAR.2009 14:49:40

ALARM CRITERIA TRANSMISSION

Test Equipment: 1036-1082-802

PERIODICALLY OPERATED LOW POWER TRANSMITTERS

EQUIPMENT: MIYSD Wireless Smoke Detector PROJECT NO.: 27180RUS1

(434.01)

Section 4. Radiated Emissions

NAME OF TEST: Radiated Emissions PARA. NO.: 15.231(b)

TESTED BY: David Light DATE: 24 March 2009

Minimum Standard:

Permissible Field Strength Limits (Momentarily Operated Devices

Fundamental Frequency	Field Strength of Fundamental	Field Strength of Unwanted Emissions
(MHz)	Microvolts/Meter at 3 meters; (watts)	Microvolts/Meter at 3 meters; (watts)
40.66 - 40.70	2,250	225
70-130	1, 250	125
130-174	1,250 to 3,750*	125 to 375
174-260 (note 1)	3,750	375
260-470 (note 1)	3,750 to 12,500*	375 to 1,250
Above 470	12,500	1,250

Notes:

# Use quasi-peak or averaging meter.	For 130 - 174 MHz: FS (microvolts/m) = (56.82 x F) -
* Linear interpolation with frequency F in MHz	6136
	For 260 - 470 MHz: FS (microvolts/m) = (41.67 x F) -
	7083

Any emissions that fall within the restricted bands of 15.205 shall not exceed the following limits:

Frequency (MHz)	Field Strength (μV/m @ 3m)	Field Strength (dB @ 3m)
30 - 88	100	40.0
88 - 216	150	43.5
216 - 960	200	46.0
Above 960	500	54.0

Test Results: Complies. The worst-case emission level is 76.8 dBμV/m @

3m at 434.01 MHz. This is 4.0 dB below the specification

limit.

Test Data: See attached table.

Above 1 GHz a spectrum analyzer and low noise amplifier are used to measure emission levels. The spectrum analyzer resolution bandwidth was set to 1 MHz and video bandwidth was 3 MHz.

In the case of handheld equipment, the E.U.T. is rotated in three planes to obtain worst-case results.

PERIODICALLY OPERATED LOW POWER TRANSMITTERS

EQUIPMENT: MIYSD Wireless Smoke Detector PROJECT NO.: **27180RUS1**

(434.01)

Test Data - Radiated Emissions

Meas.	Ant.	Atten.	Meter	Antenna	Path	RF	Corrected	Spec.	CR/SL	Pass	
Freq.	Pol.		Reading	Factor	Loss	Gain	Reading	limit	Diff.	Fail	
(MHz)	(H/V)	(dB)	(dBuV)	(dB)	(dB)	(dB)	(dBuV/m)	(dBuV/m)	(dB)	Unc.	Comment
434	V	0	57.2	17	2.6	0.0	76.8	80.8	-4.0	Pass	
434	Η	0	52.8	17	2.6	0.0	72.4	80.8	-8.4	Pass	
868	V	0	36.1	23	3.7	27.6	35.2	60.8	-25.6	Pass	
868	Η	0	48.1	23	3.7	27.6	47.2	60.8	-13.6	Pass	
2604.1	Η	0	46.1	28.9	3.5	31.8	46.7	60.8	-14.1	Pass	
3472.1	Н	0	43.3	29.8	4.3	31.7	45.7	60.8	-15.1	Pass	
1736	V	0	45.1	24.8	3.0	31.5	41.4	60.8	-19.4	Pass	

- 1) The spectrum was searched from 30 MHz to 5 GHz.
- 2) The device was tested with a fresh battery.
- 3) The device was tested on three axis'.
- 4) All readings are PEAK unless otherwise stated.

Analyzer Settings: <1000 MHz: RBW=VBW=100 kHz, Peak detector

>1000 MHz: RBW=VBW=1 MHz, Peak detector

Test Equipment: 1763-1484-1485-1304-791-1016-1767

PERIODICALLY OPERATED LOW POWER TRANSMITTERS

EQUIPMENT: MIYSD Wireless Smoke Detector PROJECT NO.: **27180RUS1**

(434.01)

Section 5. Occupied Bandwidth

NAME OF TEST: Occupied Bandwidth PARA. NO.: 15.231(c)

TESTED BY: David Light DATE: 24 March 2009

Minimum Standard: 15.231(c) The bandwidth of the emission shall be no wider

than 0.25% of the center frequency for devices operating above 70 MHz and below 900 MHz. For devices operating above 900 MHz, the emission shall be no wider than 0.5% of the center frequency. Bandwidth is determined at the points

20 dB down from the modulated carrier.


Test Results: Complies. See attached graph.

Test Data: See attached graph.

Test Equipment: 1036-802-1082

Nemko USA, Inc. FCC PART 15, SUBPART C and RSS 210. Issue 7 PERIODICALLY OPERATED LOW POWER TRANSMITTERS EQUIPMENT: MIYSD Wireless Smoke Detector PROJECT NO.: 27180RUS1 (434.01)

Test Data - Occupied Bandwidth



Nemko USA, Inc. FCC PART 15, SUBPART C and RSS 210. Issue 7 PERIODICALLY OPERATED LOW POWER TRANSMITTERS


EQUIPMENT: MIYSD Wireless Smoke Detector

PROJECT NO.: 27180RUS1


(434.01)

Section 6. Block Diagrams

Conducted Emissions




Occupied Bandwidth, Duty Cycle



EQUIPMENT: MIYSD Wireless Smoke Detector

PROJECT NO.: 27180RUS1

(434.01)



Radiated Emissions 30 MHz - 18 GHz

The spectrum was searched up to the 10th harmonic of the fundamental frequency of operation.

Nemko USA, Inc. FCC PART 15, SUBPART C and RSS 210. Issue 7
PERIODICALLY OPERATED LOW POWER TRANSMITTERS
EQUIPMENT: MIYSD Wireless Smoke Detector PROJECT NO.: 27180RUS1

(434.01)

Section 7. Test Equipment List

Nemko ID	Description	Manufacturer Model Number	Serial Number	Calibration Date	Calibration Due
1036	SPECTRUM ANALYZER	ROHDE & SCHWARZ FSEK30	830844/006	01/19/09	01/20/11
1082	CABLE 2m	Astrolab 32027-2-29094-72TC	N/A	CBU	N/A
802	Near Field Probe Set	EMCO 7405	103	N/A	N/A
1763	Bilog Antenna	Schaffner CBL 6111D	22926	11/04/08	11/04/09
1304	HORN ANTENNA	ELECTRO METRICS RGA-60	6151	09/09/08	09/10/10
1016	Pre-Amp	HEWLETT PACKARD 8449A	2749A00159	05/07/08	05/07/09
791	PREAMP, 25dB	Nemko USA, Inc. LNA25	398	05/07/08	05/07/09
1484	Cable	Storm PR90-010-072	N/A	05/07/08	05/07/09
1485	Cable	Storm PR90-010-216	N/A	05/07/08	05/07/09
1767	EMI Test Receiver 20Hz - 26.5 GHz	ROHDE & SCHWARZ ESIB26	837491/0002	09/20/07	09/19/08

PERIODICALLY OPERATED LOW POWER TRANSMITTERS
EQUIPMENT: MIYSD Wireless Smoke Detector PROJECT NO.: **27180RUS1**

(434.01)

ANNEX A - RESTRICTED BANDS

PERIODICALLY OPERATED LOW POWER TRANSMITTERS

EQUIPMENT: MIYSD Wireless Smoke Detector

PROJECT NO.: **27180RUS1**

(434.01)

Annex A Restricted Bands of Operation

(a) Except as shown in paragraph (d) of this section, only spurious emissions are permitted in any of the frequency bands listed below:

MHz	MHz	MHz	GHz
0.090 - 0.110	16.42-16.423	399.9-410	4.5-5.15
0.49 - 0.51	16.69475-16.69525	608-614	5.35-5.46
2.1735 - 2.1905	16.80425-16.80475	960-1240	7.25-7.75
3.020 - 3.026	25.5-25.67	1300-1427	8.025-8.5
4.125 - 4.128	37.5-38.25	1435-1626.6	9.0-9.2
4.17725 - 4.17775	73-74.6	1645.5-1646.5	9.3-9.5
4.20725 - 4.20775	74.8-75.2	1660-1710	10.6-12.7
6.215 - 6.218	108-121.94	1718.8-1722.2	13.25-13.4
6.31175 - 6.31225	123-138	2220-2300	14.47-14.5
8.291 - 8.294	149.9-150.05	2310-2390	15.35-16.2
8.362 - 8.366	156.52475-156.52525	2483.5-2500	17.7-21.4
8.37625 - 8.38675	156.7-156.9	2655-2900	22.01-23.12
8.41425 - 8.41475	162.0125-167.17	3260-3267	23.6-24.0
12.29 - 12.293	167.72-173.2	3332-3339	31.2-31.8
12.51975 - 12.52025	240-285	3345.8-3358	36.43-36.5
12.57675 - 12.57725	322-335.4	3600-4400	Above 38.6
13.36 - 13.41			