## System Check\_Body\_835MHz\_150605

#### **DUT: D835V2-499**

Communication System: CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: MSL\_850\_150605 Medium parameters used: f = 835 MHz;  $\sigma = 0.985$  mho/m;  $\varepsilon_r = 56.5$ ;  $\rho =$ 

Date: 2015/6/5

 $1000 \text{ kg/m}^3$ 

Ambient Temperature: 23.3 °C; Liquid Temperature: 22.3 °C

### DASY4 Configuration:

- Probe: EX3DV4 SN3954; ConvF(10.01, 10.01, 10.01); Calibrated: 2014/11/21
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1279; Calibrated: 2014/7/23
- Phantom: SAM\_Right; Type: SAM; Serial: TP-1303
- ;Postprocessing SW: SEMCAD, V1.8 Build 159

# Pin=250mW/Area Scan (61x61x1): Measurement grid: dx=15mm, dy=15mm

Maximum value of SAR (interpolated) = 3.18 mW/g


## Pin=250mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm

Reference Value = 59.2 V/m; Power Drift = -0.039 dB

Peak SAR (extrapolated) = 3.58 W/kg

SAR(1 g) = 2.36 mW/g; SAR(10 g) = 1.56 mW/g

Maximum value of SAR (measured) = 3.14 mW/g



# System Check\_Body\_1750MHz\_150608

#### **DUT: D1750V2-1068**

Communication System: CW; Frequency: 1750 MHz; Duty Cycle: 1:1

Medium: MSL\_1750\_150608 Medium parameters used: f = 1750 MHz;  $\sigma = 1.459$  S/m;  $\varepsilon_r = 53.937$ ;

 $\rho = 1000 \text{ kg/m}^3$ 

Ambient Temperature: 23.4 °C; Liquid Temperature: 22.4 °C

#### **DASY5** Configuration:

- Probe: EX3DV4 SN3955; ConvF(8.34, 8.34, 8.34); Calibrated: 2014/11/21;
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1399; Calibrated: 2014/11/13
- Phantom: SAM\_Left; Type: QD000P40CD; Serial: TP:1542
- Measurement SW: DASY52, Version 52.8 (8);SEMCAD X Version 14.6.10 (7331)

### Configuration/Pin=250mW/Area Scan (61x61x1): Interpolated grid: dx=1.500 mm,

dy=1.500 mm

Maximum value of SAR (interpolated) = 12.3 W/kg

#### Configuration/Pin=250mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm,


dy=8mm, dz=5mm

Reference Value = 93.16 V/m; Power Drift = 0.03 dB

Peak SAR (extrapolated) = 15.0 W/kg

SAR(1 g) = 9.08 W/kg; SAR(10 g) = 4.99 W/kg

Maximum value of SAR (measured) = 12.5 W/kg



0 dB = 12.5 W/kg = 10.97 dBW/kg

## System Check\_Body\_1900MHz\_150606

#### DUT: D1900V2-5d041

Communication System: CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: MSL\_1900\_150606 Medium parameters used: f=1900 MHz;  $\sigma=1.54$  mho/m;  $\epsilon_r=54.2$ ;  $\rho$ 

 $= 1000 \text{ kg/m}^3$ 

Ambient Temperature: 23.5 °C; Liquid Temperature: 22.5 °C

#### **DASY4** Configuration:

- Probe: EX3DV4 SN3954; ConvF(7.93, 7.93, 7.93); Calibrated: 2014/11/21
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1279; Calibrated: 2014/7/23
- Phantom: SAM\_Right; Type: SAM; Serial: TP-1303
- ;Postprocessing SW: SEMCAD, V1.8 Build 159

# Pin=250mW/Area Scan (61x61x1): Measurement grid: dx=15mm, dy=15mm

Maximum value of SAR (interpolated) = 14.2 mW/g


## Pin=250mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm

Reference Value = 96.3 V/m; Power Drift = 0.083 dB

Peak SAR (extrapolated) = 17.9 W/kg

SAR(1 g) = 10.1 mW/g; SAR(10 g) = 5.25 mW/g

Maximum value of SAR (measured) = 14.4 mW/g



# System Check\_Body\_1900MHz\_150606

#### DUT: D1900V2\_5d041

Communication System: CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: MSL\_1900\_150606 Medium parameters used: f = 1900 MHz;  $\sigma = 1.532 \text{ S/m}$ ;  $\varepsilon_r = 53.993$ ;

 $\rho = 1000 \text{ kg/m}^3$ 

Ambient Temperature : 23.5 °C; Liquid Temperature : 22.5 °C

#### **DASY5** Configuration:

- Probe: EX3DV4 SN3578; ConvF(7.28, 7.28, 7.28); Calibrated: 2015/3/31;
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn916; Calibrated: 2014/12/29
- Phantom: SAM\_Right; Type: QD000P40CC; Serial: TP:1383
- Measurement SW: DASY52, Version 52.8 (8);SEMCAD X Version 14.6.10 (7331)

### Configuration/Pin=250mW/Area Scan (61x61x1): Interpolated grid: dx=1.500 mm,

dy=1.500 mm

Maximum value of SAR (interpolated) = 14.6 W/kg

#### Configuration/Pin=250mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm,


dy=8mm, dz=5mm

Reference Value = 101.9 V/m; Power Drift = -0.00 dB

Peak SAR (extrapolated) = 17.2 W/kg

SAR(1 g) = 9.45 W/kg; SAR(10 g) = 4.88 W/kg

Maximum value of SAR (measured) = 14.7 W/kg



0 dB = 14.7 W/kg = 11.67 dBW/kg