

## **System Check\_Head\_835MHz\_100916**

### **DUT: Dipole 835 MHz**

Communication System: CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: HSL\_850\_100916 Medium parameters used:  $f = 835 \text{ MHz}$ ;  $\sigma = 0.915 \text{ mho/m}$ ;  $\epsilon_r = 41.5$ ;  $\rho = 1000 \text{ kg/m}^3$

Ambient Temperature :  $23.6^\circ\text{C}$ ; Liquid Temperature :  $21.5^\circ\text{C}$

#### **DASY5 Configuration:**

- Probe: EX3DV4 - SN3697; ConvF(8.32, 8.32, 8.32); Calibrated: 11/23/2009
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1210; Calibrated: 2009/11/16
- Phantom: SAM2; Type: SAM; Serial: TP-1479
- Measurement SW : DASY5, V5.2 Build 162; SEMCAD X Version 14.0 Build 57

**Pin=100mW/Area Scan (61x61x1):** Measurement grid:  $dx=15\text{mm}$ ,  $dy=15\text{mm}$

Maximum value of SAR (interpolated) =  $0.994 \text{ mW/g}$



**Pin=100mW/Zoom Scan (7x7x7)/Cube 0:** Measurement grid:  $dx=5\text{mm}$ ,  $dy=5\text{mm}$ ,  $dz=5\text{mm}$

Reference Value =  $33 \text{ V/m}$ ; Power Drift =  $-0.0019 \text{ dB}$

Peak SAR (extrapolated) =  $1.39 \text{ W/kg}$

**SAR(1 g) =  $0.920 \text{ mW/g}$ ; SAR(10 g) =  $0.601 \text{ mW/g}$**

Maximum value of SAR (measured) =  $0.989 \text{ mW/g}$



0 dB = 0.989mW/g

## **System Check\_Body\_835MHz\_100916**

### **DUT: Dipole 835 MHz**

Communication System: CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: MSL\_850\_100916 Medium parameters used:  $f = 835 \text{ MHz}$ ;  $\sigma = 0.969 \text{ mho/m}$ ;  $\epsilon_r = 56.1$ ;  $\rho = 1000 \text{ kg/m}^3$

Ambient Temperature :  $23.5^\circ\text{C}$ ; Liquid Temperature :  $21.4^\circ\text{C}$

#### **DASY5 Configuration:**

- Probe: EX3DV4 - SN3697; ConvF(8.22, 8.22, 8.22); Calibrated: 11/23/2009
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1210; Calibrated: 2009/11/16
- Phantom: SAM1; Type: SAM; Serial: TP-1477
- Measurement SW : DASY5, V5.2 Build 162; SEMCAD X Version 14.0 Build 57

**Pin=100mW/Area Scan (61x61x1):** Measurement grid:  $dx=15\text{mm}$ ,  $dy=15\text{mm}$

Maximum value of SAR (interpolated) =  $1.02 \text{ mW/g}$



**Pin=100mW/Zoom Scan (7x7x7)/Cube 0:** Measurement grid:  $dx=5\text{mm}$ ,  $dy=5\text{mm}$ ,  $dz=5\text{mm}$

Reference Value =  $32.1 \text{ V/m}$ ; Power Drift =  $-0.012 \text{ dB}$

Peak SAR (extrapolated) =  $1.41 \text{ W/kg}$

**SAR(1 g) =  $0.950 \text{ mW/g}$ ; SAR(10 g) =  $0.628 \text{ mW/g}$**

Maximum value of SAR (measured) =  $1.02 \text{ mW/g}$



0 dB = 1.02mW/g

## **System Check\_Head\_1900MHz\_100917**

### **DUT: Dipole 1800 MHz**

Communication System: CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: HSL\_1900\_100917 Medium parameters used:  $f = 1900$  MHz;  $\sigma = 1.41$  mho/m;  $\epsilon_r = 40.5$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Ambient Temperature : 23.7 °C; Liquid Temperature : 21.6 °C

#### **DASY5 Configuration:**

- Probe: EX3DV4 - SN3697; ConvF(7.32, 7.32, 7.32); Calibrated: 11/23/2009
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1210; Calibrated: 2009/11/16
- Phantom: SAM2; Type: SAM; Serial: TP-1479
- Measurement SW : DASY5, V5.2 Build 162; SEMCAD X Version 14.0 Build 57

**Pin=100mW/Area Scan (91x91x1):** Measurement grid: dx=10mm, dy=10mm

Maximum value of SAR (interpolated) = 4.54 mW/g



**Pin=100mW/Zoom Scan (7x7x7)/Cube 0:** Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 56.2 V/m; Power Drift = 0.00120 dB

Peak SAR (extrapolated) = 7.53 W/kg

**SAR(1 g) = 4 mW/g; SAR(10 g) = 2.08 mW/g**

Maximum value of SAR (measured) = 4.5 mW/g



0 dB = 4.5mW/g

**System Check\_Body\_1900MHz\_100917**

**DUT: Dipole 1900 MHz**

Communication System: CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: MSL\_1900\_100917 Medium parameters used:  $f = 1900 \text{ MHz}$ ;  $\sigma = 1.52 \text{ mho/m}$ ;  $\epsilon_r = 54.5$ ;  $\rho = 1000 \text{ kg/m}^3$

Ambient Temperature :  $23.7^\circ\text{C}$ ; Liquid Temperature :  $21.5^\circ\text{C}$

**DASY5 Configuration:**

- Probe: EX3DV4 - SN3697; ConvF(7.04, 7.04, 7.04); Calibrated: 11/23/2009
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1210; Calibrated: 2009/11/16
- Phantom: SAM1; Type: SAM; Serial: TP-1477
- Measurement SW : DASY5, V5.2 Build 162; SEMCAD X Version 14.0 Build 57

**Pin=100mW/Area Scan (61x61x1):** Measurement grid:  $dx=15\text{mm}$ ,  $dy=15\text{mm}$

Maximum value of SAR (interpolated) =  $4.61 \text{ mW/g}$



**Pin=100mW/Zoom Scan (7x7x7)/Cube 0:** Measurement grid:  $dx=5\text{mm}$ ,  $dy=5\text{mm}$ ,  $dz=5\text{mm}$

Reference Value =  $54.5 \text{ V/m}$ ; Power Drift =  $-0.0035 \text{ dB}$

Peak SAR (extrapolated) =  $7.61 \text{ W/kg}$

**SAR(1 g) =  $4.05 \text{ mW/g}$ ; SAR(10 g) =  $2.08 \text{ mW/g}$**

Maximum value of SAR (measured) =  $4.6 \text{ mW/g}$



0 dB = 4.6mW/g