Material:

Base Material: 3502-17 749 2.6 MIL White BOPP TC S90 40# Lamination: 3001-26 10442 1 MIL Clear Compucal EXC MTC722

Color: Light Gray coated background



Wireless Carbon Monoxide Alarm with Supplemental Temperature Sensing

Activate: Slide switch as shown by white arrow until it locks into place.

Activate: Since switch as snown by white arrow until it locks into place.

Deactivate: Press and hold a pin into hole ♠, slide switch in direction of black arrow until it locks into place • For more info see owner's manual, 90-4075-00

• CO alarm sounds with 4-pulse pattern, Fire alarm sounds with a 3-pulse pattern
• ♠ or ♠ will flash red twice/min for three days to show prior alarm activation
• Temperature Rating: Fixed Temp. 135°F (57°C), Rate of Rise > 20°F/min (11°C)
• Constant exposure to high and low temps or high humidity may reduce battery life

• Silence button will silence alarm for up to 5 min • Test weekly - Press front button
• Alarm is sealed with no serviceable parts, and all maintenance and testing specified must be performed. Once deactivated, it cannot be reactivated and must be replaced • Clean alarm by vacuuming exterior • Low Battery: A Flashes red with two chirps per minute
• End-of-Life: A Double flashes red with two chirps per minute

CO Sensitivity (Sensibilité): 70PPM at 60-70 min, 150PPM at 10-15 min 400PPM at 4-8 min

ISSUE NO. SI XX,XXX c(UL)us

> SINGLE AND/OR MULTIPLE STATION SMOKE ALARM

S24815 LISTED

MARNING Carbon Monoxide cannot be seen or smelled but can kill you. If alarm signal sounds with 4 rapid beeps:

1) Press and release the Silence Button

2) Call your emergency services (fire department or 911)

3) Immediately move to fresh air - outdoors or by an open door/window

Date of Installation: Remplacer par:

IC: 9299A-NX15
FCC ID: YST-NX15
This device complies with part 15 of the
FCC rules. Operation is subject to the
following two conditions: 1) This device
may not cause harmful interference. 2)
This device must accept any interference received including interference
that may cause undesired operation.

AVERTISSEMENT Le monoxyde de carbone peut pas être vu ou senti, mais peut vous tuer.

· CO alarme retentit avec un motif de 4 tons, Fire alarme retentit

avec un motif de 3 tons • Low Battery : Δ Flashes red with two chirps per minute

• End-of-Life: Double flashes red with two chirps per minute

Pour plus d'informations, lire manuel du propriétaire, 90-4075-00
 Fin-de-Vie: Clignote en rouge avec deux bips/min

Made in USA

Model: EX20 CO MFG Date: Mar. 23, 2013

MFG Date: Mar. 23, 2013 Serial No.: XXXXXXXX Serial No.: XXXXXXXX 3.0 VDC 3.0 VDC

Model: EX20C CO

Exigent Sensors LLC 11331 Markon Drive Garden Grove, CA 92841 crossfirealarms.com