Test Laboratory: Sporton International Inc. SAR/HAC Testing Lab Date: 2011/6/20

System Check_Body_835MHz_110620

DUT: Dipole 835 MHz

Communication System: CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: MSL_850_110620 Medium parameters used: f = 835 MHz; $\sigma = 0.963$ mho/m; $\varepsilon_r = 54.5$; $\rho = 1000$

 kg/m^3


Ambient Temperature: 22.4; Liquid Temperature: 21.4

DASY5 Configuration:

- Probe: ET3DV6 SN1787; ConvF(6.35, 6.35, 6.35); Calibrated: 2011/5/20
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1249; Calibrated: 2011/2/21
- Phantom: ELI 4.0; Type: QDOVA001BA; Serial: 1029
- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

Pin=250mW/Area Scan (61x61x1): Measurement grid: dx=15mm, dy=15mm Maximum value of SAR (interpolated) = 2.56 mW/g

Pin=250mW/Zoom Scan (7x7x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm, dz=5mm Reference Value = 54 V/m; Power Drift = -0.024 dB Peak SAR (extrapolated) = 3.27 W/kg SAR(1 g) = 2.37 mW/g; SAR(10 g) = 1.58 mW/g Maximum value of SAR (measured) = 2.57 mW/g



Test Laboratory: Sporton International Inc. SAR/HAC Testing Lab Date: 2011/6/21

System Check_Body_835MHz_110621

DUT: Dipole 835 MHz

Communication System: CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: MSL_850_110621 Medium parameters used: f = 835 MHz; $\sigma = 0.996$ mho/m; $\varepsilon_r = 55.4$; $\rho = 1000$

 kg/m^3


Ambient Temperature: 22.3 ; Liquid Temperature: 21.3

DASY5 Configuration:

- Probe: EX3DV4 SN3697; ConvF(8.65, 8.65, 8.65); Calibrated: 2010/11/23
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1249; Calibrated: 2011/2/21
- Phantom: ELI 4.0; Type: QDOVA001BA; Serial: 1029
- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

Pin=250mW/Area Scan (61x61x1): Measurement grid: dx=15mm, dy=15mm Maximum value of SAR (interpolated) = 2.88 mW/g

Pin=250mW/Zoom Scan (7x7x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm, dz=5mm Reference Value = 54.3 V/m; Power Drift = -0.190 dB Peak SAR (extrapolated) = 3.94 W/kg SAR(1 g) = 2.57 mW/g; SAR(10 g) = 1.66 mW/g Maximum value of SAR (measured) = 2.77 mW/g



Test Laboratory: Sporton International Inc. SAR/HAC Testing Lab Date: 2011/6/20

System Check_Body_1900MHz_110620

DUT: Dipole 1900 MHz

Communication System: CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: MSL_1900_110620 Medium parameters used: f = 1900 MHz; $\sigma = 1.43$ mho/m; $\varepsilon_r = 39.2$; $\rho = 1000$

 kg/m^3


Ambient Temperature: 22.5; Liquid Temperature: 21.5

DASY5 Configuration:

- Probe: ET3DV6 SN1787; ConvF(5.03, 5.03, 5.03); Calibrated: 2011/5/20
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1249; Calibrated: 2011/2/21
- Phantom: ELI 4.0; Type: QDOVA001BA; Serial: 1029
- Measurement SW: DASY5, V5.0 Build 125; SEMCAD X Version 13.4 Build 125

Pin=250mW/Area Scan (61x61x1): Measurement grid: dx=15mm, dy=15mm Maximum value of SAR (interpolated) = 11.6 mW/g

Pin=250mW/Zoom Scan (7x7x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm, dz=5mm Reference Value = 89.3 V/m; Power Drift = 0.027 dB Peak SAR (extrapolated) = 17.6 W/kg SAR(1 g) = 9.74 mW/g; SAR(10 g) = 5.1 mW/g Maximum value of SAR (measured) = 11 mW/g



System Check_Body_1900MHz_110622

DUT: Dipole 1900 MHz

Communication System: CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: MSL 1900 110622 Medium parameters used: f = 1900 MHz; $\sigma = 1.52$ mho/m; $\varepsilon_r = 54.6$; ρ

Date: 2011/6/22

 $= 1000 \text{ kg/m}^3$

Ambient Temperature: 22.4 °C; Liquid Temperature: 21.4 °C

DASY4 Configuration:

- Probe: EX3DV4 SN3731; ConvF(7.13, 7.13, 7.13); Calibrated: 2010/9/20
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn778; Calibrated: 2010/10/22
- Phantom: ELI 4.0 Front; Type: QDOVA001BB; Serial: 1026
- Measurement SW: DASY4, V4.7 Build 80; Postprocessing SW: SEMCAD, V1.8 Build 186

Pin=250mW/Area Scan (61x61x1): Measurement grid: dx=15mm, dy=15mm Maximum value of SAR (interpolated) = 11.1 mW/g

Pin=250mW/Zoom Scan (7x7x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm, dz=5mm Reference Value = 84.1 V/m; Power Drift = -0.050 dB Peak SAR (extrapolated) = 18.3 W/kg

SAR(1 g) = 9.41 mW/g; SAR(10 g) = 4.72 mW/gMaximum value of SAR (measured) = 10.6 mW/g

