GRIDINTEL · UTILITY INTELLIGENCE

DisCo operations

ATC&C and its parts, revenue not realised, collection by customer class, reliability and hours of supply, assets requiring attention, outages and alarms.

SAMPLE: SYNTHETIC DATA

This report is a sample. It shows the format and the methods GridIntel would deliver; it is not a report of real results. Every figure in it is calculated from a designed demonstration dataset, and none describes a real network, site, customer or organization.

A designed demonstration dataset for September 2026. It describes no real network, customer, meter reading, outage, bill or payment.

FOR
DisCo management

RECORDS OF
Savanna Electricity Distribution (synthetic)

PERIOD
September 2026

REPORT ID
GI-OPS-2026-09-C2E8D496

FIGURES COMPUTED
20 Oct 2026, 10:10 WAT, from data as of 1 Oct 2026, 00:00 WAT

DEFINITION
Version 1

DATA FINGERPRINT (SHA-256)
`20965f6061d19d5ee0a4dd5e411cf247203eca3fe47d529bb35a6529e215924e`

IN BRIEF

ATC&C
31.4% ≈ C
Estimated inputs · Calculated · gridintel.atcc.reference 0.1.0

REVENUE NOT REALISED
₦46,304,966 ≈ D
Estimated inputs · Derived · gridintel.revenue_gap.reference 0.1.0
Estimate. Monthly figure for the reporting period; not annualised.

COLLECTION EFFICIENCY
83.8% • C
OK · Calculated · gridintel.atcc.reference 0.1.0
Cash basis: received in the period ÷ billed in the period.

SAIDI
241.0 h • C
OK · Calculated · gridintel.reliability.reference 0.3.0
Provisional: includes 1 open outage(s); duration counted to period end.

SAIFI
46.7 • C
OK · Calculated · gridintel.reliability.reference 0.3.0
Provisional: includes 1 open outage(s); duration counted to period end.

Provisional: includes 1 open outage(s); duration counted to period end.

1 interruption(s) were still in progress at the end of the period; see section 6.

CONTENTS

1. Losses: ATC&C and its parts
2. Revenue not realised
3. Billing and collection by customer class
4. Reliability and hours of supply
5. Assets requiring attention
6. Outages and alarms at the end of the period

7. Method, sources and how to reproduce this report
8. Regulatory references
9. Glossary and key

1 Losses: ATC&C and its parts

How much of the energy the DisCo received was not turned into money, and in which part of the chain it was lost.

ATC&C
31.4% ≈ C
Estimated inputs · Calculated · gridintel.atcc.reference 0.1.0

TECHNICAL LOSS
9.3% ≈ E
Estimated inputs · Estimated · gridintel.atcc.reference 0.1.0
Estimated: from a loss study, not metered.

COMMERCIAL LOSS
8.9% ≈ D
Estimated inputs · Derived · gridintel.atcc.reference 0.1.0
Derived residual; inherits the technical-loss estimate.

COLLECTION LOSS
13.2% ≈ C
Estimated inputs · Calculated · gridintel.atcc.reference 0.1.0

BILLING EFFICIENCY
81.8% ≈ C
Estimated inputs · Calculated · gridintel.atcc.reference 0.1.0

COLLECTION EFFICIENCY
83.8% • C
OK · Calculated · gridintel.atcc.reference 0.1.0
Cash basis: received in the period ÷ billed in the period.

The energy account

From energy received at the DisCo's boundary to energy billed, top to bottom. Each line keeps its own origin: a technical loss from a loss study is an estimate, unbilled energy a residual.

	ENERGY
Energy received sum of energy received over 2 section(s)	2,104,819 kWh • M
Technical loss sum of technical loss over 2 section(s)	196,615 kWh ≈ E
Energy delivered sum of energy delivered over 2 section(s)	1,908,204 kWh ≈ C
Energy billed Sum of the energy on charges raised in the period (meter readings, prepaid vends and estimated bills).	1,720,953 kWh ≈ E
Unbilled energy sum of unbilled energy over 2 section(s)	187,251 kWh ≈ D

Method: GridIntel reference energy accounting (gridintel.energy.reference 0.2.0).

Losses by feeder

Each feeder's losses as shares of the energy it received. The parts add up to its ATC&C.

	ATC&C	TECHNICAL	COMMERCIAL	COLLECTION	BILLING EFFICIENCY
Market Road 11 kV feeder Band A	18.5% ≈ C	6.5% ≈ E	5.7% ≈ D	6.4% ≈ C	87.9% ≈ C
Old Town 11 kV feeder Band C	62.8% ≈ C	11.9% ≈ E	27.9% ≈ D	23.1% ≈ C	60.3% ≈ C
Farm Road 11 kV feeder Band D	70.8% ≈ C	15.2% ≈ E	18.4% ≈ D	37.2% ≈ C	66.4% ≈ C
Government Avenue 11 kV feeder Band B	36.9% ≈ C	7.7% ≈ E	2.3% ≈ D	26.9% ≈ C	90.1% ≈ C

Method: GridIntel reference ATC&C (gridintel.atcc.reference 0.1.0).

The DisCo's reported loss and collection figures

The report's methodology ("Utility internal reporting (synthetic)") has not been verified as equivalent to the GridIntel reference methods the calculations use. This applies to every figure below.

ATC&C · Hillcrest 33/11 kV injection substation

Reported	33.0% • R	fraction of energy input net of transfers out; collection on a cash basis
Calculated	40.1% ≈ C	fraction of energy input net of transfers out; collection on a cash basis

Same basis. Calculated less reported: +7.08 percentage points. The calculated value's quality is estimated.

From: Monthly operations report, September 2026 (synthetic)

Collection efficiency · Hillcrest 33/11 kV injection substation

Reported	74.0% • R	collection on a cash basis
Calculated	68.8% • C	collection on a cash basis

Same basis. Calculated less reported: -5.16 percentage points.

From: Monthly operations report, September 2026 (synthetic)

ATC&C · Riverside 33/11 kV injection substation

Reported	27.0% • R	fraction of energy input net of transfers out; collection on a cash basis
Calculated	31.0% ≈ C	fraction of energy input net of transfers out; collection on a cash basis

Same basis. Calculated less reported: +3.96 percentage points. The calculated value's quality is estimated.

From: Monthly operations report, September 2026 (synthetic)

Collection efficiency · Riverside 33/11 kV injection substation

Reported	91.0% • R	collection on a cash basis
Calculated	89.9% • C	collection on a cash basis

Same basis. Calculated less reported: -1.08 percentage points.

From: Monthly operations report, September 2026 (synthetic)

2 Revenue not realised

What the commercial and the collection losses are worth, in money, and on which feeders.

COMMERCIAL GAP

₦15,554,796 ≈ D

Estimated inputs · Derived · gridintel.revenue_gap.reference 0.1.0

Derived from unbilled energy, which is a residual; inherits the technical-loss estimate.

COLLECTION GAP

₦30,750,171 • C

OK · Calculated · gridintel.revenue_gap.reference 0.1.0

Cash basis.

REVENUE NOT REALISED

₦46,304,966 ≈ D

Estimated inputs · Derived · gridintel.revenue_gap.reference 0.1.0

Estimate. Monthly figure for the reporting period; not annualised.

> **What the figure is.** An estimate of revenue not realised in the period. The commercial part values unbilled energy at the average rate actually billed to low-voltage, non-maximum-demand customers where the loss occurs; unbilled energy is a residual that depends on a technical-loss study. It is not an amount owed by anyone, and it does not say why the energy went unbilled. For the reporting period only. Not annualised.

> Tariffs are assumptions, not current published rates.

> 19 account(s) with unknown demand class excluded from the rate. They are not assumed to be non-MD.

By feeder

Each feeder's commercial and collection gap. A negative part is shown as it is and not netted.

	COMMERCIAL GAP	COLLECTION GAP	NOT REALISED
Market Road 11 kV feeder	₦7,931,823 ≈ D	₦9,019,028 • C	₦16,950,851 ≈ D
Old Town 11 kV feeder	₦5,586,115 ≈ D	₦4,632,027 • C	₦10,218,143 ≈ D

	COMMERCIAL GAP	COLLECTION GAP	NOT REALISED
Farm Road 11 kV feeder	₦722,824 ≈ D	₦1,459,545 • C	₦2,182,369 ≈ D
Government Avenue 11 kV feeder	₦1,314,034 ≈ D	₦15,639,570 • C	₦16,953,603 ≈ D

Method: GridIntel reference revenue gap (gridintel.revenue_gap.reference 0.1.0).

3 Billing and collection by customer class

Who was billed, who paid, and who left the most uncollected.

REVENUE BILLED
₦190,319,632 • M
OK · Measured

REVENUE COLLECTED
₦159,569,461 • M
OK · Measured

COLLECTION EFFICIENCY
83.8% • C
OK · Calculated · gridintel.atcc.reference 0.1.0
Cash basis: received in the period ÷ billed in the period.

By customer class

Cash basis: money received in the period against bills issued in the period. Largest shortfall first.

	ACCOUNTS	BILLED	COLLECTED	NOT COLLECTED	COLLECTION EFFICIENCY
Government (MDA)	90 • C	₦17,244,187 • C	₦3,414,797 • C	₦13,829,391 • C	19.8% • C
Residential	5,936 • C	₦119,656,493 • C	₦106,467,746 • C	₦13,188,747 • C	89.0% • C
Commercial	421 • C	₦40,380,252 • C	₦37,560,928 • C	₦2,819,324 • C	93.0% • C
Industrial	1 • C	₦13,038,699 • C	₦12,125,990 • C	₦912,709 • C	93.0% • C

Method: GridIntel reference ATC&C (gridintel.atcc.reference 0.1.0).

4 Reliability and hours of supply

How often, and for how long, customers were without supply, and whether each feeder gave the hours its band commits to.

SAIDI
241.0 h • C
OK · Calculated · gridintel.reliability.reference 0.3.0
Provisional: includes 1 open outage(s); duration counted to period end.

SAIFI
46.7 • C
OK · Calculated · gridintel.reliability.reference 0.3.0
Provisional: includes 1 open outage(s); duration counted to period end.

CAIDI
5.2 h • C
OK · Calculated · gridintel.reliability.reference 0.3.0
Provisional: includes 1 open outage(s); duration counted to period end.

SAIDI ATTRIBUTED TO THE DISTRIBUTION NETWORK
14.0 h • C
OK · Calculated · gridintel.reliability.reference 0.3.0
Provisional: includes 1 open outage(s); duration counted to period end.

> Provisional: includes 1 open outage(s); duration counted to period end.

Hours of supply against the band, by feeder

Each day is tested against the band minimum on its own; the average over the period is shown beside it.

	BAND	BAND MINIMUM	AVERAGE SUPPLIED	DAYS MET	DAYS BELOW
Market Road 11 kV feeder	Band A	20.0 h/day • C	21.5 h/day • C	23 • C	7 • C
Old Town 11 kV feeder	Band C	12.0 h/day • C	13.8 h/day • C	28 • C	2 • C
Farm Road 11 kV feeder	Band D	8.0 h/day • C	9.2 h/day • C	20 • C	10 • C
Government Avenue 11 kV feeder	Band B	16.0 h/day • C	17.7 h/day • C	23 • C	7 • C

Method: GridIntel reference hours of supply (gridintel.supply_hours.reference 0.2.0).

> The indices by substation and feeder, where interruptions began and the DisCo's reported reliability figures are in the Reliability and service standards report for the same period.

5 Assets requiring attention

Which assets had a source alarm, a derived condition or an interruption on them, each fact with its own origin.

> **Why an asset is listed.** An asset is listed when a source alarm is standing on it or on its monitor at the as-of time, or GridIntel derived a condition for it or its monitor in the period, or one or more interruptions attributed to the distribution network began at it in the period. Order: most standing alarms first; then conditions that hold at the as-of time; then most readings above rating; then most interruptions begun; then by id. It is an ordering of facts, not a score.

The assets

In the order the rule gives. Loading is apparent power against rating, from telemetry; alarms are as source systems recorded them; conditions are GridIntel's, by rule.

	CLASS	PEAK LOADING	READINGS ABOVE RATING	SOURCE ALARMS STANDING	DERIVED CONDITIONS	INTERRUPTIONS THAT BEGAN HERE
South Gate transformer Riverside 33/11 kV injection substation · Old Town 11 kV feeder	Distribution transformer	78.1% • C	0 • C	medium: Communications failure: remote unit SYN-DTM-OLD3 (transformer monitor) has not answered 2 consecutive polls. (on its monitor)	Monitor quiet, holding at the end of the period; a source alarm agrees	1 • C
Farm Road 11 kV feeder Hillcrest 33/11 kV injection substation	11 kV feeder	53.8% • C	0 • C	high: 11 kV feeder breaker tripped on earth fault and locked out.	None	1 • C
Riverside T1 Riverside 33/11 kV injection substation	Power transformer	72.2% • C	0 • C	medium: Power transformer top-oil temperature above its alarm setting.	None	0 • C
Riverbank transformer Riverside 33/11 kV injection substation · Old Town 11 kV feeder	Distribution transformer	121.2% • C	69 • C	None	Loaded above rating; no source alarm raised	1 • C
Government Avenue transformer 3 Hillcrest 33/11 kV injection substation · Government Avenue 11 kV feeder	Distribution transformer	110.6% • C	53 • C	None	Loaded above rating; no source alarm raised	0 • C
Farm Road transformer 3 Hillcrest 33/11 kV injection substation · Farm Road 11 kV feeder	Distribution transformer	62.7% • C	0 • C	None	None	1 • C
Government Avenue transformer 4 Hillcrest 33/11 kV injection substation · Government Avenue 11 kV feeder	Distribution transformer	67.6% • C	0 • C	None	None	1 • C
Garden Estate transformer Riverside 33/11 kV injection substation · Market Road 11 kV feeder	Distribution transformer	91.8% • C	0 • C	None	None	1 • C
Government Avenue 11 kV feeder Hillcrest 33/11 kV injection substation	11 kV feeder	72.3% • C	0 • C	None	None	1 • C

	CLASS	PEAK LOADING	READINGS ABOVE RATING	SOURCE ALARMS STANDING	DERIVED CONDITIONS	INTERRUPTIONS THAT BEGAN HERE
Old Town 11 kV feeder Riverside 33/11 kV injection substation	11 kV feeder	80.9% • C	0 • C	None	None	1 • C

Method: GridIntel reference equipment loading (gridintel.loading.reference 0.1.0).

1 standing source alarm(s) name no single asset of these classes (for example a substation as a whole); they are in section 6.

Maintenance records: Not available. No source supplies work orders, inspections or repairs, so none is shown and no asset is called maintained or overdue.

Age and condition: Not available. The registry holds no commissioning date, test result or condition assessment for transformers or feeders, so no asset is ranked by age or health.

6 Outages and alarms at the end of the period

What was wrong when the period closed: interruptions still in progress, alarms standing, and conditions holding.

Interruptions in progress

Outages whose customers, or some of them, had not got supply back at the end of the period, largest first.

	CAUSE	INTERRUPTED	RESTORED	STILL OFF	CUSTOMERS STILL OFF
Farm Road 11 kV feeder Hillcrest 33/11 kV injection substation · Farm Road 11 kV feeder	Fault	30 Sep 2026, 23:20 WAT	*No restoration recorded*	10 transformers	1,015 • C

Restoration not recorded

Outages with no restoration time whose source does not say they are open: a gap in the record, not a finding that supply is still off.

	CAUSE	INTERRUPTED	RESTORED	STILL OFF	CUSTOMERS STILL OFF
SP-MKT2-001 Riverside 33/11 kV injection substation · Market Road 11 kV feeder	Cause not known	21 Sep 2026, 09:15 WAT	*No restoration recorded*	1 service point	1 • M

Source alarms standing

As source systems recorded them, most severe first. Accounts behind an alarm are those connected there, not a count of customers without supply.

	SEVERITY	ALARM	RAISED	ACKNOWLEDGED	ACCOUNTS BEHIND IT
Farm Road 11 kV feeder Feeder	high	11 kV feeder breaker tripped on earth fault and locked out. (FDR-EF-TRIP)	30 Sep 2026, 23:20 WAT	30 Sep 2026, 23:24 WAT	1,015 • C
Hillcrest 33/11 kV injection substation Substation	high	110 V DC supply low: battery charger failure. Protection will run on the battery alone. (DC-SUPPLY-LOW)	30 Sep 2026, 21:40 WAT	*Not acknowledged*	2,781 • C
Monitor on South Gate transformer Monitoring device	medium	Communications failure: remote unit SYN-DTM-OLD3 (transformer monitor) has not answered 2 consecutive polls. (RTU-COMMS-FAIL)	30 Sep 2026, 16:55 WAT	30 Sep 2026, 17:20 WAT	42 • C
Riverside T1 Power transformer	medium	Power transformer top-oil temperature above its alarm setting. (PT-OIL-TEMP-HIGH)	26 Sep 2026, 20:05 WAT	26 Sep 2026, 20:12 WAT	3,543 • C

1 alarm(s) have no recorded raise time, so whether they were standing cannot be told.

27 alarm(s) raised were cleared by the end of the period.

Derived conditions

Found by GridIntel from telemetry under fixed rules, for the period. They are calculated, and are not alarms from any source system.

	RULE	FIGURE	AT THE END OF THE PERIOD	SOURCE ALARM
Monitor on South Gate transformer Monitoring device	Monitor quiet	9.1 h • C	Holding	A source alarm agrees
Riverbank transformer Transformer	Loaded above rating	121.2% • C	Not holding	No source alarm raised
Government Avenue transformer 3 Transformer	Loaded above rating	110.6% • C	Not holding	No source alarm raised

Method: GridIntel reference derived conditions (gridintel.conditions.reference 0.3.0); GridIntel reference equipment loading (gridintel.loading.reference 0.1.0).

Loaded above rating: Loading (apparent power ÷ rated capacity, or highest phase current ÷ rated current) was above 100% of rating at one or more telemetry readings in the period.

Monitor quiet: The device's last check-in is more than 120 minutes before the as-of time, or no check-in from it is held in the 24 hours before it. Applied only where the record of check-ins is complete over those hours.

7 Method, sources and how to reproduce this report

Where every figure came from, and how a reader can check that this document is the one the records give.

Methodologies

METHODOLOGY	VERSION	WHAT IT SAYS OF ITSELF
GridIntel reference ATC&C `gridintel.atcc.reference`	`0.1.0`	GridIntel reference calculation — not a regulatory figure.
GridIntel reference derived conditions `gridintel.conditions.reference`	`0.3.0`	GridIntel derived condition, calculated from telemetry. It is not an alarm recorded by a source system.
GridIntel reference energy accounting `gridintel.energy.reference`	`0.2.0`	GridIntel reference calculation — not a regulatory figure.
GridIntel reference equipment loading `gridintel.loading.reference`	`0.1.0`	GridIntel reference calculation — not a regulatory figure.
GridIntel reference reliability indices `gridintel.reliability.reference`	`0.3.0`	GridIntel reference calculation — not a regulatory figure.
GridIntel reference revenue gap `gridintel.revenue_gap.reference`	`0.1.0`	GridIntel reference calculation — not a regulatory figure. An estimate of revenue not realised in the period; not an amount owed, and not annualised.
GridIntel reference hours of supply `gridintel.supply_hours.reference`	`0.2.0`	GridIntel reference calculation — not a regulatory figure. Band minimums are NERC Service-Based Tariff definitions.

Sources

- Synthetic alarm list (synthetic)
- Synthetic billing and vending (synthetic)
- Synthetic meter data (synthetic)
- Synthetic outage log (synthetic)
- Synthetic asset registry (synthetic)
- Synthetic utility reports (synthetic)
- Synthetic telemetry (synthetic)

> Every source above is synthetic: designed demonstration data, not records of a real organization.

How to reproduce it

1. Build the report with definition version 1, for September 2026, from the Savanna Electricity Distribution (synthetic) records.
2. The data fingerprint must be `20965f6061d19d5ee0a4dd5e411cf247203eca3fe47d529bb35a6529e215924e`. SHA-256 over the sorted SHA-256 digests of every distinct result the report's services were given by the repositories, each written as JSON with its keys in order.
3. With the same definition, methodologies and fingerprint the report ID is the same: GI-OPS-2026-09-C2E8D496. A different ID means something above differs.
4. The figures with their status, origin, unit and method are in the CSV of the same report ID: gridintel-operations-2026-09-SAMPLE-SYNTHETIC.csv.

8 Regulatory references

How far this report carries the fields of the instruments below, as read from the instruments themselves. It is not a claim that the report conforms to any regulator's or programme's template: none has been checked against the template it would be filed on.

INSTRUMENT	REQUIREMENT	THIS REPORT
NERC Reporting Compliance Regulations 2009 (NERC-R-02-09), s. 9 and Schedule 4A	7–8. Distribution losses; technical losses: energy delivered to the DisCo, energy billed, physical losses; monthly	**PARTLY** Section 1 gives the energy account and ATC&C with its parts, by DisCo and feeder, for a month. The technical loss is an estimate from a loss study, not metered, and is labelled as one.
NERC Reporting Compliance Regulations 2009 (NERC-R-02-09), s. 9 and Schedule 4A	15–16. Billing efficiency; collection efficiency: energy billed and received, revenue billed and collected; monthly	**CARRIED** Sections 1 and 3, for a month. Collection is on a cash basis: money received in the period against bills issued in it.
NERC Reporting Compliance Regulations 2009 (NERC-R-02-09), s. 9 and Schedule 4A	1–3. SAIDI, SAIFI, CAIDI; monthly	**PARTLY** Section 4 gives the DisCo's indices in brief; by substation and feeder they are in the Reliability and service standards report.
NERC Reporting Compliance Regulations 2009 (NERC-R-02-09), s. 9 and Schedule 4A	12–14, 17–20. Staff cost, productivity, unit cost, naira per kWh, outstanding debt, capacity costs	**NOT CARRIED** Not held: GridIntel holds no financial accounts of the DisCo.
NERC Reporting Compliance Regulations 2009 (NERC-R-02-09), s. 9 and Schedule 4A	s. 9. Monthly customer complaints report and register	**NOT CARRIED** Not held: GridIntel holds no complaints records.

9 Glossary and key

ATC&C — Aggregate technical, commercial and collection loss: the share of energy received that was not paid for. Technical + commercial + collection loss.

Technical loss — Energy lost in the network itself. Here an estimate from a loss study, not a measurement.

Commercial loss — Energy delivered but not billed: a residual, delivered less billed, which carries the uncertainty of the technical-loss estimate.

Collection loss — The share of energy billed whose bills were not paid in the period.

Billing efficiency — Energy billed ÷ energy received.

Collection efficiency — Revenue collected in the period ÷ revenue billed in the period, on a cash basis.

Revenue not realised — An estimate of revenue lost to commercial and collection loss in the period, each valued at the rate where it occurs. Not annualised.

Not available for a day — A loss account and collection efficiency need energy, billing and collection over one span; a single day does not give one, so they are given for a month only.

SAIDI — System Average Interruption Duration Index: the hours of interruption the average customer served had in the period. Customer-hours interrupted ÷ customers served.

SAIFI — System Average Interruption Frequency Index: the interruptions the average customer served had in the period. Customer interruptions ÷ customers served.

CAIDI — Customer Average Interruption Duration Index: the average length of an interruption, in hours. SAIDI ÷ SAIFI.

Network-attributable — The part of an index caused by interruptions that began on the distribution network (33 kV and 11 kV lines, distribution transformers, the low-voltage network), under the reference methodology.

Service band — NERC's Service-Based Tariff band of a feeder, with its minimum average hours of supply a day: A 20, B 16, C 12, D 8, E 4.

Provisional — A figure that includes an interruption still open at the end of the period, counted to its end. It is calculated, not estimated, and is final only when the restoration is recorded.

Source alarm — An alarm as a source system (SCADA, a relay, a monitor) recorded it. Observed; GridIntel does not decide whether it is true.

Derived condition — Something GridIntel worked out from telemetry under a fixed rule (loaded above rating, monitor quiet). Calculated; never shown as an alarm.

Accounts behind	Active customer accounts connected behind an asset, from the registry. It says who is connected there, not who is without supply.
Restoration not recorded	An outage with no restoration time whose source does not say it is open: a gap in the record, not a finding that supply is still off.
Measured	Read from a meter, a device or a source record.
Reported	A figure published by someone else, shown as they stated it. It is never altered.
Calculated	Computed by GridIntel from records, under a named and versioned methodology.
Estimated	An estimate, not a measurement; the method is named with it.
Derived	A residual: what is left when other figures are subtracted. It carries their uncertainty.
Insufficient data	An input the figure needs is missing. No value is given rather than a guess, and never a zero.
Not available	No source holds this figure, or the data does not cover the period.
Same basis	A reported figure and a calculation count the same things over the same period by the same rule. Only figures on the same basis are compared.
Data fingerprint	A SHA-256 digest of every record the report was built from. The same records give the same fingerprint; any change to them gives another.
Report ID	The report's code, its period and the first characters of a digest of its definition, methodologies and data fingerprint. The same report of the same data has the same ID.

The marks beside a figure

• **OK**	Every input is present and measured.
≈ **Estimated inputs**	Calculated; every input is present, but at least one was estimated rather than measured.
! **Insufficient data**	An input this figure needs is missing. No value is shown rather than a guess.
∅ **Not computable**	The inputs exist but the calculation is undefined for them.
– **Not available**	The platform has no source for this figure.
M **Measured**	Read from a meter, device or source record.
R **Reported**	Published by someone else; shown as stated.
C **Calculated**	Computed by GridIntel under a named methodology.
E **Estimated**	An estimate, not a measurement.
D **Derived**	A residual: what is left after subtracting other figures. It inherits their uncertainty.

SAMPLE: SYNTHETIC DATA. End of report GI-OPS-2026-09-C2E8D496.