GRIDINTEL · UTILITY INTELLIGENCE

Reliability and service standards

SAIDI, SAIFI and CAIDI by feeder and substation, attribution by where interruptions began, service-band compliance by day, and the DisCo's reported figures against the calculation on their basis.

SAMPLE: SYNTHETIC DATA

This report is a sample. It shows the format and the methods GridIntel would deliver; it is not a report of real results. Every figure in it is calculated from a designed demonstration dataset, and none describes a real network, site, customer or organization.

A designed demonstration dataset for September 2026. It describes no real network, customer, meter reading, outage, bill or payment.

FOR
Regulator; the DisCo's network planning

RECORDS OF
Savanna Electricity Distribution (synthetic)

PERIOD
September 2026

REPORT ID
GI-REL-2026-09-10DCE6F2

GENERATED
15 Oct 2026, 14:06 WAT

DATA AS OF
1 Oct 2026, 00:00 WAT

DEFINITION
Version 1

DATA FINGERPRINT (SHA-256)
53b8256333afd69bcfe34e4bc6e72ffc536e2cfb4cc28ef830b97c47981163d5

IN BRIEF

SAIDI
241.0 h • C
OK · Calculated · gridintel.reliability.reference 0.3.0
Provisional: includes 1 open outage(s); duration counted to period end.

SAIFI
46.7 • C
OK · Calculated · gridintel.reliability.reference 0.3.0
Provisional: includes 1 open outage(s); duration counted to period end.

CAIDI
5.2 h • C
OK · Calculated · gridintel.reliability.reference 0.3.0
Provisional: includes 1 open outage(s); duration counted to period end.

SAIDI ATTRIBUTED TO THE DISTRIBUTION NETWORK
14.0 h • C
OK · Calculated · gridintel.reliability.reference 0.3.0
Provisional: includes 1 open outage(s); duration counted to period end.

CUSTOMERS SERVED
6,324 • C
OK · Calculated

Provisional: includes 1 open outage(s); duration counted to period end.

8 reported figure(s) state an attribution rule other than the reference one; what each rule changes is set out in section 7.

CONTENTS

1. The DisCo's indices
2. By substation
3. By feeder
4. Where interruptions began
5. Service-band compliance
6. Interruptions still open at the end of the period
7. Reported against calculated
8. Method, sources and how to reproduce this report
9. Regulatory references
10. Glossary and key

1 The DisCo's indices

How often, and for how long, the average customer was interrupted, and how much of it was the distribution network's.

SAIDI
241.0 h • C
OK · Calculated · gridintel.reliability.reference 0.3.0
Provisional: includes 1 open outage(s); duration counted to period end.

SAIFI
46.7 • C
OK · Calculated · gridintel.reliability.reference 0.3.0
Provisional: includes 1 open outage(s); duration counted to period end.

CAIDI
5.2 h • C
OK · Calculated · gridintel.reliability.reference 0.3.0
Provisional: includes 1 open outage(s); duration counted to period end.

ASAI
66.5% • C
OK · Calculated · gridintel.reliability.reference 0.3.0
Provisional: includes 1 open outage(s); duration counted to period end.

CUSTOMERS SERVED
6,324 • C
OK · Calculated

> Provisional: includes 1 open outage(s); duration counted to period end.

By attribution: whose interruption it was

Each interruption is attributed by where it began, under the reference methodology. The rows add up to the totals above.

	SAIDI (H)	SAIFI	SHARE OF CUSTOMER-HOURS
Network Faults, planned work and weather on the distribution network, including the lines that feed its substations.	14.0 h • C	4.0 • C	5.8% • C
Upstream supply Loss of supply that began at the transmission station or on the grid.	1.7 h • C	0.5 • C	0.7% • C
Load shedding Supply withheld under load management.	225.3 h • C	42.3 • C	93.5% • C
Other Customer, third party, or not known.	0.0 h • C	0.0 • C	0.0% • C

Method: GridIntel reference reliability indices (gridintel.reliability.reference 0.3.0).

1 exposure(s) were left out because a time or a customer count the calculation needs is missing.

13 momentary interruption(s) are not counted in SAIDI or SAIFI, under the methodology's threshold.

2 By substation

The same indices for each injection substation and the customers it serves.

Indices by substation

All interruptions, then the part attributed to the distribution network.

	CUSTOMERS	SAIDI (H)	SAIFI	CAIDI (H)	NETWORK SAIDI (H)	NETWORK SAIFI
Riverside 33/11 kV injection substation	3,543 • C	208.7 h • C	45.0 • C	4.6 h • C	6.9 h • C	1.7 • C
Hillcrest 33/11 kV injection substation	2,781 • C	282.2 h • C	49.0 • C	5.8 h • C	23.1 h • C	6.9 • C

Method: GridIntel reference reliability indices (gridintel.reliability.reference 0.3.0).

Hillcrest 33/11 kV injection substation: Provisional: includes 1 open outage(s); duration counted to period end.

3 By feeder

Which feeders fail their customers, ranked by what the distribution network itself did.

Indices by 11 kV feeder

Ranked by network-attributable SAIDI, highest first. Loss of upstream supply and load shedding are shown beside it and do not set the rank.

	CUSTOMERS	SAIDI (H)	SAIFI	CAIDI (H)	NETWORK SAIDI (H)	UPSTREAM SAIDI (H)	LOAD SHEDDING SAIDI (H)
1. Farm Road 11 kV feeder Hillcrest 33/11 kV injection substation	1,015 • C	442.5 h • C	80.1 • C	5.5 h • C	57.8 h • C	10.7 h • C	374.0 h • C
2. Old Town 11 kV feeder Riverside 33/11 kV injection substation	2,066 • C	305.2 h • C	62.1 • C	4.9 h • C	9.2 h • C	0.0 h • C	296.0 h • C
3. Market Road 11 kV feeder Riverside 33/11 kV injection substation	1,477 • C	73.8 h • C	21.1 • C	3.5 h • C	3.8 h • C	0.0 h • C	70.0 h • C
4. Government Avenue 11 kV feeder Hillcrest 33/11 kV injection substation	1,766 • C	190.1 h • C	31.1 • C	6.1 h • C	3.1 h • C	0.0 h • C	187.0 h • C

Method: GridIntel reference reliability indices (gridintel.reliability.reference 0.3.0).

Farm Road 11 kV feeder: Provisional: includes 1 open outage(s); duration counted to period end.

4 Where interruptions began

Attribution by the part of the system each interruption began at, which decides whether it is the distribution network's to fix.

By origin point

The part of the system the outage record names as where the interruption began, and which side of the boundary it is on.

	SAIDI (H)	SAIFI	SHARE OF CUSTOMER-HOURS
The grid (supply allocated) Load management or upstream	225.3 h • C	42.3 • C	93.5% • C
Sub-transmission line (33 kV) The distribution network	11.1 h • C	3.1 • C	4.6% • C
Distribution feeder (11 kV) The distribution network	2.6 h • C	0.8 • C	1.1% • C
Transmission station Upstream	1.7 h • C	0.5 • C	0.7% • C
Distribution transformer The distribution network	0.3 h • C	0.1 • C	0.1% • C
Low-voltage network The distribution network	0.1 h • C	0.0 • C	0.0% • C

Method: GridIntel reference reliability indices (gridintel.reliability.reference 0.3.0).

By cause

The cause the outage record gives.

	SAIDI (H)	SAIFI	SHARE OF CUSTOMER-HOURS
Load shedding	225.3 h • C	42.3 • C	93.5% • C
Fault	13.9 h • C	3.9 • C	5.8% • C
Loss of upstream supply	1.7 h • C	0.5 • C	0.7% • C
Planned maintenance	0.2 h • C	0.0 • C	0.1% • C
Weather	0.0 h • C	0.0 • C	0.0% • C

Method: GridIntel reference reliability indices (gridintel.reliability.reference 0.3.0).

The elements interruptions most often began at

Interruptions other than load shedding, most interruptions first.

	ORIGIN POINT	ATTRIBUTED TO	INTERRUPTIONS	SAIDI (H)
Hillcrest rural 33 kV line Named in the outage log; not a registry asset	Sub-transmission line (33 kV)	Network	16 • C	9.1 h • C
132/33 kV transmission station Named in the outage log; not a registry asset	Transmission station	Upstream supply	3 • C	1.7 h • C
Riverside 33 kV line Named in the outage log; not a registry asset	Sub-transmission line (33 kV)	Network	1 • C	2.0 h • C
Old Town 11 kV feeder Feeder	Distribution feeder (11 kV)	Network	1 • C	1.7 h • C
Government Avenue 11 kV feeder Feeder	Distribution feeder (11 kV)	Network	1 • C	0.8 h • C
Riverbank transformer Transformer	Distribution transformer	Network	1 • C	0.1 h • C
Farm Road 11 kV feeder Feeder	Distribution feeder (11 kV)	Network	1 • C	0.1 h • C

	ORIGIN POINT	ATTRIBUTED TO	INTERRUPTIONS	SAIDI (H)
Government Avenue transformer 4 Transformer	Distribution transformer	Network	1 • C	0.1 h • C
Farm Road transformer 3 Transformer	Low-voltage network	Network	1 • C	0.1 h • C
Garden Estate transformer Transformer	Distribution transformer	Network	1 • C	0.1 h • C
South Gate transformer Transformer	Low-voltage network	Network	1 • C	0.0 h • C

Method: GridIntel reference reliability indices (gridintel.reliability.reference 0.3.0).

Interruptions other than load shedding, by the element the outage record names as where they began. A 33 kV line and the transmission station are not registry assets, so they keep the names the outage log gives them.

5 Service-band compliance

Whether each feeder gave its customers the hours of supply its service band commits to, day by day.

Hours of supply against the band, by feeder

Each day is tested against the band minimum on its own; the average over the period is shown beside it and is a separate test.

	BAND	BAND MINIMUM	AVERAGE SUPPLIED	DAYS MET	DAYS BELOW
Farm Road 11 kV feeder Hillcrest 33/11 kV injection substation	Band D	8.0 h/day • C	9.2 h/day • C	20 • C	10 • C
Old Town 11 kV feeder Riverside 33/11 kV injection substation	Band C	12.0 h/day • C	13.8 h/day • C	28 • C	2 • C
Market Road 11 kV feeder Riverside 33/11 kV injection substation	Band A	20.0 h/day • C	21.5 h/day • C	23 • C	7 • C
Government Avenue 11 kV feeder Hillcrest 33/11 kV injection substation	Band B	16.0 h/day • C	17.7 h/day • C	23 • C	7 • C

Method: GridIntel reference hours of supply (gridintel.supply_hours.reference 0.2.0).

Farm Road 11 kV feeder: GridIntel reference calculation — not a regulatory figure. Band minimums are NERC Service-Based Tariff definitions.

Old Town 11 kV feeder: GridIntel reference calculation — not a regulatory figure. Band minimums are NERC Service-Based Tariff definitions.

Market Road 11 kV feeder: GridIntel reference calculation — not a regulatory figure. Band minimums are NERC Service-Based Tariff definitions.

Government Avenue 11 kV feeder: GridIntel reference calculation — not a regulatory figure. Band minimums are NERC Service-Based Tariff definitions.

Days below the band minimum

Every feeder-day that fell short, by feeder.

	DAY	HOURS SUPPLIED	BAND MINIMUM
Farm Road 11 kV feeder Band D	2026-09-02	7.8 h • C	8.0 h/day • C
Farm Road 11 kV feeder Band D	2026-09-08	7.5 h • C	8.0 h/day • C
Farm Road 11 kV feeder Band D	2026-09-09	7.8 h • C	8.0 h/day • C
Farm Road 11 kV feeder Band D	2026-09-12	7.8 h • C	8.0 h/day • C
Farm Road 11 kV feeder Band D	2026-09-13	6.8 h • C	8.0 h/day • C
Farm Road 11 kV feeder Band D	2026-09-16	7.4 h • C	8.0 h/day • C
Farm Road 11 kV feeder Band D	2026-09-23	6.1 h • C	8.0 h/day • C
Farm Road 11 kV feeder Band D	2026-09-25	7.8 h • C	8.0 h/day • C
Farm Road 11 kV feeder Band D	2026-09-29	7.1 h • C	8.0 h/day • C
Farm Road 11 kV feeder Band D	2026-09-30	7.7 h • C	8.0 h/day • C
Old Town 11 kV feeder Band C	2026-09-06	8.9 h • C	12.0 h/day • C
Old Town 11 kV feeder Band C	2026-09-18	11.4 h • C	12.0 h/day • C

	DAY	HOURS SUPPLIED	BAND MINIMUM
Market Road 11 kV feeder Band A	2026-09-06	19.0 h • C	20.0 h/day • C
Market Road 11 kV feeder Band A	2026-09-12	18.8 h • C	20.0 h/day • C
Market Road 11 kV feeder Band A	2026-09-18	17.4 h • C	20.0 h/day • C
Market Road 11 kV feeder Band A	2026-09-20	19.0 h • C	20.0 h/day • C
Market Road 11 kV feeder Band A	2026-09-21	19.0 h • C	20.0 h/day • C
Market Road 11 kV feeder Band A	2026-09-29	19.0 h • C	20.0 h/day • C
Market Road 11 kV feeder Band A	2026-09-30	19.0 h • C	20.0 h/day • C
Government Avenue 11 kV feeder Band B	2026-09-02	15.0 h • C	16.0 h/day • C
Government Avenue 11 kV feeder Band B	2026-09-04	15.0 h • C	16.0 h/day • C
Government Avenue 11 kV feeder Band B	2026-09-13	15.0 h • C	16.0 h/day • C
Government Avenue 11 kV feeder Band B	2026-09-14	15.0 h • C	16.0 h/day • C
Government Avenue 11 kV feeder Band B	2026-09-15	15.3 h • C	16.0 h/day • C
Government Avenue 11 kV feeder Band B	2026-09-17	15.0 h • C	16.0 h/day • C
Government Avenue 11 kV feeder Band B	2026-09-26	15.0 h • C	16.0 h/day • C

Method: GridIntel reference hours of supply (gridintel.supply_hours.reference 0.2.0).

6 Interruptions still open at the end of the period

Which figures are provisional because a restoration is not yet recorded.

> Provisional: includes 1 open outage(s); duration counted to period end.

Feeders whose figures are provisional

An interruption still open is counted to the end of the period. The figure is calculated, not estimated, and is not final until the restoration is recorded.

	WHAT IS PROVISIONAL
Farm Road 11 kV feeder Hillcrest 33/11 kV injection substation	Provisional: includes 1 open outage(s); duration counted to period end.

7 Reported against calculated

Each figure the DisCo reported for this period, beside GridIntel's calculation on the reported figure's own basis, and what a report's attribution rule changes.

The DisCo's reported figures

The report's methodology ("Utility internal reporting (synthetic)") has not been verified as equivalent to the GridIntel reference methods the calculations use. This applies to every figure below.

SAIDI · Riverside 33/11 kV injection substation

Reported	3.0 h • R	network interruptions only; planned work included
Calculated	6.9 h • C	network interruptions only; planned work included; treating as upstream: the grid, transmission stations

Same basis. Calculated less reported: +3.94 hours. The reported figure does not state how it put interruptions into classes (which origin points it treats as upstream). The variance may reflect a difference in classification rather than in what happened.

From: Monthly operations report, September 2026 (synthetic)

SAIFI · Riverside 33/11 kV injection substation

Reported	0.9 • R	network interruptions only; planned work included
Calculated	1.7 • C	network interruptions only; planned work included; treating as upstream: the grid, transmission stations

Same basis. Calculated less reported: +0.75 interruptions per customer. The reported figure does not state how it put interruptions into classes (which origin points it treats as upstream). The variance may reflect a difference in classification rather than in what happened.

From: Monthly operations report, September 2026 (synthetic)

SAIDI · Market Road 11 kV feeder

Reported	0.2 h • R	network interruptions only; planned work included; treating as upstream: the grid, transmission stations, sub-transmission lines
Calculated	0.2 h • C	network interruptions only; planned work included; treating as upstream: the grid, transmission stations, sub-transmission lines

Same basis. Calculated less reported: +0.03 hours.

From: Monthly operations report, September 2026 (synthetic)

ATTRIBUTION-RULE FINDING · MARKET ROAD 11 KV FEEDER

Rule treats sub-transmission lines as upstream

SAIDI on the report's rule	0.2 h • C
SAIDI on the reference rule	3.8 h • C
What the rule changes	+3.6 h • C

From: Monthly operations report, September 2026 (synthetic)

SAIFI · Market Road 11 kV feeder

Reported	0.1 • R	network interruptions only; planned work included; treating as upstream: the grid, transmission stations, sub-transmission lines
Calculated	0.1 • C	network interruptions only; planned work included; treating as upstream: the grid, transmission stations, sub-transmission lines

Same basis. Calculated less reported: -0.05 interruptions per customer.

From: Monthly operations report, September 2026 (synthetic)

ATTRIBUTION-RULE FINDING · MARKET ROAD 11 KV FEEDER

Rule treats sub-transmission lines as upstream

SAIFI on the report's rule	0.1 • C
SAIFI on the reference rule	1.1 • C
What the rule changes	+1.0 • C

From: Monthly operations report, September 2026 (synthetic)

SAIDI · Old Town 11 kV feeder

Reported	5.0 h • R	network interruptions only; planned work included; treating as upstream: the grid, transmission stations, sub-transmission lines
Calculated	5.6 h • C	network interruptions only; planned work included; treating as upstream: the grid, transmission stations, sub-transmission lines

Same basis. Calculated less reported: +0.59 hours.

From: Monthly operations report, September 2026 (synthetic)

ATTRIBUTION-RULE FINDING · OLD TOWN 11 KV FEEDER

Rule treats sub-transmission lines as upstream

SAIDI on the report's rule	5.6 h • C
SAIDI on the reference rule	9.2 h • C
What the rule changes	+3.6 h • C

From: Monthly operations report, September 2026 (synthetic)

SAIFI · Old Town 11 kV feeder

Reported	1.4 • R	network interruptions only; planned work included; treating as upstream: the grid, transmission stations, sub-transmission lines
Calculated	1.1 • C	network interruptions only; planned work included; treating as upstream: the grid, transmission stations, sub-transmission lines

Same basis. Calculated less reported: -0.32 interruptions per customer.

From: Monthly operations report, September 2026 (synthetic)

ATTRIBUTION-RULE FINDING · OLD TOWN 11 KV FEEDER

Rule treats sub-transmission lines as upstream

SAIFI on the report's rule	1.1 • C
SAIFI on the reference rule	2.1 • C
What the rule changes	+1.0 • C

From: Monthly operations report, September 2026 (synthetic)

SAIDI · Hillcrest 33/11 kV injection substation

Reported	1.9 h • R	network interruptions only; planned work included
Calculated	23.1 h • C	network interruptions only; planned work included; treating as upstream: the grid, transmission stations

Same basis. Calculated less reported: +21.16 hours. The reported figure does not state how it put interruptions into classes (which origin points it treats as upstream). The variance may reflect a difference in classification rather than in what happened.

From: Monthly operations report, September 2026 (synthetic)

SAIFI · Hillcrest 33/11 kV injection substation

Reported	0.8 • R	network interruptions only; planned work included
Calculated	6.9 • C	network interruptions only; planned work included; treating as upstream: the grid, transmission stations

Same basis. Calculated less reported: +6.13 interruptions per customer. The reported figure does not state how it put interruptions into classes (which origin points it treats as upstream). The variance may reflect a difference in classification rather than in what happened.

From: Monthly operations report, September 2026 (synthetic)

SAIDI · Farm Road 11 kV feeder

Reported	1.0 h • R	network interruptions only; planned work included; treating as upstream: the grid, transmission stations, sub-transmission lines
Calculated	1.0 h • C	network interruptions only; planned work included; treating as upstream: the grid, transmission stations, sub-transmission lines

Same basis. Calculated less reported: +0.04 hours.

From: Monthly operations report, September 2026 (synthetic)

ATTRIBUTION-RULE FINDING · FARM ROAD 11 KV FEEDER

Rule treats sub-transmission lines as upstream

SAIDI on the report's rule	1.0 h • C
SAIDI on the reference rule	57.8 h • C
What the rule changes	+56.7 h • C

From: Monthly operations report, September 2026 (synthetic)

SAIFI · Farm Road 11 kV feeder

Reported	1.1 • R	network interruptions only; planned work included; treating as upstream: the grid, transmission stations, sub-transmission lines
Calculated	1.1 • C	network interruptions only; planned work included; treating as upstream: the grid, transmission stations, sub-transmission lines

Same basis. Calculated less reported: +0.01 interruptions per customer.

From: Monthly operations report, September 2026 (synthetic)

ATTRIBUTION-RULE FINDING · FARM ROAD 11 KV FEEDER

Rule treats sub-transmission lines as upstream

SAIFI on the report's rule	1.1 • C
SAIFI on the reference rule	17.1 • C
What the rule changes	+16.0 • C

From: Monthly operations report, September 2026 (synthetic)

SAIDI · Government Avenue 11 kV feeder

Reported	2.7 h • R	network interruptions only; planned work included; treating as upstream: the grid, transmission stations, sub-transmission lines
Calculated	3.1 h • C	network interruptions only; planned work included; treating as upstream: the grid, transmission stations, sub-transmission lines

Same basis. Calculated less reported: +0.40 hours.

From: Monthly operations report, September 2026 (synthetic)

ATTRIBUTION-RULE FINDING · GOVERNMENT AVENUE 11 KV FEEDER

Rule treats sub-transmission lines as upstream

SAIDI on the report's rule	3.1 h • C
SAIDI on the reference rule	3.1 h • C
What the rule changes	0.0 h • C

From: Monthly operations report, September 2026 (synthetic)

SAIFI · Government Avenue 11 kV feeder

Reported	1.0 • R	network interruptions only; planned work included; treating as upstream: the grid, transmission stations, sub-transmission lines
Calculated	1.1 • C	network interruptions only; planned work included; treating as upstream: the grid, transmission stations, sub-transmission lines

Same basis. Calculated less reported: +0.08 interruptions per customer.

From: Monthly operations report, September 2026 (synthetic)

ATTRIBUTION-RULE FINDING · GOVERNMENT AVENUE 11 KV FEEDER

Rule treats sub-transmission lines as upstream

SAIFI on the report's rule	1.1 • C
SAIFI on the reference rule	1.1 • C
What the rule changes	0.0 • C

From: Monthly operations report, September 2026 (synthetic)

8 Method, sources and how to reproduce this report

Where every figure came from, and how a reader can check that this document is the one the records give.

Methodologies

METHODOLOGY	VERSION	WHAT IT SAYS OF ITSELF
GridIntel reference reliability indices `gridintel.reliability.reference`	`0.3.0`	GridIntel reference calculation — not a regulatory figure.
GridIntel reference reliability indices, on a reported attribution rule `gridintel.reliability.reference+upstream:grid,subtransmission_line,transmission_station`	`0.3.0`	GridIntel reference calculation — not a regulatory figure.
GridIntel reference hours of supply `gridintel.supply_hours.reference`	`0.2.0`	GridIntel reference calculation — not a regulatory figure. Band minimums are NERC Service-Based Tariff definitions.

Sources

- Synthetic outage log (synthetic)
- Synthetic asset registry (synthetic)

> Every source above is synthetic: designed demonstration data, not records of a real organization.

How to reproduce it

1. Build the report with definition version 1, for September 2026, from the Savanna Electricity Distribution (synthetic) records.
2. The data fingerprint must be `53b8256333afd69bcfe34e4bc6e72ffc536e2cfb4cc28ef830b97c47981163d5`. SHA-256 over the sorted SHA-256 digests of every distinct result the report's services were given by the repositories, each written as JSON with its keys in order.
3. With the same definition, methodologies and fingerprint the report ID is the same: GI-REL-2026-09-10DCE6F2. A different ID means something above differs.
4. The figures with their status, origin, unit and method are in the CSV of the same report ID: gridintel-reliability-2026-09-SAMPLE-SYNTHETIC.csv.

9 Regulatory references

> How far this report carries the fields of the instruments below, as read from the instruments themselves. It is not a claim that the report conforms to any regulator's or programme's template: none has been checked against the template it would be filed on.

INSTRUMENT	REQUIREMENT	THIS REPORT
NERC Reporting Compliance Regulations 2009 (NERC-R-02-09), s. 9 and Schedule 4A	1. SAIDI: total duration of interruption (hrs), total number of interruptions to customers, total number of registered customers; monthly	**PARTLY** Sections 1–3 give SAIDI and its parts by DisCo, substation and feeder. The denominator is customers served by the network in the registry; whether it is the Schedule's "registered customers" is to be confirmed.
NERC Reporting Compliance Regulations 2009 (NERC-R-02-09), s. 9 and Schedule 4A	2. SAIFI: total number of system interruptions, total number of supply points affected (from distribution transformer uprisers); monthly	**PARTLY** Sections 1–3 give SAIFI per customer served. A count by supply point (transformer upriser) is not calculated.
NERC Reporting Compliance Regulations 2009 (NERC-R-02-09), s. 9 and Schedule 4A	3. CAIDI: SAIDI, SAIFI; monthly	**CARRIED** Sections 1–3.
NERC Reporting Compliance Regulations 2009 (NERC-R-02-09), s. 9 and Schedule 4A	4. CAIFI: total number of customer interruptions, total number of registered customers; monthly	**NOT CARRIED** Not calculated: it needs the number of distinct customers interrupted, which the methodology does not yet count.
NERC Reporting Compliance Regulations 2009 (NERC-R-02-09), s. 9 and Schedule 4A	5–6. HV and LV fault clearance indices: faults cleared within 8 hours against faults reported; monthly	**NOT CARRIED** Not calculated. The outage records hold the times it would be counted from.

INSTRUMENT	REQUIREMENT	THIS REPORT
NERC June 2024 Supplementary Order to MYTO 2024 (e.g. ORDER/NERC/2024/068, YEDC), para. 9 and Appendix 1	Service-Based Tariff bands and their minimum hours of supply a day (A 20, B 16, C 12, D 8, E 4)	**CARRIED** Section 5 tests each feeder's days against its band minimum, and gives its average over the period.
NERC June 2024 Supplementary Order to MYTO 2024 (e.g. ORDER/NERC/2024/068, YEDC), para. 9 and Appendix 1	9(c). Publish daily a rolling seven-day average of daily hours of supply on each Band A feeder	**PARTLY** Section 5 and the CSV give each Band A feeder's hours of supply day by day; the rolling seven-day average is not calculated.
NERC June 2024 Supplementary Order to MYTO 2024 (e.g. ORDER/NERC/2024/068, YEDC), para. 9 and Appendix 1	9(d)–(e). A Band A feeder below its committed level on two, and on seven, consecutive days	**PARTLY** Section 5 lists every feeder-day below the band minimum; runs of consecutive days are not counted.

10 Glossary and key

SAIDI — System Average Interruption Duration Index: the hours of interruption the average customer served had in the period. Customer-hours interrupted ÷ customers served.

SAIFI — System Average Interruption Frequency Index: the interruptions the average customer served had in the period. Customer interruptions ÷ customers served.

CAIDI — Customer Average Interruption Duration Index: the average length of an interruption, in hours. SAIDI ÷ SAIFI.

ASAI — Average Service Availability Index: the share of customer-hours in the period with supply.

Network-attributable — The part of an index caused by interruptions that began on the distribution network (33 kV and 11 kV lines, distribution transformers, the low-voltage network), under the reference methodology.

Upstream supply — Interruptions that began at the transmission station or above it: not the distribution network's.

Load shedding — A feeder opened on purpose because the supply allocated was short. It began nowhere on the network.

Origin point — The part of the system an outage record names as where an interruption began. It decides the attribution.

Service band — NERC's Service-Based Tariff band of a feeder, with its minimum average hours of supply a day: A 20, B 16, C 12, D 8, E 4.

Provisional — A figure that includes an interruption still open at the end of the period, counted to its end. It is calculated, not estimated, and is final only when the restoration is recorded.

Attribution-rule finding — Where a reported figure states an attribution rule other than the reference one: the same figure on both rules and the difference, so a reader sees what the rule changes.

Measured — Read from a meter, a device or a source record.

Reported — A figure published by someone else, shown as they stated it. It is never altered.

Calculated — Computed by GridIntel from records, under a named and versioned methodology.

Estimated — An estimate, not a measurement; the method is named with it.

Derived — A residual: what is left when other figures are subtracted. It carries their uncertainty.

Insufficient data — An input the figure needs is missing. No value is given rather than a guess, and never a zero.

Not available — No source holds this figure, or the data does not cover the period.

Same basis — A reported figure and a calculation count the same things over the same period by the same rule. Only figures on the same basis are compared.

Data fingerprint — A SHA-256 digest of every record the report was built from. The same records give the same fingerprint; any change to them gives another.

Report ID — The report's code, its period and the first characters of a digest of its definition, methodologies and data fingerprint. The same report of the same data has the same ID.

The marks beside a figure

• OK — Every input is present and measured.

≈ Estimated inputs — Calculated; every input is present, but at least one was estimated rather than measured.

! Insufficient data — An input this figure needs is missing. No value is shown rather than a guess.

∅ **Not computable**	The inputs exist but the calculation is undefined for them.
– **Not available**	The platform has no source for this figure.
M **Measured**	Read from a meter, device or source record.
R **Reported**	Published by someone else; shown as stated.
C **Calculated**	Computed by GridIntel under a named methodology.
E **Estimated**	An estimate, not a measurement.
D **Derived**	A residual: what is left after subtracting other figures. It inherits their uncertainty.

SAMPLE: SYNTHETIC DATA. End of report GI-REL-2026-09-10DCE6F2.