



BACHY SOLETANCHE GROUP
SOIL & FOUNDATIONS SPECIALISTS

DRILLHOLE RECORD

HOLE NO. DH39

SHEET 1 of 4

CONTRACT

PROJECT LINCOLN HOUSE DEVELOPMENT, QUARRY BAY

METHOD ROTARY

CO-ORDINATES

W.O. W-518

MACHINE & No. LY-61

E 839923.80

DATE from 27/1/96 to 1/2/96

N 816560.75

FLUSHING MEDIUM WATER

ORIENTATION Vertical

GROUND-LEVEL 3.86 mPD

Drilling Progress	Casing size	Water level (m) Shift start/end	Total core Recovery %	Solid core Recovery %	R.Q.D.	Fracture Index	Tests	Samples	Reduced Level	Depth (m)	Legend	Grade	Description
1	SX		89					SX	3.66	0.20			Concrete Slab.
2	SX 1.75m PX		100					T2 -101	2.56 2.11	1.30 1.75			Brown, gravelly silty medium to coarse SAND. (FILL)
3	PX 3.50m HX		100					T2 -101					Angular Boulder, Cobbles and Gravels of moderately decomposed granite with some brown silty SAND. (FILL)
4			100					T2 -101					1.37m-1.70m: boulder. Concrete with Cobbles and Gravels of moderately decomposed granite. (FILL)
5			91					T2 -101					Angular Cobbles and Gravels of moderately decomposed granite and tuff with some brown, silty SAND. (FILL)
6			64					T2 -101					Wash boring. (No recovery)
7													
8													
9													
10													

• SMALL DISTURBED SAMPLE	Δ WATER SAMPLE
▬ LARGE DISTURBED SAMPLE	▲ PIEZOMETER TIP
▨ SPT LINER SAMPLE	◻ STANDPIPE
▩ U75 UNDISTURBED SAMPLE	↓ STANDARD PENETRATION TEST
▩ U100 UNDISTURBED SAMPLE	┃ PERMEABILITY TEST
▩ MAZIER SAMPLE (70mm)	√ IN-SITU VANE SHEAR TEST
▩ PISTON SAMPLE	

LOGGED FRANK CHAN

DATE 02/02/96

APPROVED C.LUN

DATE 03/02/96

REMARKS

Hole termination depth at 33.61m.



BACHY SOLETANCHE GROUP
SOIL & FOUNDATIONS SPECIALISTS

DRILLHOLE RECORD

HOLE NO. DH39

CONTRACT

SHEET 2 of 4

PROJECT LINCOLN HOUSE DEVELOPMENT, QUARRY BAY

METHOD ROTARY

CO-ORDINATES

W.O. W-518

MACHINE & No. LY-61

E 839923.80
N 816560.75

DATE from 27/1/96 to 1/2/96

FLUSHING MEDIUM WATER

ORIENTATION Vertical

GROUND-LEVEL 3.86 mPD

Drilling Progress	Casing size	Water level (m) Shift start/end	Total core Recovery %	Solid core Recovery %	R.Q.D.	Fracture Index	Tests	Samples	Reduced Level	Depth (m)	Legend	Grade	Description
11													AS SHEET 1 OF 4.
12													
13													
14													
15													
16													
17													
18													
19													
20													

- SMALL DISTURBED SAMPLE
- ▬ LARGE DISTURBED SAMPLE
- ▨ SPT LINER SAMPLE
- ▩ U76 UNDISTURBED SAMPLE
- ▩ U100 UNDISTURBED SAMPLE
- ▩ MAZIER SAMPLE (70mm)
- ▩ PISTON SAMPLE
- △ WATER SAMPLE
- ▲ PIEZOMETER TIP
- STANDPIPE
- ⊥ STANDARD PENETRATION TEST
- ⊥ PERMEABILITY TEST
- ∨ IN-SITU VANE SHEAR TEST

LOGGED FRANK CHAN

DATE 02/02/96

APPROVED C.LUN

DATE 03/02/96

REMARKS



BACHY SOLETANCHE GROUP
SOIL & FOUNDATIONS SPECIALISTS

DRILLHOLE RECORD

HOLE NO. DH39

CONTRACT

SHEET 3 of 4

PROJECT LINCOLN HOUSE DEVELOPMENT, QUARRY BAY

METHOD ROTARY

CO-ORDINATES

W.O. W-518

MACHINE & No. LY-61

E 839923.80

DATE from 27/1/96 to 1/2/96

N 816560.75

FLUSHING MEDIUM WATER

ORIENTATION Vertical

GROUND-LEVEL 3.86 mPD

Drilling Progress	Casing size	Water level (m) Shift start/end	Total core Recovery %	Solid core Recovery %	R.Q.D.	Fracture Index	Tests	Samples	Reduced Level	Depth (m)	Legend	Grade	Description
21													AS SHEET 2 OF 4.
22													
23													
24	HX 23.90m								-20.04	23.90	+	III	
25			100	44	26	7.5 NI 10.0		T2-101	-20.57 -20.77 -21.07	24.43 24.63 24.93	++ ++ ++	IV/III III IV/III	Moderately weak to moderately strong, brownish pink spotted black and white, moderately decomposed medium to coarse grained GRANITE with medium to closely spaced, narrow to moderately narrow, rough planar, limonite, manganese stained, kaolin coated joints, dipping 10°-20°, 80°-85° and occasionally vertical joints.
26			100	100	67	5.9 NI		T2-101	-21.79	25.65	++	III	
27			100	90	63	2.6 NI		T-76	-23.58 -23.75 -23.91	27.44 27.61 27.77	++ ++ ++	IV/III III IV/III	24.43m-24.63m, 24.93m-25.65m, 27.44m-27.61m & 27.77m-28.14m: weak to moderately weak, brownish pink spotted black and white, highly to moderately decomposed medium to coarse grained GRANITE.
28			100	68	33	20.0 NI		T-76	-24.28	28.94 28.22	++ ++	III IV/III	
29			100	100	87	4.2		T-76		28.49	++	III	Moderately weak to moderately strong, brownish pink spotted black and white, moderately decomposed medium to coarse grained GRANITE with widely to medium spaced, very narrow, rough planar, limonite, manganese stained and kaolin coated joints, dipping 10°-20°, 40°-60°, 70°-80°.
30			100	100	83			T-76		29.12	++		

- SMALL DISTURBED SAMPLE
- ▬ LARGE DISTURBED SAMPLE
- ▬ SPT LINER SAMPLE
- ▬ U76 UNDISTURBED SAMPLE
- ▬ U100 UNDISTURBED SAMPLE
- ▬ MAZIER SAMPLE (70mm)
- ▬ PISTON SAMPLE
- Δ WATER SAMPLE
- ▲ PIEZOMETER TIP
- STANDPIPE
- ┆ STANDARD PENETRATION TEST
- ┆ PERMEABILITY TEST
- ∇ IN-SITU VANE SHEAR TEST

LOGGED FRANK CHAN

DATE 02/02/96

APPROVED C.LUN

DATE 03/02/96

REMARKS

		BACHY SOLETANCHE GROUP SOIL & FOUNDATIONS SPECIALISTS		DRILLHOLE RECORD		HOLE NO. DH39							
				CONTRACT		SHEET 4 of 4							
PROJECT LINCOLN HOUSE DEVELOPMENT, QUARRY BAY													
METHOD ROTARY				CO-ORDINATES E 839923.80 N 816560.75		W.O. W-518							
MACHINE & No. LY-61						DATE from 27/1/96 to 1/2/96							
FLUSHING MEDIUM WATER				ORIENTATION Vertical		GROUND-LEVEL 3.86 mPD							
Drilling Progress	Casing size	Water level (m) Shift start/end	Total core Recovery %	Solid core Recovery %	R.Q.D.	Fracture Index	Tests	Samples	Reduced Level	Depth (m)	Legend	Grade	Description
31/01			100	100	62	8.6		1-74		30.12	+	III	AS SHEET 3 OF 4.
31								1-74		30.64	+		
32/96			100	100	86	2.4		1-74		31.07	+		
01/02/96										31.90	+		
33			100	100	79	2.9		1-74		32.12	+		
										32.56	+		
										33.61	+		End of hole at 33.61m.
34													
35													
36													
37													
38													
39													
40													
• SMALL DISTURBED SAMPLE ▮ LARGE DISTURBED SAMPLE ▮ SPT LINER SAMPLE ▮ U76 UNDISTURBED SAMPLE ▮ U100 UNDISTURBED SAMPLE ▮ MAZIER SAMPLE (70mm) ▮ PISTON SAMPLE Δ WATER SAMPLE ▲ PIEZOMETER TIP ◻ STANDPIPE ⊥ STANDARD PENETRATION TEST ⊥ PERMEABILITY TEST ∨ IN-SITU VANE SHEAR TEST								LOGGED <u>FRANK CHAN</u> DATE <u>02/02/96</u> APPROVED <u>C.LUN</u> DATE <u>03/02/96</u>		REMARKS			