

Number: SOP-HPCS-STBY	Use Category: CONTINUOUS	Major Rev: 003
Title: HPCS System Standby		Minor Rev: 001 Page: 1 of 1

## 1.0 STANDBY

- 1.1 **VERIFY** HPCS high and low level signals reset.
- 1.2 **VERIFY** HPCS-P-1 stopped.
- 1.3 **VERIFY** HPCS-V-1 open.
- 1.4 **VERIFY** HPCS-V-23 closed.
- 1.5 **VERIFY** HPCS-V-4 closed.
- 1.6 **VERIFY** DG-3 "READY FOR AUTO START" lamp illuminated.