TECHNICAL SPECIFICATION

9	Pt.	TECHNICAL SPECIFICATION DETAIL
BASE FRAME	a	**The steel base & Top** frame shall be constructed from MS I-BEAM 120X64, full perimeter beams with central runner and cross members.
	b	**Lifting eyes** are provided at intermediate points at the Base of the cabin welded the painted in 01 coat of red oxide primer and 01 coat with matt enamel paint.
	c	**Base frame** shall paint with 02 coat paint, one with red oxide, one with rust free enamel paint.
FLOOR SYSTEM	a	**Floor Frame:** The Floor frame shall be constructed from MS angle 50X50X2.7MM welded into the base & top frame, making the floor assembly one integral frame. (400mm joists spacing). The floor frame shall be grit blasted to SA2.5 and painted with 02 coat system of epoxy paint
	b	**Floor decking:** One layer of 18 mm thick cement board, fixed to the base frame and floor frame. Bottom of the cement board is painted with bitumen paint.
	c	**Floor finish in Dry Area:** 1.5mm PVC vinyl sheet from the good brand.
	d	**Floor finish in WET Area:** PVC vinyl sheet 1.5mm thick.
WALL SYSTEM	a	**External Finish:** 06mm thick cement board finish with heavy texture paint. As per approved color. **External wall joints shall be covered by 6mm thick CFB joint strips.**
	b	**Internal Finish in dry area: 12.5** mm thick gypsum board finish with emulsion paint. Floor skirting MDF 50mm/PVC 75MM SKIRTING.
	c	**Internal Finish in Wet area: 12mm thick MR GYPSUM board** fixed to cold formed steel wall framing. Joints shall be covered with mdf 5cm skirting.
	d	**Wall Framing:** on LGS profile framing GI studs 70x35x 0.45 fixed together by screws at spacing of 610 mm vertically & 1200mm horizontally.
	e	**Wall Insulation:** 50mm thick glass-wool insulation 12kg/m3 density.
	f	**Dry Area: Emulsion paint** (**off-white color**) applied to gypsum board. (National) **Wet area: Enamel paint** (**white color**) applied to cement fiber board. (National).
Roofing	a	**Roof Covering**: 0.5mm thick GI Corrugated steel shall be fixed on furry channel 0.5mm purlins as per drawing.
	b	**Trusses:** Truss shall be made of MS Angle 40x40x2.7mm.
	c	
Ceiling	a	**Ceiling in Dry Area:** ceiling shall be12mm gypsum board finish with the fine texture paint.
	b	**Ceiling in Wet Areas:** ceiling shall be 12mm gypsum board finish with the fine texture paint.
	c	
Door	a	**External door:** Supply and installation of Aluminum/PVC Door accessories. 900x2100 **Door Accessories:** **Door Lock system:** Mortice lockset with cylinder and SS door handles shall be provided for all internal doors and Single cylinder with thumb turn latch shall be provided for internal toilet doors.
	b	**Internal/Toilet NFR Door Size**: 900/700x2100mm PVC DOOR **Door Accessories:** **Door Lock system:** Mortice lockset with cylinder and SS door handles shall be provided for all internal doors and Single cylinder with thumb turn latch shall be provided for internal toilet doors
	c	
Windows	a	**External Windows:** Powder coated aluminum frame (non-thermal break), with **6mm thick clear glass externally** Hinged window (One shutter hinged & other fixed). 900x900.
	b	**Exhaust window:** Powder coated aluminum frame (non-thermal break), fixed Exhaust window with **6mm thick Single obscure glass**. Size: **400x400mm**
	c	
ELECTRICAL	a	Electrical Supply: conduits and wiring by National/Du-cab/RR.
	b	Tube light 36w ceiling light by MAX.
	c	
	a	
	b	
	c	