NSW ANNUAL FIRE SAFETY STATEMENT

AFSS readiness checklist

Run through this before the owner or their agent signs the annual fire safety statement. Tick each item, or note why it doesn't apply.

BUILDING AND ADDRESS

COUNCIL

AFSS DUE DATE (AS COUNCIL HOLDS IT)

PLANNED ISSUE DATE

OWNER OR AGENT SIGNING

ACCREDITED PRACTITIONER(S) (FIRE SAFETY)

ACCREDITATION NO(S)

1 Schedule and records

- [ ] Current fire safety schedule on hand, and it matches the measures installed in the building
- [ ] Last annual statement, and any supplementary statements, on file
- [ ] Due date confirmed with the council
  Councils word the 12-month rule differently, so use the date they hold.
- [ ] Recent AS 1851-2012 servicing records (logbooks, condition report) available to inform the assessment

2 Every measure assessed

s 88

- [ ] Every measure on the schedule assessed on site by an accredited practitioner (fire safety)
- [ ] Each one found capable of performing to the standard of performance on the schedule
  Or, for a measure not on the schedule, the standard it was designed and installed to.
- [ ] Assessment dates fall within the 3 months before the planned issue date
- [ ] Each practitioner's accreditation checked on the register, and it covers the measures they assessed

3 Exits and paths of travel

Part 15

- [ ] Fire exits, fire exit doors, paths of travel to exits and fire safety notices inspected
- [ ] Nothing found that would give grounds for a prosecution under Part 15
- [ ] Inspection dates also within the 3 months before issue

4 Defects closed or noted

- [ ] Every defect from the assessment is rectified and verified, or noted with the owner's agreed action
- [ ] Critical defects reported to the owner within the AS 1851-2012 timeframes, and in writing
- [ ] No measure listed as capable while a defect stops it performing to its standard
- [ ] If defects will push the statement past its due date, the council told in writing early

5 Practitioner details on the form

s 92

- [ ] Section 4: each measure, its standard of performance, the date(s) assessed and the practitioner's accreditation number
- [ ] Section 5: the parts of the building inspected, the date(s) and the accreditation number
- [ ] Section 6: each practitioner's name, contact details and signature, or their separate signed document attached

6 The form and the declaration

- [ ] The approved NSW form used without changes
  No letterhead or logo, and no sections added or removed.
- [ ] Section 1 marked annual; building described (section 2); owner named (section 3)
- [ ] Sections 7 and 8: the person declaring is the owner, or an agent with the owner's prior authority
- [ ] The person declaring is not a practitioner who assessed or inspected, nor their employer, employee or direct associate
- [ ] Current fire safety schedule attached
  The statement can't be issued without it.
- [ ] Signed, with the date issued filled in

7 After it is signed

s 89

- [ ] Copy given to the council by the due date, the way that council asks for it
- [ ] Copy, with the current schedule, to Fire and Rescue NSW as soon as practicable
  fire.nsw.gov.au/afsssubmission
- [ ] Copy, with the current schedule, displayed in a prominent place in the building
- [ ] Next AFSS due date in the diary: _____
- [ ] Supplementary statement dates for critical measures in the diary
  They run on their own cycle, set by the schedule (s 90).
- [ ] Copies of the statement, schedule and reports kept with the building's records

CHECKED BY

SIGNATURE AND DATE

Based on the Environmental Planning and Assessment (Development Certification and Fire Safety) Regulation 2021 (NSW): s 81 (maintaining measures), ss 88 to 92 (fire safety statements) and Part 15 (exits), and the notes to the approved fire safety statement form (version 4). Summarised in our own words as at October 2026. A checklist, not legal advice: check the current Regulation, the form and the council's requirements.