FIRE SAFETY DEFECTS

Defect register

One building per sheet. Log each defect as you find it, record when the owner was told, and close it out with the rectified date and who verified it.

Sheet _____ of _____

BUILDING	ADDRESS	OWNER OR AGENT	PRACTITIONER AND COMPANY	ACCREDITATION NO.

REF	MEASURE	LOCATION	DESCRIPTION	CRITICAL / NON-CRITICAL	NOTIFIED TO OWNER (DATE)	ACTION	RECTIFIED (DATE)	VERIFIED BY (NAME, DATE)
EXAMPLE *D-001*	*Exit signs*	*Level 2, east corridor, above door 2.04*	*Exit sign not lit during the battery discharge test*	CD ☐ NCD ☑	*14/10/2026*	*Replace the fitting and retest (Acme Fire Safety)*	*21/10/2026*	*Alex Morgan, 21/10/2026*
				CD ☐ NCD ☐				
				CD ☐ NCD ☐				
				CD ☐ NCD ☐				
				CD ☐ NCD ☐				
				CD ☐ NCD ☐				
				CD ☐ NCD ☐				
				CD ☐ NCD ☐				
				CD ☐ NCD ☐				
				CD ☐ NCD ☐				

CD critical defect · **NCD** non-critical defect, classified under AS 1851-2012. AS 1851-2012 sets how quickly the owner must be told for each class; check your licensed copy. A defect is closed once it has a rectified date and has been verified. A measure with a defect that stops it performing to its standard has to be fixed before an annual fire safety statement can declare it capable. The example row is fictional.