



Lancaster County
Planning Department
P. O. Box 1809
Lancaster, SC 29721
803.285.6005
planning@lancastercountysc.net

March 19, 2026

Arafath Mohammad
Waxlan Investments LLC
1030 CHERRY LAUREL DRIVE
Waxhaw, NC 28173

Project Number	20260168
Project Name	10935 Harrisburg Rd - Arafath Mohammad
Location	10935 Harrisburg Rd, Indian Land
Stage	Conditional Use
Parcel(s)	0003.00.048.00
Status	Not Approved

Dear: Arafath Mohammad

We have completed our review of the plan identified above. The comments listed on the attached report must be addressed and revised plans submitted with a response letter.

If the attached comments require changes to the plans, please submit the requisite number of sets, along with a pdf of the plan set on a CD, to the Lancaster County Planning Department.

Once revised plans are received, they will be submitted to staff for review.

Please be aware that plans will not be routed for review without a response letter

Sincerely,

A handwritten signature in black ink that reads "Chanda Kirkland".

Chanda Kirkland, Development Service Coordinator
Lancaster County Government
101 N Main St
Lancaster, SC 29720
P: (803) 416-9390

Plan Review Comments

County Engineer - Stephen Blackwelder - 8035482406
sblackwelder@lanastercountysc.gov

Conditional

Review Comments:

General Comments:

1. This is located in the Lancaster County Stormwater MS4 area. We are a designated review authority for SC DHEC in the Indian Land Area. Once you have civil plan approval from all departments in Lancaster County, you will need to go through the SC DES E-permitting process to get your NOI to them. You will fill out the appropriate form based on the acreage of disturbed area. We will upload a letter of approval into Evolve that you will need during this process. SC DES will release your NDPES permit once you have fully completed their process.
2. The preliminary nature of this plan set does not provide adequate detail to formally comment, but the following are items of note from the information given. More specific comments will be provided during the civil review cycle.
3. SC DES regulations must be met. The regulations will depend on the area of land disturbance, the total amount of impervious area added, etc.
4. The southern radius of the driveway must have 5+ feet of tangent between the end of the radius and the property line.
5. SCDOT will need to approve an encroachment permit for all work done on their Right of Way and for the access point location and improvements.

Fire Marshal - Mike Magette - 8032838888
jmagette@lanastercountysc.gov

Conditional

Review Comments:

1. Show length of fire apparatus access road. Dead end fire apparatus access roads longer than 150 feet in length must have an approved turnaround.

SCDOT - David Gamble - (803) 385-4280
GambleDD@scdot.org

Conditional

Review Comments:

Encroachment permit will be required for revising the existing residential drive to commercial standards.

Zoning - Julie Faile - 803-283-0567
jfaile@lanastercountysc.gov

Conditional

Review Comments:

Additional information is required upon submission of the Civil Site Plan:

- 1) Landscape islands are mandated at a minimum of one island per 10 parking spaces.
- 2) Parking calculations must differentiate between office areas and assembly spaces. Please provide a detailed breakdown of these areas to facilitate accurate parking requirement determinations.
- 3) Specify the width of standard parking spaces and accessible (ADA-compliant) access aisles.
- 4) In areas lacking curbs, wheel stops shall be installed. Parking stall lengths must be adjusted to accommodate the installation of wheel stops.

Contact Julie Faile at 803-283-0567 for any questions.

Planning - Kirsten Willis - 803-285-6005
kwillis@lanastercountysc.gov

Not Approved

Review Comments:

Planning Commissions provides recommendation of approval or denial to County Council. All planner commentary and recommendation are strictly advisory. Status will remain "Not Approved" until case is heard by Planning Commission. Once Planning Commission provides recommendation, County Council will hear this Conditional Use application for one reading for approval or denial.

Planning Commission Hearing: April 21, 2026 at 6:00pm in Council Chambers.

Staff will be recommending approval.

LC Water & Sewer District - Tim Kiser - 8032856919
tim.kiser@lcwasd.org

No Review Needed

Review Comments:
