

# System Efficiency between TYSONS (26165) and TABBITA-1 (26215) for period 2019-10-16 00:00 to 2019-11-17 00:00

System Efficiency (%):	106.1
------------------------	-------

Diverted (ML):	899.0
Delivered (ML):	111.2
Evaporative loss (ML):	2.9
Rainfall (ML):	0.6
Seepage loss (ML):	not yet implemented
Unaccounted loss (ML):	-8.7

## Outlets

Telemetered:	3
Manually read:	0
Unmetered sites:	0
Total:	3

outlet	object_id	RTU_totaliser (ML)	flow_integral (ML)	manual_reading (ML)	diff	
M2371/1	67666	40.515	39.163		3.337	
M2371/3	67672	58.870	57.604		2.150	
M2371/4	67675	11.815	10.952		7.308	
	Total	111.2	107.7	0.0		0.0

time of data collection: 2020-04-23 14:28