

System Efficiency between TYSONS (26165) and TABBITA-1 (26215)

for period 2020-01-16 00:00 to 2020-02-17 00:00

System Efficiency (%):	100.9
------------------------	-------

Diverted (ML):	1014.5
Delivered (ML):	161.9
Evaporative loss (ML):	3.5
Rainfall (ML):	1.7
Seepage loss (ML):	not yet implemented
Unaccounted loss (ML):	-3.3

Outlets

Telemetered:	3
Manually read:	0
Unmetered sites:	0
Total:	3

outlet	object_id	RTU_totaliser (ML)	flow_integral (ML)	manual_reading (ML)	diff	
M2371/1	67666	41.413	39.810		3.872	
M2371/3	67672	85.537	84.265		1.488	
M2371/4	67675	34.945	33.968		2.796	
	Total	161.9	158.0	0.0		0.0

time of data collection: 2020-04-23 14:29