

System Efficiency between TYSONS (26165) and TABBITA-1 (26215) for period 2020-03-16 00:00 to 2020-04-17 00:00

System Efficiency (%):	65.0
------------------------	------

Diverted (ML):	326.2 274.3
Delivered (ML):	33.7
Evaporative loss (ML):	1.8
Rainfall (ML):	1.0
Seepage loss (ML):	not yet implemented
Unaccounted loss (ML):	17.4

Outlets

Telemetered:	3
Manually read:	0
Unmetered sites:	0
Total:	3

outlet	object_id	RTU_totaliser (ML)	flow_integral (ML)	manual_reading (ML)	diff	
M2371/1	67666	21.435	20.676		3.540	
M2371/3	67672	11.587	11.067		4.490	
M2371/4	67675	0.693	0.660		4.724	
	Total	33.7	32.4	0.0		0.0

time of data collection: 2020-04-23 15:06