

System Efficiency between TYSONS (26165) and TABBITA-1 (26215)

for period 2019-08-16 00:00 to 2019-09-17 00:00

System Efficiency (%):	33.7
------------------------	------

Diverted (ML):	417.7 287.9
Delivered (ML):	43.8
Evaporative loss (ML):	1.5
Rainfall (ML):	0.2
Seepage loss (ML):	not yet implemented
Unaccounted loss (ML):	84.6

Outlets

Telemetered:	3
Manually read:	0
Unmetered sites:	0
Total:	3

outlet	object_id	RTU_totaliser (ML)	flow_integral (ML)	manual_reading (ML)	diff	
M2371/1	67666	30.295	29.279		3.354	
M2371/3	67672	11.032	10.598		3.935	
M2371/4	67675	2.466	2.378		3.588	
	Total	43.8	42.3	0.0		0.0

time of data collection: 2020-04-23 15:05