

# Heat meters —

## Part 2: Constructional requirements

The European Standard EN 1434-2:2007 has the status of a British Standard

ICS 17.200.10

# National foreword

This British Standard is the UK implementation of EN 1434-2:2007. It supersedes BS EN 1434-2:1997 which is withdrawn.

The start and finish of text introduced or altered by corrigendum is indicated in the text by tags **AC** **AC**. Text altered by CEN corrigendum October 2007 is indicated in the text by **AC1** **AC1**.

The UK participation in its preparation was entrusted by Technical Committee CPI/30, Measurement of fluid flow in closed conduits, to Subcommittee CPI/30/7, Volume flow-rate methods.

A list of organizations represented on this subcommittee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

**Compliance with a British Standard cannot confer immunity from legal obligations.**

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 May 2007

© BSI 2008

ISBN 978 0 580 60652 6

## Amendments issued since publication

Amd. No.	Date	Comments
17486 Corrigendum No. 1	31 January 2008	See national foreword

English Version

## Heat meters - Part 2: Constructional requirements

Compteurs d'énergie thermique - Partie 2: Prescriptions de fabrication

Wärmezähler - Teil 2: Anforderungen an die Konstruktion

This European Standard was approved by CEN on 7 January 2007.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**Management Centre: rue de Stassart, 36 B-1050 Brussels**

# Contents

Page

Foreword.....	4
1 Scope .....	5
2 Normative references .....	5
3 Temperature sensors .....	5
3.1 General.....	5
3.2 Mechanical design .....	6
3.2.1 General.....	6
3.2.2 Materials of temperature probe sheath and pocket .....	6
3.2.3 Dimensions of direct mounted short probes - Type DS .....	6
3.2.4 Dimensions of direct mounted long probes - Type DL.....	6
3.2.5 Dimensions of pocket mounted long probes - Type PL .....	9
3.2.6 Dimensions of temperature pocket.....	9
3.2.7 Design of short probes with respect to installation .....	11
3.2.8 Design of long probes with respect to installation .....	11
3.3 Platinum temperature sensor.....	12
3.3.1 Specialised definitions for 2 wire temperature probes.....	12
3.3.2 Resistance characteristics .....	13
3.3.3 Signal leads .....	14
3.3.4 Temperature sensors for the 2-wire method .....	14
3.3.5 Temperature sensors for the 4-wire method .....	14
3.3.6 Thermal response time .....	15
3.4 Other temperature sensors.....	15
4 Flow sensors .....	15
4.1 Maximum admissible working pressure, PS in bar.....	15
4.2 Sizes and dimensions .....	15
4.3 Test signal output.....	17
4.4 Adjusting device .....	17
5 Calculators .....	17
5.1 Mechanical dimensions for calculators for domestic use.....	17
5.2 Terminals - specification and identification.....	18
5.2.1 General.....	18
5.2.2 Terminals for signal leads .....	18
5.2.3 Terminals for connection to the mains supply.....	19
5.3 Batteries.....	20
5.4 Dynamic behaviour.....	20
5.5 Test signal output.....	20
5.6 24 h interruption in supply voltage .....	20
6 Complete meter.....	20
7 Interfaces between sub-assemblies .....	20
7.1 Definitions for pulse device interfaces.....	21
7.1.1 General.....	21
7.1.2 Electrical connection.....	21
7.1.3 Classification of pulse output devices .....	21
7.1.4 Timing and electrical parameters for pulse output devices (other than test signals).....	22
7.1.5 Classification of pulse input devices .....	22
7.1.6 Timing and electrical parameter for pulse input devices .....	23
7.1.7 Compatibility .....	23
8 Marking and security seals.....	24

<b>8.1</b>	<b>Marking</b> .....	<b>24</b>
<b>8.1.1</b>	<b>General</b> .....	<b>24</b>
<b>8.1.2</b>	<b>Temperature sensor pairs</b> .....	<b>24</b>
<b>8.1.3</b>	<b>Pockets</b> .....	<b>24</b>
<b>8.1.4</b>	<b>Flow sensor</b> .....	<b>24</b>
<b>8.1.5</b>	<b>Calculator</b> .....	<b>25</b>
<b>8.1.6</b>	<b>Complete meter</b> .....	<b>25</b>
<b>8.2</b>	<b>Sites for marking</b> .....	<b>26</b>
<b>8.3</b>	<b>Security seals</b> .....	<b>26</b>
<b>Annex A</b>	<b>(informative) Examples of temperature sensors</b> .....	<b>27</b>
<b>Annex B</b>	<b>(normative) Input and output test signals</b> .....	<b>36</b>
<b>Annex C</b>	<b>(informative) Low voltage Power Supply for heat meters and their sub-assemblies</b> .....	<b>39</b>
<b>C.1</b>	<b>Remote supply</b> .....	<b>39</b>
<b>C.1.1</b>	<b>Voltage (DC or AC)</b> .....	<b>39</b>
<b>C.1.2</b>	<b>Current available</b> .....	<b>39</b>
<b>C.1.3</b>	<b>Cabling requirements</b> .....	<b>39</b>
<b>C.2</b>	<b>Local external DC supply</b> .....	<b>39</b>
<b>C.2.1</b>	<b>Voltage</b> .....	<b>39</b>
<b>C.2.2</b>	<b>Other data</b> .....	<b>40</b>
<b>C.3</b>	<b>Power supply specifications</b> .....	<b>40</b>
<b>Annex ZA</b>	<b>(informative) Relationship between this European Standard and the Essential Requirements of EU Directive 2004/22/EC, MID</b> .....	<b>41</b>
<b>Bibliography</b>	.....	<b>42</b>

## **Foreword**

This document (EN 1434-2:2007) has been prepared by Technical Committee CEN/TC 176 “Heat meters”, the secretariat of which is held by DS.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by August 2007, and conflicting national standards shall be withdrawn at the latest by August 2007.

This document supersedes EN 1434-2:1997.

The other parts are

Part 1 - General requirements

Part 3 - Data exchange and interfaces

Part 4 - Pattern approval tests

Part 5 - Initial verification tests

Part 6 - Installation, commissioning, operational monitoring and maintenance

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

## 1 Scope

This European Standard specifies the constructional requirements and applies to heat meters, that is to instruments intended for measuring the heat which, in a heat-exchange circuit, is absorbed (cooling) or given up (heating) by a liquid called the heat-conveying liquid. The heat meter indicates the quantity of heat in legal units.

Electrical safety requirements are not covered by this European Standard.

Pressure safety requirements are not covered by this European Standard.

Surface mounted temperature sensors are not covered by this European Standard.

## 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1434-1:2007, *Heat meters — Part 1: General requirements*

prEN 1434-3, *Heat meters — Part 3: Data exchange and interfaces*

EN 60751:1995, *Industrial platinum resistance thermometer sensors (IEC 60751:1983 + A1:1986)*

EN 60947-5-6, *Low-voltage switchgear and controlgear — Part 5-6: Control circuit devices and switching elements — DC interface for proximity sensors and switching amplifiers (NAMUR) (IEC 60947-5- 6:1999)*

EN ISO 228-1, *Pipe threads where pressure tight joints are not made on the threads — Part 1: Dimensions, tolerances and designation (ISO 228-1:2000)*

ISO 4903, *Information technology — Data communication — 15-pole DTE/DCE interface connector and contact number assignments*

ISO 7005-1, *Metallic flanges — Part 1: Steel flanges*

ISO 7005-2, *Metallic flanges — Part 2: Cast iron flanges*

ISO 7005-3, *Metallic flanges — Part 3: Copper alloy and composite flanges*

## 3 Temperature sensors

### 3.1 General

The temperature sensor sub-assembly shall consist of platinum resistance temperature sensors selected as matched pairs.

Other types of temperature sensor pairs may be used, where the sub-assembly consists, inseparably, of temperature sensors and calculator.

The maximum admissible working pressure shall be declared by the supplier.

Where no dimensional tolerance is specified, the values shall be taken from Table 1.

**Table 1 — Tolerances**

Dimension mm	0,5 up to 3	over 3 up to 6	over 6 up to 30	over 30 up to 120	over 120 up to 400
Tolerance mm	± 0,2	± 0,3	± 1	± 1,5	± 2,5

## 3.2 Mechanical design

### 3.2.1 General

For pipe sizes up to and including DN 250, 3 different temperature sensor types are standardised:

direct mounted short probes - Type DS;

direct mounted long probes - Type DL;

pocket mounted long probes - Type PL.

Types PL and DL can be either head probes or have permanently connected signal leads. Type DS shall have permanently connected signal leads only.

### 3.2.2 Materials of temperature probe sheath and pocket

The temperature pocket and the protective sheath of direct mounted probes shall be of a material, that is adequately strong and resistant to corrosion and has the requisite thermal conductivity.

A suitable material has been shown to be EN 10088-3 - X6 Cr Ni Mo Ti 17 12 2

### 3.2.3 Dimensions of direct mounted short probes - Type DS

The dimensions shall be as given in Figure 1.

Further non-normative information is given in Annex A, Figure A.1.

The qualifying immersion depth shall be 20 mm – or less if so specified by the supplier.

### 3.2.4 Dimensions of direct mounted long probes - Type DL


The dimensions shall be as given in Figure 2.

Further information is given in Annex A, Figures A.2 and A.3.

The qualifying immersion depth shall be 50 % of the length B – or less if so specified by the supplier.



Dimensions in millimetres




**Key**

- 1 temperature sensing element
- 2 protective sheath
- 3 sealing ring

**Figure 1 — Temperature probes type DS**

Dimensions in millimetres



Key

G 1/2 B thread in accordance with EN ISO 228-1

A: < 30 mm or  $\leq$  50 mm for PT1000

Alternative lengths	
B	C head probe only
85	105
120	140
210	230

- 1 temperature sensing element
- 2 protective sheath
- 3 sealing face
- 4 outline of head probe
- 5 outline of permanently connected signal lead probe
- 6 inlet for signal cable –  $\varnothing \leq 9$  mm

Figure 2 — Temperature probes type DL (head or cable)

### **3.2.5 Dimensions of pocket mounted long probes - Type PL**

The dimensions shall be as given in Figure 3.


Further information is given in Annex A, Figures A.4 and A.5.

The qualifying immersion depth shall be 50 % of the length B for the shortest pocket specified – or less if so specified by the supplier.

### **3.2.6 Dimensions of temperature pocket**

The temperature pocket is designed for use with type PL temperature probes only. It is designed to be capable of being inserted through a pipe wall to which has been externally brazed or welded a boss (see Annex A, Figure A.6 a) and b) and in this respect only, it is interchangeable with a direct mounted long probe of corresponding insertion length. The dimensions shall be as given in Figure 4.

Dimensions in millimetres

**Key**

<sup>1)</sup> Corresponding to c11 in ISO 286-2, rounded to 2 decimals


A: < 30 mm or ≤ 50 mm for PT1000

Alternative lengths
B (head probe only)
105
140
230

- 1 temperature sensing element
- 2 outline of head probe
- 3 outline of permanently connected signal lead probe
- 4 inlet for signal cable –  $\varnothing \leq 9$  mm

**Figure 3 — temperature probes – Type PL (head or cable)**

Dimensions in millimetres

**Key**

1) Corresponding to H11 in ISO 286-2 rounded to 2 decimals

G 1/2 B thread in accordance with EN ISO 228-1

Alternative lengths	
C	D
85	$\leq 100$
120	$\leq 135$
210	$\leq 225$

- 1 sealing face
- 2 probe clamping screw with provision for security sealing

**Figure 4 — Temperature pocket**

### 3.2.7 Design of short probes with respect to installation

The sensor shall be mounted perpendicular to the flow and with the sensing element inserted to at least the centre of the pipe.

For internal pressures up to 16 bar, the sensor shall be designed to fit in a pipe fitting (see Annex A, Figure A.7).

### 3.2.8 Design of long probes with respect to installation


The sensor shall be mounted with the sensing element inserted to at least the centre of the pipe.

The sensor shall be designed to fit in the following types of installation, (for internal pressures up to PN 16):

- a) in a pipe DN 50 mounted with the tip pointing into the flow in a bend (see Annex A, Figure A.8 B), using welded-in boss (see Annex A, Figure A.6 b)).
- b) in a pipe DN 50 mounted at an angle  $45^\circ$  to the direction of the flow with the tip pointing into the flow (see Annex A, Figure A.8 C), using a welded in boss (see Annex A, Figure A.6 b)).
- c) in a pipe DN 65 to DN 250, mounted perpendicular to the flow (see Annex A, Figure A.8 D), using a welded-in boss (see Annex A, Figure A.6 a)).

### 3.3 Platinum temperature sensor

#### 3.3.1 Specialised definitions for 2 wire temperature probes



#### Key

$R_1$ temperature sensing element resistance	1 temperature sensing element
$R_2$ internal wire resistance	2 protective sheath
$R_3$ signal lead resistance	3 mounting thread
	4 signal leads

Figure 5 — Temperature probe with permanently connected signal leads




Figure 6 — Head sensor temperature probe

**Key** $R_1$  temperature sensing element resistance $R_2$  internal wire and terminals resistance

1 temperature sensing element

2 protective sheath

3 mounting thread

4 outline of head

**3.3.2 Resistance characteristics**

The calibration of temperature sensors shall be traceable to national temperature standards. The intermediate values of the heat meter temperature sensor shall be interpolated using the EN 60751 equation as follows:

$$R_1 = R_0 (1 + At + Bt^2)$$

where

$R_1$  is the resistance value at temperature  $t$  in  $\Omega$  (excluding cable resistance - see Figures 5 and 6);

$R_0$  is the resistance value at temperature  $0\text{ }^\circ\text{C}$  in  $\Omega$  (base value) (excluding cable resistance);

$A$  is  $3,908\ 3 \times 10^{-3}\text{ }^\circ\text{C}^{-1}$ ;

B is  $-5,775 \times 10^{-7} \text{ }^{\circ}\text{C}^{-2}$ .

NOTE It is assumed that the national temperature standards are established with reference to ITS-90 - The International Temperature Scale of 1990.

### **3.3.3 Signal leads**

For signal leads, leads with strands can be used, or in the case of head probes, solid wires. The lead ends shall be precisely trimmed, if strands are used (e.g. by lead end sleeves). Solder-coating of the lead ends to prevent splicing is not permissible.

A soldered joint to connect the temperature probe signal lead to the calculator is only permitted in the case of non-interchangeable temperature probes.

For screened cables for temperature sensors there shall be no connection between the screen and the protecting sheet.

### **3.3.4 Temperature sensors for the 2-wire method**

The length and cross sectional area of signal leads of paired resistance sensors of separable sub-assemblies shall be equal.

The length of the signal lead as supplied by the manufacturer shall not be changed.

The length shall be within the values given in Table 2.

**Table 2 — Maximum lengths of leads for Pt 100 temperature sensors**

Lead cross section mm <sup>2</sup>	Max. length for Pt 100 m
0,22	2,5
0,50	5,0
0,75	7,5
1,50	15,0

For sensors of higher resistances the limiting value can be extended proportionally.

NOTE The values given in Table 2 have been obtained in the following manner:

It is assumed, that the difference in temperature of the leads does not exceed one third of the temperature difference between flow and return pipes.

The maximum permissible length of lead for each lead cross section was then calculated, having decided that the error created may not be allowed to exceed 0,2 times the maximum permissible error of the temperature probe pair and using the knowledge of the different resistances created by the temperature differences between the flow and return leads.

The influence of the length of a signal lead can be neglected, if the total resistance of a lead for a Pt 100 temperature sensor does not exceed two times 0,2  $\Omega$ .

### **3.3.5 Temperature sensors for the 4-wire method**

If the cable length requirements in 3.3.4 cannot be fulfilled, the 4-wire method shall be used.

The connections shall be clearly identifiable so that they cannot be confused.



A cross-section of  $0,5 \text{ mm}^2$  is recommended for head sensors and a minimum cross-section of  $0,14 \text{ mm}^2$  for cable sensors.

### 3.3.6 Thermal response time

The supplier shall declare the temperature sensor response time  $\tau_{0,5}$  as defined in 4.3.3 of EN 60751:1995, using the test method in 4.3.3.3 of EN 60751:1995.

## 3.4 Other temperature sensors

Other types of temperature sensors are permissible, but shall be tested as part of the calculator.

# 4 Flow sensors

## 4.1 Maximum admissible working pressure, PS in bar

The maximum admissible working pressure shall be declared by the manufacturer.

## 4.2 Sizes and dimensions

The flow sensor is designated either by the thread size of the end connections or by the nominal diameter of the flange. For each flow sensor size there is a corresponding value of the permanent flow rate  $q_p$  and a set of lengths as given in Tables 3 and 4.

The values in Table 3 apply to the connecting screw and/or the flange and the overall lengths.

For sizes larger than DN 250 the flow sensor dimensions are not standardised.

Table 3 — Dimensions

$q_p$ m <sup>3</sup> /h	Preferred			Also acceptable			Also acceptable	
	Overall length mm	Threaded end connections	Flanged connections DN	Overall length mm	Threaded end connections	Flanged connections DN	Overall length mm	Threaded end connections
0,6	110	G 3/4 B	15	190	G 1 B	20	110 110 130	G 3/4 B G 3/4 B G 1 B
1,0	130	G 3/4 B	15	190	G 1 B	20		
1,5	165	G 3/4 B	15	190	G 1 B	20		
2,5	190	G 1 B	20					
3,5	260	G 1 1/4 B	25					
6,0	260	G 1 1/2 B	32	260	G 1 1/4 B	25		
10	300	G 2 B	40					
15	300		50	270		50		
25	300		65					
40	350		80	300		80		
60	350		100	360		100		
100	350		125					
150	500		150					
250	500		200					
400	600		250					

To achieve the necessary overall length adaptor pieces can be fitted.

The adjacent lengths larger or smaller than the preferred lengths may be adopted for  $q_p \geq 10$  m<sup>3</sup>/h

Tolerances on the overall length shall be:

up to 300 mm  $\begin{smallmatrix} 0 \\ -2 \end{smallmatrix}$  mm;

from 350 to 600 mm  $\begin{smallmatrix} 0 \\ -3 \end{smallmatrix}$  mm.

Threaded connection


Dimensions for the threaded end connections are specified in Table 4. Threads shall comply with EN ISO 228-1. Figure 7 outlines the dimensions a and b.

Flanged connection

Flanged end connections shall comply with ISO 7005-1, 7005-2 and 7005-3 (as appropriate) for a nominal pressure corresponding to that of the flow sensor.

**Table 4 — Threaded end connections**  
Range of size and minimum thread lengths in mm

Thread	a	b
G 3/4 B	10	12
G 1 B	12	14
G 1 1/4 B	12	16
G 1 1/2 B	13	18
G 2 B	13	20



**Figure 7 — Outline of the dimensions a and b in Table 4**

### 4.3 Test signal output

For test purposes, it is required that either high resolution pulses using an adaptor according to Annex B shall be provided, or data from a serial interface, as described in prEN 1434-3, using an adapter (if necessary) shall be employed. The discrimination of these test outputs shall be such, that in a test at  $q_i$  (defined in 5.3 of EN 1434-1:2007), the measurement error resulting from the number of pulses is not greater than 0,8 %,  $\langle AC_1 \rangle$  and the test period of 1 h for sizes  $q_p < 10 \text{ m}^3/\text{h}$  or 1,5 h for  $q_p \geq 10 \text{ m}^3/\text{h}$ , is not exceeded.  $\langle AC_1 \rangle$

The nominal relationship between the signal emitted and the quantity measured shall be declared by the supplier.

Output names used at pulse output connections are given in Annex B.

### 4.4 Adjusting device

The flow sensor may be fitted with an adjustment device making it possible to correct the relationship between the indicated and the true value.

## 5 Calculators

### 5.1 Mechanical dimensions for calculators for domestic use

The casing of calculators intended for wall mounting shall have maximum dimensions given in Figure 8.

If the casing is large enough, the centre distances for the mounting holes shall be as in Figure 8. If the casing is smaller, an adapter plate shall be available.




Figure 8 — Maximum dimensions

## 5.2 Terminals - specification and identification

### 5.2.1 General

The numbers specified shall be used for the inscriptions on the terminals provided. Terminals not required can be omitted. The screening of a screened cable may be connected to the terminal board for earthing purposes. The screening of a screened cable may be anchored to the terminal board to prevent damage of the cable by pulling, provided the cable used is suitable for this.

### 5.2.2 Terminals for signal leads

The terminals shall meet the following requirements:

- a) maximum cable cross-section  $1,5 \text{ mm}^2$ ;
- b) distance between terminals 5 mm;
- c) suitable for stranded wire;
- d) the contact resistance for a two-wire Pt 100 transition between the terminal and the wire shall be  $\leq 5 \text{ m}\Omega$ . The change in contact resistance with time shall be  $< 5 \text{ m}\Omega$ .

Table 5 — Numbering of terminals

Terminal no.	Signal descriptor	Signal identification
1	High temperature sensor/assigned to No. 5*	
2	High temperature sensor/assigned to No. 6 *	
3	Low temperature sensor/assigned to No. 7 *	
4	Low temperature sensor/assigned to No. 8 *	
5	High temperature sensor	
6	High temperature sensor	
7	Low temperature sensor	
8	Low temperature sensor	
9	Flow sensor, positive supply voltage output	
10	Flow sensor signal input	
11	Flow sensor reference input	
12	Test signals reference output	-U
13	High resolution energy test signal output	CH
14	Flow pulse test signal input	CI
15	High resolution volume test signal input	CT
16	Remote counting pulses energy output	CE
17	Remote counting pulses energy output, reference level	
18	Remote counting pulses volume output	CV
19	Remote counting pulses volume output, reference level	
20	CL 0 - interface with 4-wire	RX+/RTX+
21	CL 0 - interface with 4-wire	RX-/RTX-
22	CL 0 - interface with 4-wire	TX+
23	CL 0 - interface with 4-wire	TX-
24	Meter bus interface	
25	Meter bus interface	
* Used only with 4-wire method		

Rules about numbering of terminals:

- there may be more than one terminal, each of them having the same number, if they are electrically connected (e.g. connection of temperature sensor cable's shield);
- terminals and their numbers can be omitted, if corresponding signals are not present;
- for signals other than those described, terminal number 50 and upwards shall be used.

### 5.2.3 Terminals for connection to the mains supply

Two or, preferably, three terminals shall be provided, which shall be suitable for stranded wire up to a cross-section of 2,5 mm<sup>2</sup>. Cables with permanently fitted connections may also be used.

Table 6 — Numbering and marking of the mains terminals

Terminal No	Marking
26	earth symbol
27	N
28	L

If no polarity indication is needed, the "N" and "L" can be replaced by the standardized symbol for a mains connection.

### **5.3 Batteries**

If a heat meter has interchangeable batteries, they shall be replaceable without damaging verification markings. The life time of the batteries shall be declared by the supplier.

### **5.4 Dynamic behaviour**

The supplier shall declare how the temperature measurements and integration are related to the flow sensor signal and time.

### **5.5 Test signal output**

A high resolution energy signal is required for testing purposes. The resolution shall be sufficiently high so that at a test at the lower limit of temperature difference and/or flow rate, the additional error caused by the resolution of the energy signal can be shown to be insignificant. The nominal relationship between the high resolution signal and the energy reading shall be stated by the supplier.

The energy signal as specified above shall be available either directly at the calculator connection terminal or at the terminal of a testing adapter as stated in Annex B.

The test signal shall be either pulses with a defined value of pulses/energy increment or a data output, specially defined, or a display with correspondingly high resolution.

Pulse output names used at output connections are given in Annex B.

### **5.6 24 h interruption in supply voltage**

The calculator shall be able to handle interruptions in the supply voltage for periods of up to 24 h, without a change more than one digit in the energy display.

## **6 Complete meter**

The requirements given in Clauses 3 to 5 shall be applied where relevant.

A test output shall be provided, in which the resolution is high enough to ensure, that the reading error does not exceed 0,5 % for a test duration of 2 h.

The attachment of devices for sampling the test output shall have no effect on the accuracy of the heat meter.

In addition the indicating device may be provided with a high resolution scale for testing purposes, provided that the resolution requirements are met.

It is assumed that the reading error will not exceed half the smallest scale interval for each meter reading or, in the case of digital indicators, cannot exceed 0,99 of the least significant digit.

Pulse output names used at output connections are given in Annex B

## **7 Interfaces between sub-assemblies**

The type of signals between the calculator, the temperature sensors and the flow sensor shall be clearly defined by the supplier.

The definition shall include all relevant data, e.g. type of signal, voltage and current levels and limitations such as maximum and minimum frequency, duty cycles etc.

## **7.1 Definitions for pulse device interfaces**

### **7.1.1 General**

To define the compatibility between a unit with a pulse output and another unit with a pulse input, the following specification shall be used.

### **7.1.2 Electrical connection**

The electrical connection of a pulse device has two terminals. Both terminals shall be isolated from ground (e.g. pipes or casing) with an insulation resistance greater than 100 M $\Omega$  measured at 100 V DC under reference conditions.

The possible shielding connection shall be designed to the rules of the electromagnetic compatibility.

### **7.1.3 Classification of pulse output devices**

Class OA: electromechanical switch.

Typical examples of a class OA device is the Reed contact and the electronic switch.

The "ON" state is defined by the closed switch, the "OFF" state by the open switch.

A characteristic feature of the electromechanical switch is bouncing of the mechanical contacts.

Class OB: passive electronic current sink with slow pulses; high current.

Typical example for a passive electronic current sink class OB is the "open collector" with a Darlington transistor. Class OB devices replace the typical models of class OA devices by an electronic solid state solution. These devices do not bounce and need an auxiliary power supply and electronic control signal to switch the current source "ON" and "OFF".

Class OC: passive electronic current sink with slow pulses; low current.

A typical example of a passive electronic current sink class OC is also the "open collector" or "open drain" device. These devices do not bounce and need an auxiliary power supply and electronic control signal to switch the current source "ON" and "OFF". This device has lower voltage drop than Class OB.

Class OD: passive electronic current sink with fast pulses. low current

Class OD devices differ from class OC devices by a shorter pulse length.

Class OE: passive electronic current sink with fast pulses; higher current.

The current sink shall be according to EN 60947-5-6 (Namur). It differs from class OD by higher level of current and voltage. It allows to monitor the connecting cable on short and break.

## 7.1.4 Timing and electrical parameters for pulse output devices (other than test signals)

Table 7 — Timing and electrical parameters

Parameter	Class OA	Class OB	Class OC	Class OD	Class OE
Example	Reed or electronic switch	(Darlington) open collector	Open collector	Open collector or active	
Polarity reversal	Possible	Not possible	Not possible	Not possible	Not possible
Pulse length	$\geq 100$ ms	$\geq 30$ ms	$\geq 100$ ms	$\geq 0,1$ ms	$\geq 0,04$ ms
Pulse pause	$\geq 100$ ms	$\geq 100$ ms	$\geq 100$ ms	$\geq 0,1$ ms	$\geq 0,04$ ms
Bounce time	$\leq 1$ ms	--	--	--	-
Max. input voltage	30 V	30 V	6 V	6 V	12,5 V
Max. input current	27 mA	27 mA	0,1 mA	0,1 mA	17 mA
"ON" Condition	$U \leq 2,0$ V at 27 mA	$U \leq 2,0$ V at 27 mA	$U \leq 0,3$ V at 0,1 mA	$U \leq 0,3$ V at 0,1 mA	$I \geq 2,2$ mA
"OFF" Condition	$R \geq 6$ M $\Omega$	$R \geq 6$ M $\Omega$	$R \geq 6$ M $\Omega$	$R \geq 6$ M $\Omega$	$I \leq 1,0$ mA

## 7.1.5 Classification of pulse input devices

Class IA:

In a typical example, the actuating coil drives an electromechanical relay or an electromechanical counter - In combination with a fixed voltage source (specified DC voltage: 3 V, 12 V and 24 V), these devices work with class OA and OB pulse output devices.

Class IB:

A typical example is a micro controller CMOS input with a low pass filter for protection against and suppression of bouncing parts of the pulse signal.

A pull-up resistor to stabilize the CMOS input is used as current source for class OC pulse output devices.

Class IC:

Class IC devices are similar to Class IB devices, but the time constant of the low-pass filter is designed to be shorter. IC input devices cannot work with output devices that exhibit bouncing.

Class ID:

The input device shall be according to EN 60947-5-6 (Namur). Similar to class IB with higher levels of current and voltage. The switching thresholds are defined as current levels.



The optional supervision of input signal for short or open circuit shall be disabled as default.

Class IE:

The input device shall be according to EN 60947-5-6 (Namur). Similar to class ID but for faster signals. IE input devices cannot work with output devices that exhibit bouncing.

The optional supervision of input signal for short or open circuit shall be disabled as default.

#### 7.1.6 Timing and electrical parameter for pulse input devices

**Table 8 — Timing and electrical parameters**

Parameter	Class IA	Class IB	Class IC	Class ID	Class IE
Voltage supply	$\leq 30 \text{ V}$	$\leq 6 \text{ V}$	$\leq 6 \text{ V}$	7 V to 9 V	7 V to 9 V
Source current	$\leq 27 \text{ mA}$	$\leq 0,1 \text{ mA}$	$\leq 0,1 \text{ mA}$	7 mA to 16 mA	7 mA to 16 mA
High level input threshold	$U \geq 8 \text{ V}$	$U \geq 2 \text{ V}$	$U \geq 2 \text{ V}$	$I \leq 1,2 \text{ mA}$	$I \leq 1,2 \text{ mA}$
Low level input threshold	$U \leq 3 \text{ V}$	$U \leq 0,5 \text{ V}$	$U \leq 0,5 \text{ V}$	$I \geq 2,1 \text{ mA}$	$I \geq 2,1 \text{ mA}$
Pull-up resistor	--	50 k $\Omega$ to 2 M $\Omega$	50 k $\Omega$ to 2 M $\Omega$	562 $\Omega$ to 1 k $\Omega$	562 $\Omega$ to 1 k $\Omega$
Pulse length	$\geq 30 \text{ ms}$	$\geq 100 \text{ ms}$	$\geq 0,1 \text{ ms}$	$\geq 2 \text{ ms}$	$\geq 0,04 \text{ ms}$
Pulse frequency	$\leq 5 \text{ Hz}$	$\leq 5 \text{ Hz}$	$\leq 5 \text{ kHz}$	$\leq 200 \text{ Hz}$	$\leq 12,5 \text{ kHz}$

#### 7.1.7 Compatibility

Table 9 shows how the different input and output devices can be used together.


**Table 9 — Compatibility**

Input Devices $\Rightarrow$	Class IA	Class IB	Class IC	Class ID	Class IE
Output Devices $\Downarrow$					
Class OA	✓ yes	✓ yes	✗ no	✓ yes	✗ no
Class OB	✓ yes	✗ no	✗ no	✓ yes	✓ yes
Class OC	✗ no	✓ yes	✓ yes	✗ no	✗ no
Class OD	✗ no	✗ no	✓ yes	✗ no	✗ no
Class OE	✗ no	✗ no	✗ no	✗ no	✓ yes

## 8 Marking and security seals

### 8.1 Marking

#### 8.1.1 General

If complete information about measuring range and other limitations cannot be clearly printed on the marking plate, a warning sign  be placed immediately after the incomplete information.

#### 8.1.2 Temperature sensor pairs

The following information shall appear in legible and indelible characters on the head or a separate security sealed plate:

- a) name of the supplier, or his trade mark;
- b) type - inclusive Pt-designation (e.g. Pt 100), year of manufacture and serial number;
- c) limits of the temperature range ( $\vartheta_{\min}$  and  $\vartheta_{\max}$ ). An additional set of limits for the cooling range may be specified for heating/cooling meters;
- d) limits of temperature differences ( $\Delta\vartheta_{\min}$  and  $\Delta\vartheta_{\max}$ ). An additional set of limits for the cooling range may be specified for heating/cooling meters;
- e) maximum admissible working pressure;
- d) if needed, identification of flow and return temperature sensors.

#### 8.1.3 Pockets

The pockets following this European Standard shall be marked with "EN 1434".

#### 8.1.4 Flow sensor

The following information shall appear in legible and indelible characters on the sensor or a security sealed plate:

- a) name of the supplier, or his trade mark;
- b) type, year of manufacture, serial number;
- c) meter factor;
- d) limits of temperature ( $\vartheta_{\min}$  and  $\vartheta_{\max}$ ).  
An additional set of limits for the cooling range may be specified for heating/cooling meters;
- e) limits of flow-rate ( $q_i$ ,  $q_p$  and  $q_s$ ). Different sets of  $q_i$  and  $q_s$  may be given depending on mounting orientation and type of liquid;
- f) one or two arrows to indicate the direction of the flow;
- g) maximum admissible working pressure, PS in bar;
- h) nominal pressure, PN;

- i) accuracy class; may differ depending on mounting orientation and on type of liquid;
- j) environmental class;
- k) heat conveying liquid if other than water;
- l) voltage level for external power supply.

#### 8.1.5 Calculator

The following information shall appear in legible and indelible characters on the casing or a security sealed plate:

- a) name of the supplier, or his trade mark;
- b) type, year of manufacture, serial number;
- c) type of temperature sensors (e.g. Pt 100, Pt 500);
- d) limits of the temperature ( $\theta_{\min}$  and  $\theta_{\max}$ ). An additional set of limits for the cooling range may be specified for heating/cooling meters;
- e) Limits of temperature differences ( $\Delta\theta_{\min}$  and  $\Delta\theta_{\max}$ ). An additional set of limits for the cooling range may be specified for heating/cooling meters;
- f) meter factor for the flow sensor;
- g) flow sensor to be operated at the flow or return temperature;
- h) environmental class;
- i) heat conveying liquid if other than water;
- j) voltage level for external power supply.

#### 8.1.6 Complete meter

The following information shall appear in legible and indelible characters:

- a) name of the supplier, or his trade mark;
- b) type, year of manufacture and serial number;
- c) limits of the temperature ( $\theta_{\min}$  and  $\theta_{\max}$ ). An additional set of limits for the cooling range may be specified for heating/cooling meters;
- d) limits of temperature differences ( $\Delta\theta_{\min}$  and  $\Delta\theta_{\max}$ ). An additional set of limits for the cooling range may be specified for heating/cooling meters;
- e) limiting values of the flow-rate ( $q_i$ ,  $q_p$  and  $q_s$ ). Different sets of  $q_i$  and  $q_s$  may be given depending on mounting orientation and type of liquid;
- f) meter to be installed in the flow or return;
- g) one or more arrows to indicate the direction of the flow;
- h) maximum admissible working pressure, PS in bar;

- i) nominal pressure, PN;
- j) accuracy class; may differ depending on mounting orientation and on type of liquid;
- k) environmental class;
- l) heat conveying liquid if other than water;
- m) voltage level for external power supply.

## **8.2 Sites for marking**

Sites shall be provided for marks (e.g. legal status marks) to be sited on that part of the heat meter indicating the quantity of heat for a complete meter or on each sub-assembly for combined meters.

All parts of the heat meter that might be separated after calibration and testing shall have sites for placing an identity mark.

The sites for these marks shall be situated so that the marks are clearly visible when attached.

## **8.3 Security seals**

Sites for security seals shall be provided so that the provisions of 6.4 of EN 1434-1:2007 are met.

## **Annex A** (informative)

### **Examples of temperature sensors**

This annex deals with examples of temperature sensor design and installation.

Figure A.1 Temperature probe - direct mounted - short - Type DS-cable

Figure A.2 Temperature probe - direct mounted - long - Type DL-head

Figure A.3 Temperature probe - direct mounted - long - Type DL-cable

Figure A.4 Temperature probe - pocket mounted - Type PL-head

Figure A.5 Temperature probe - pocket mounted - Type PL-cable


Figure A.6 Temperature probe bosses and sealing ring

Figure A.7 Threaded pipe fitting G1/2B, G3/4B and G1B sizes

Figure A.8 Installation recommendations


NOTE 1 In the figures in this annex, all dimensions are given in millimetres.

NOTE 2 All pipe threads (e.g. G1/2B) are meant to be in accordance with EN ISO 228-1.



<b>Key</b>	3 identification plate (example)	6 protective sheath
1 connecting lead	4 provision for locking wire	7 temperature sensing element
2 provision for security sealing (example)	5 sealing ring – material: e.g. copper or PTFE	

**Figure A.1 — Temperature probe – direct mounted – short – type DS-cable**

**Key**<sup>1)</sup> preferred

A installed length

1 outline of head

2 signal cable inlet

3 provision for locking wire


4 provision for security sealing

5 sealing face

6 protective sheath

7 temperature sensing element

**Figure A.2 — Temperature probe – direct mounted – long – Type DL-head**




<b>Key</b>	1 connecting lead	5 sealing face
	2 provision for security sealing (example)	6 protective sheath
	3 identification plate (example)	7 temperature sensing element
	4 provision for locking wire	

<sup>1)</sup> preferred

A installed length


Figure A.3 — Temperature probe – direct mounted – Type DL-cable



**Key**

- |   |                                  |                               |
|---|----------------------------------|-------------------------------|
| 1) tolerance on the diameter applies for this length          | 1 outline of head                | 4 protective sheath           |
| 2) corresponding to c11 in EN ISO 286-2 rounded to 2 decimals | 2 inlet for signal cable         | 5 temperature sensing element |
|   | 3 provision for security sealing |                               |

**Figure A.4 — Temperature probe – pocket mounted – Type PL-head**



- Key**
- |  |   |                   |  |                                  |                     |                               |
|--|---|-------------------|--|----------------------------------|---------------------|-------------------------------|
| 1) tolerance on the diameter applies for this length | 2) corresponding to c11 in EN ISO 286-2 rounded to 2 decimals | 1 connecting lead | 2 provision for security sealing (example) | 3 identification plate (example) | 4 protective sheath | 5 temperature sensing element |
|--|---|-------------------|--|----------------------------------|---------------------|-------------------------------|

**Figure A.5 — Temperature probe – pocket mounted – Type PL-cable**




FIG. A.6a




FIG. A.6b

### Key


Fig. A.6a For use with perpendicular type probe installation – see Figure A.8 D

1 recess for sealing ring

2 copper sealing ring for use with both types of boss

Fig. A.6b All other dimensions as in Fig. A.6a. For use with angled probe or probe in a bend installation – see Figures A.8 B and A.8 C

**Figure A.6 — Temperature boss and sealing ring**



Key

Threaded connection size A	Tapping bore size B
G1/2B	18,5 mm
G3/4B	24 mm
G1B	30,5 mm

NOTE Tolerance on machined dimensions = ± 0,5 mm.

Pipe fittings for use with probe Type DS: see Figure A.8 A

1 provision for security sealing

Figure A.7 — Threaded pipe fitting G1/2B, G3/4b and G1B sizes





TYPE OF PROBE INSTALLATION	PIPE SIZE	INSTALLATION RECOMMENDATIONS	KEY
A  IN THREADED PIPE FITTING	DN 15 DN 20 DN 25		1 For probe type DS only 2 Temperature sensing element inserted to axis of fitting or beyond 3 Probe axis perpendicular to axis of fitting and in the same plane 4 Pipe fitting, see Figure A.7
B  IN BEND	$\leq$ DN 50		1 Either probe type DL or temperature pocket plus type PL 2 Boss, see Figure A.6b 3 Flow 4 Probe axis coincident with pipe axis
C  ANGLED PROBE	$\leq$ DN 50		1 Either probe type DL or temperature pocket plus type PL 2 Boss, see Figure A.6b 3 Flow 4 Temperature sensing element inserted to pipe axis or beyond
D  PERPENDI-CULAR PROBE	DN 65 TO DN 250		1 Either probe type DL or temperature pocket plus type PL 2 Boss, see Figure A.6a 3 Temperature sensing element inserted to pipe axis or beyond 4 Probe axis perpendicular to pipe axis and in the same plane

Figure A.8 — Installation recommendations


**Annex B**  
(normative)

**Input and output test signals**

This annex deals with specifications for the input and output signals of the EUT - see EN 1434-1 - where the EUT is to be tested by high resolution pulses as described in 4.3, 5.5 and Clause 6.

For this method of testing the flow sensor and/or calculator shall have the input and output signals shown in Table B.1, by means of an additional assembly (adaptor) if necessary, offered by the supplier, with input and output signals according to Table B.2.

The input and output signals provided shall allow rapid and precise testing without influencing the meter performance when connected to a suitable test device with input and output signals according to Table B.2, where the signals are interpreted with the signal UR - see Table B.1 - as reference.



**Figure B.1 — Signal flow diagram**

Table B.1 — Input and output test signals for the EUT

Signal ID	Signal description		Function
<u>+U</u>	Input	Positive supply voltage	Power for adapter
<u>-U</u>	Input	Negative supply voltage	Reference for all signals
<u>UR</u>	Output	Reference level	EUT logic supply voltage level
Referring to flow-sensor			
<u>FH</u>	Output	High resolution volume pulses	Test output of flow sensor
<u>FO</u>	Output	Volume output signal	E.g. from contact mechanism
Referring to calculator			
<u>CH</u>	Output	High resolution energy pulses	Test output from calculator
CE	Output	Energy counter pulses	E.g. from energy counter
CV	Output	Volume counter pulses	E.g. from volume counter
CI*	Input	Trigger signal for the calculation cycle	Simulated pulses, from contact mechanism
CT*	Input	Test input for volume proportional pulses	Simulated pulses, e.g. FH from flow sensor
CS	Output	Status signal	Active = measurement running
<p>___ Underlined signals are compulsory</p> <p>*) Only one of the signals CI and CT shall be available</p>			

Table B.2 — Electrical and mechanical specifications for standardized test device

Signal ID	Adaptor contact no.	Electrical specification	Remarks
+U	7 + 8	8 V $\pm$ 0,5 V - Load max. 125 mA	Power supply for adapter
-U	1 + 2		
UR	6	1 V < UR < 12 V - Load max 0,1 mA	
FH	3	$f \leq 10$ kHz      TH $\geq 50$ $\mu$ s	f: frequency in Hertz  TH: time at high level in seconds
FO	4	$f \leq 5$ Hz      TH $\geq 1$ ms	
CH	15	$f \leq 2$ MHz      TH $\geq 200$ ns	
CE	11	TH $\geq 30$ ms	
CV	12	TH $\geq 30$ ms	
CI	13	$f \leq 1$ Hz      TH/TL = $1 \pm 0,1$	TL: time at low level in seconds
CT	14	$f \leq 10$ kHz      TH/TL = $1 \pm 0,1$	
CS	10	$f \leq 5$ Hz      TH $\geq 1$ ms	

All signals shall be CMOS with levels higher than 0,6 UR interpreted as logical 1 and lower than 0,4 UR as logical 0.

All inputs on the test device shall have an impedance of 100 k $\Omega$  or higher.

All outputs on the test device shall be able to be loaded with 10 k $\Omega$ .

Connector from adapter to test device 15 pin Sub-D connector shall be in accordance with ISO 4903.



## **Annex C** (informative)

### **Low voltage Power Supply for heat meters and their sub-assemblies**

#### **C.1 Remote supply**

##### **C.1.1 Voltage (DC or AC)**

Recommended nominal levels 24 V

Tolerance DC: 18 V to 41 V

If the remote supply lines are also used for data transmission (e.g. M-Bus, see prEN 1434-3) these values shall be maintained during any data transmission.

Tolerance AC:  $\pm 30\%$

##### **C.1.2 Current available**

Peak value to be specified by the supplier

Long term mean value to be specified by the supplier

Total available energy to be specified by the supplier

##### **C.1.3 Cabling requirements**

Max. cable length >10 m - restricted only by voltage drop

Shielded cable a possible requirement to be specified by the supplier

Twisted cable a possible requirement to be specified by the supplier

#### **C.2 Local external DC supply**

##### **C.2.1 Voltage**

Recommended nominal levels 6 V, 3,6 V, 3 V

### C.2.2 Other data

**Table C.1 — Standardized levels for external powering**

Nominal voltage	6 V	3,6 V	3 V
Max. average current	100 mA	10/20/50/100/200 µA	10/20/50/100/200 µA
Tolerance at average current	5,4 V to 6,6 V	3,4 V to 3,8 V	2,8 V to 3,3 V
Peak current	100 mA	10 mA	5 mA
Min. voltage at peak current	5,4 V	3,2 V	2,7 V

### C.3 Power supply specifications

The supplier should make available data sheets containing at least the following information:

- supplier;
- type identification;
- external or remote power supply;
- nominal voltage level;
- available current (peak and long term mean value);
- total available energy (if battery);
- cabling requirement (maximum cable length and possible requirement for shielded or twisted cable).

**Annex ZA**  
(informative)

**Relationship between this European Standard and the Essential Requirements of  
EU Directive 2004/22/EC, MID**

This European Standard has been prepared under a mandate given to CEN by the European Commission to provide a means of conforming to Essential Requirements of the New Approach Directive 2004/22/EC on measuring instruments.

Once this standard is cited in the Official Journal of the European Communities under that Directive and has been implemented as a national standard in at least one Member State, compliance with all the normative clauses in Parts 1, 2, 4 and 5 of this standard confers, within the limits of the scope of this standard, a presumption of conformity with the relevant Essential Requirements of that Directive and associated EFTA regulations.

**WARNING —** Other requirements and other EU Directives may be applicable to the product(s) falling within the scope of this standard.

NOTE      A corresponding annex is included in EN 1434-1, EN 1434-4 and EN 1434-5.

## Bibliography

- [1] EN 10088-3, *Stainless steels — Part 3: Technical delivery conditions for semi-finished products, bars, rods, wire, sections and bright products of corrosion resisting steels for general purposes*
- [2] ISO 286-2, *ISO system of limits and fits — Part 2: Tables of standard tolerance grades and limit deviations for holes and shafts*



---

## BSI — British Standards Institution

BSI is the independent national body responsible for preparing British Standards. It presents the UK view on standards in Europe and at the international level. It is incorporated by Royal Charter.

### Revisions

British Standards are updated by amendment or revision. Users of British Standards should make sure that they possess the latest amendments or editions.

It is the constant aim of BSI to improve the quality of our products and services. We would be grateful if anyone finding an inaccuracy or ambiguity while using this British Standard would inform the Secretary of the technical committee responsible, the identity of which can be found on the inside front cover.  
Tel: +44 (0)20 8996 9000. Fax: +44 (0)20 8996 7400.

BSI offers members an individual updating service called PLUS which ensures that subscribers automatically receive the latest editions of standards.

### Buying standards

Orders for all BSI, international and foreign standards publications should be addressed to Customer Services. Tel: +44 (0)20 8996 9001.  
Fax: +44 (0)20 8996 7001. Email: [orders@bsi-global.com](mailto:orders@bsi-global.com). Standards are also available from the BSI website at <http://www.bsi-global.com>.

In response to orders for international standards, it is BSI policy to supply the BSI implementation of those that have been published as British Standards, unless otherwise requested.

### Information on standards

BSI provides a wide range of information on national, European and international standards through its Library and its Technical Help to Exporters Service. Various BSI electronic information services are also available which give details on all its products and services. Contact the Information Centre.  
Tel: +44 (0)20 8996 7111. Fax: +44 (0)20 8996 7048. Email: [info@bsi-global.com](mailto:info@bsi-global.com).

Subscribing members of BSI are kept up to date with standards developments and receive substantial discounts on the purchase price of standards. For details of these and other benefits contact Membership Administration.  
Tel: +44 (0)20 8996 7002. Fax: +44 (0)20 8996 7001.  
Email: [membership@bsi-global.com](mailto:membership@bsi-global.com).

Information regarding online access to British Standards via British Standards Online can be found at <http://www.bsi-global.com/bsonline>.

Further information about BSI is available on the BSI website at <http://www.bsi-global.com>.

### Copyright

Copyright subsists in all BSI publications. BSI also holds the copyright, in the UK, of the publications of the international standardization bodies. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI.

This does not preclude the free use, in the course of implementing the standard, of necessary details such as symbols, and size, type or grade designations. If these details are to be used for any other purpose than implementation then the prior written permission of BSI must be obtained.

Details and advice can be obtained from the Copyright & Licensing Manager.  
Tel: +44 (0)20 8996 7070. Fax: +44 (0)20 8996 7553.  
Email: [copyright@bsi-global.com](mailto:copyright@bsi-global.com).