

SolarMind Fix-First Work Order

INV 01.07.047

Recent annual technical loss	EUR 863/yr
Lifetime avoidable loss (M4)	EUR 7,411
Degradation trend	-1.836%/yr
Curtailement loss (separate)	EUR 299
Evidence confidence	HIGH

Likely cause pattern

Strangausfall

Fault evidence

0A010A: Erkennung von Netzunterspannung (ENS,Leistungsteil) (134.7 h)

Ticket evidence

Strangausfall

Recommended action

Inspect inverter and DC strings

Traceability

v fix first; revenue loss; degradation rates; fault events; tickets recent

Historical evidence association only. Curtailment is excluded from Fix-First loss. All figures are generated from validated DuckDB tables.