

Equipment Datasheet - T-101

Document No.	DS-T101-001	Revision	01
System	Solution Preparation Tank T-101	Status	Approved - Training
Project	Otrivin Nasal Spray Facility - Synthetic Case	Purpose	RAG/C&Q Training

Training disclaimer: This is a fictional, simplified document set created solely for education. It does not describe or reproduce the actual manufacturing process, specifications, or controlled records for Otrivin.

1. Equipment data

Vendor design data for the synthetic training vessel.

Design Data

Parameter	Specified value
Equipment tag	T-101
Nominal working volume	1,000 L
Total vessel volume	1,200 L
Product-contact material	316L stainless steel
Internal surface finish	Ra <= 0.8 µm
Agitator range	50-300 rpm
Design temperature	5-60 °C
Normal process temperature	15-30 °C
Drainage	Bottom outlet, sloped to drain
CIP	Fixed spray device; automated CIP sequence