

Simplified P&ID; / Process & Instrument Diagram - T-101

Document No.	PID-T101-001	Revision	01
System	Solution Preparation Tank T-101	Status	Approved - Training
Project	Otrivin Nasal Spray Facility - Synthetic Case	Purpose	RAG/C&Q Training

Training disclaimer: This is a fictional, simplified document set created solely for education. It does not describe or reproduce the actual manufacturing process, specifications, or controlled records for Otrivin.

1. Diagram

PW-101 -> XV-101 -> T-101. T-101 includes AG-101, TT-101, LT-101 and high-level alarm LAH-101. CIP supply connects through XV-102 to spray device SP-101. Product leaves through bottom outlet XV-104 to transfer pump P-101.

2. Instrument tags

- TT-101: product temperature
- LT-101: continuous level
- LAH-101: high-level alarm at 90%
- AG-101: variable-speed agitator
- XV-104: product outlet valve

3. Design note

The drawing identifies T-101 and connected instruments but does not itself constitute qualification evidence.