

Functional Specification - T-101 Controls

Document No.	FS-T101-001	Revision	01
System	Solution Preparation Tank T-101	Status	Approved - Training
Project	Otrivin Nasal Spray Facility - Synthetic Case	Purpose	RAG/C&Q Training

Training disclaimer: This is a fictional, simplified document set created solely for education. It does not describe or reproduce the actual manufacturing process, specifications, or controlled records for Otrivin.

1. Mixing control

The operator selects an approved recipe. The PLC commands AG-101 to the recipe speed setpoint within the allowable 50-300 rpm range.

2. Temperature monitoring

TT-101 is displayed continuously on the HMI. The intended measurement accuracy is +/-0.5 °C.

3. Level and alarm

LT-101 provides continuous level indication. LAH-101 activates when level reaches 90%.

4. Electronic records

Recipe parameter changes are intended to be attributable to an authenticated user and recorded in the system audit trail.

5. Emergency stop

Local E-stop ES-101 removes the run command to AG-101.