

Instrument List - T-101

Document No.	IL-T101-001	Revision	01
System	Solution Preparation Tank T-101	Status	Approved - Training
Project	Otrivin Nasal Spray Facility - Synthetic Case	Purpose	RAG/C&Q Training

Training disclaimer: This is a fictional, simplified document set created solely for education. It does not describe or reproduce the actual manufacturing process, specifications, or controlled records for Otrivin.

1. Scope

Critical and major instruments associated with T-101.

Instrument Register

Tag	Service	Range	Accuracy	Critical?
TT-101	Product temperature	0-60 °C	+/-0.5 °C	Yes
LT-101	Tank level	0-100%	+/-1.0% FS	Yes
ST-101	Agitator speed	0-350 rpm	+/-2 rpm	Yes
PT-101	CIP supply pressure	0-6 bar	+/-0.05 bar	No