

Valve List - T-101

Document No.	VL-T101-001	Revision	01
System	Solution Preparation Tank T-101	Status	Approved - Training
Project	Otrivin Nasal Spray Facility - Synthetic Case	Purpose	RAG/C&Q Training

Training disclaimer: This is a fictional, simplified document set created solely for education. It does not describe or reproduce the actual manufacturing process, specifications, or controlled records for Otrivin.

1. Scope

Process and CIP valves inside the qualification boundary.

Valve Register

Tag	Service	Type	Material	Fail position
XV-101	Purified water inlet	Diaphragm	316L	Closed
XV-102	CIP supply	Diaphragm	316L	Closed
XV-103	Vent	Diaphragm	316L	Open
XV-104	Product outlet	Diaphragm	316L	Closed