

PLC I/O List - T-101

Document No.	IO-T101-001	Revision	01
System	Solution Preparation Tank T-101	Status	Approved - Training
Project	Otrivin Nasal Spray Facility - Synthetic Case	Purpose	RAG/C&Q Training

Training disclaimer: This is a fictional, simplified document set created solely for education. It does not describe or reproduce the actual manufacturing process, specifications, or controlled records for Otrivin.

1. Scope

Simplified PLC I/O relevant to C&Q.;

I/O Register

Tag	Signal	Type	PLC channel
TT-101	Temperature PV	AI	AI-101
LT-101	Level PV	AI	AI-102
ST-101	Agitator speed feedback	AI	AI-103
LAH-101	High level alarm	DI	DI-111
AG-101	Agitator run command	DO	DO-121
ES-101	Emergency stop healthy	DI	DI-112