

Factory Acceptance Test Protocol - T-101

Document No.	FAT-T101-001	Revision	01
System	Solution Preparation Tank T-101	Status	Approved - Training
Project	Otrivin Nasal Spray Facility - Synthetic Case	Purpose	RAG/C&Q Training

Training disclaimer: This is a fictional, simplified document set created solely for education. It does not describe or reproduce the actual manufacturing process, specifications, or controlled records for Otrivin.

1. Objective

Verify selected mechanical and control functions before shipment.

Planned FAT Tests

Test	Acceptance criterion	URS link
FAT-01	Nameplate identifies T-101	URS-015
FAT-02	Vendor records show 1,000 L working volume	URS-001
FAT-03	Material certificates identify 316L product contact surfaces	URS-002
FAT-04	Surface-finish certificate states Ra <= 0.8 µm	URS-003
FAT-05	Agitator runs at 100 rpm and 200 rpm	URS-004
FAT-06	High-level alarm activates at simulated 90%	URS-008
FAT-07	Emergency stop removes agitator run command	URS-013