

Factory Acceptance Test Report - T-101

Document No.	FATR-T101-001	Revision	01
System	Solution Preparation Tank T-101	Status	Approved - Training
Project	Otrivin Nasal Spray Facility - Synthetic Case	Purpose	RAG/C&Q Training

Training disclaimer: This is a fictional, simplified document set created solely for education. It does not describe or reproduce the actual manufacturing process, specifications, or controlled records for Otrivin.

1. Summary

All planned FAT tests were executed. One observation was recorded: the agitator was demonstrated at 100 and 200 rpm only; minimum and maximum operating limits were not challenged at FAT.

Results

Test	Result	Evidence
FAT-01	Pass	Nameplate photo FAT-E01
FAT-02	Pass	Vendor volume calculation FAT-E02
FAT-03	Pass	Material cert MTR-316L-77
FAT-04	Pass	Finish cert SF-088
FAT-05	Pass with observation	100 and 200 rpm demonstrated
FAT-06	Pass	Alarm simulation record
FAT-07	Pass	E-stop functional check