

Calibration Certificate Package - T-101

Document No.	CAL-T101-001	Revision	01
System	Solution Preparation Tank T-101	Status	Approved - Training
Project	Otrivin Nasal Spray Facility - Synthetic Case	Purpose	RAG/C&Q Training

Training disclaimer: This is a fictional, simplified document set created solely for education. It does not describe or reproduce the actual manufacturing process, specifications, or controlled records for Otrivin.

1. Summary

Synthetic calibration records for critical T-101 instruments.

Calibration Status

Tag	Calibration date	Due date	Result	As-found
TT-101	2026-07-01	2027-07-01	Pass	Within +/-0.3 °C
LT-101	2025-07-15	2026-07-15	EXPIRED	Within +/-0.8% FS
ST-101	2026-07-03	2027-07-03	Pass	Within +/-1 rpm