

Operational Qualification Protocol - T-101

Document No.	OQ-T101-001	Revision	01
System	Solution Preparation Tank T-101	Status	Approved - Training
Project	Otrivin Nasal Spray Facility - Synthetic Case	Purpose	RAG/C&Q Training

Training disclaimer: This is a fictional, simplified document set created solely for education. It does not describe or reproduce the actual manufacturing process, specifications, or controlled records for Otrivin.

1. Objective

Challenge key operating functions of T-101.

OQ Tests

Test	Challenge	Acceptance criterion	URS link
OQ-01	Agitator at 50, 150, 300 rpm	Actual speed within +/-5 rpm	URS-004
OQ-02	Temperature indication at 15, 22.5, 30 °C	Indication within +/-0.5 °C	URS-005/006
OQ-03	Level indication at 10, 50, 90%	Indication within +/-2% FS	URS-007
OQ-04	High-level alarm	Alarm activates at 90% +/-2%	URS-008
OQ-05	Emergency stop	Agitator stops on E-stop	URS-013
OQ-06	Recipe control	Recipe steps/setpoints execute as configured	URS-011
OQ-07	CIP sequence	Automated CIP sequence completes without fault	URS-010