



INSPECTION VERIFICATION FORM

Property Address: (Subject Property Address Here, prints black)

The inspector verifies that the Inspection of the subject property listed above has been completed and complies with ICC Residential Building Code and FHA/HUD Minimum Property Standards. Additional, items listed below, have been verified in compliance and indicated by a checked box.

- ☐ Physical address numbers are visible and installed on the front of the home
- ☐ Sod, landscaping, and irrigation are complete
- ☐ All appliances have been installed
- ☐ All utilities (water, electricity, gas) are turned on and function at the time of the inspection.
- ☐ The property has been completed in accordance with all applicable building codes and standards.
- ☐ For two-story homes: Window limiters are installed on all second-floor windows where windowsills are less than 24 inches from the finished floor. All bedroom windows are accessible and open, close and lock as required.
- ☐ Spring hinges are installed on all garage service doors
- ☐ Whole House Surge protector, all required GFCI & AFCI protection is installed and present
- ☐ Property complies with all safety requirements.
- ☐ Drainage appears to be correct without testing or equipment to measure

Verified by Inspector # 0000 Inspected on: 00/00/0000

Inspector: (Name populates from form)