


MONARCH STEEL MILLS LTD

Factory Site : KM 16, Along Shagamu-Ikorodu Road, At Ewu Jagun Village, Kamabo Ogijo, Ogun State, Nigeria.

M/s TEE-EM ROWLAND NIGERIA LIMITED

We certify that the material described below fully conforms to NISIT 2004 Chemical Composition and Mechanical Properties of the product as tested in accordance with the scheme of Testing and Inspection contained as per standard

Product		High Tensile Concrete Reinforcement Tinned Steel Bar												Certificate No.		MEM/20/500180					
Condition		Hot Rolled Reinforcing Bars												Date		21/03/2025					
Standard		Conforms to NISIT 2004												Trials No		ILDG 108 XX					
Brand		MON 600-TMT												CHEMICAL ANALYSIS (WT %)				MECHANICAL PROPERTIES			
Size (mm)	QTY (MT)	HEAT NOS	C	Si	Mn	P	S	Cr	Co	Mo	Ni	V	Cu	YS (Mpa)	UTS (Mpa)	UTSN S (Mpa)	Elongatio n % (50)	BEND/ RE BIND TEST			
12MM	60.000	C-34	0.20	0.27	0.70	0.042	0.032	0.22	0.27	<0.005	<0.12	<0.005	0.33	515	625	1.21	20	OK			



21/3/2025

MONARCH STEEL MILLS LTD


Factory Site : KM 16, Along Shagamu-Ikurodu Road, At Ewu-Jagun Village, Kamalo Ogi/O, Ogun State, Nigeria.

N/A TEE-EM ROWLAND NIGERIA LIMITED

We certify that the material described below fully conforms to NISIT 2004 Chemical Composition and Mechanical Properties of the product as tested in accordance with the scheme of Testing and Inspection contained as per standard

MILL TEST CERTIFICATE - MON 500-TMT

MILL TEST CERTIFICATE - MON 500-TMT															Certificate No		NISML/2015092579		
Product High Tensile Concrete Reinforcement: Ribbed Steel Bar Condition Hot Rolled Reinforcing Bars Standards Conforms to NISIT 2004 Brand MON 500-TMT															Date		08/07/2025		
															Truck No		BDG 708 XX		
CHEMICAL ANALYSIS (WT %)															MECHANICAL PROPERTIES				
Size (mm)	QTY (PIC)	HEAT NOS	C	SI	Mn	P	S	Cr	CU	Mo	Ni	V	Co	YS (Mpa)	UTS (Mpa)	UTS/YS RATIO	Elongation % (50)	BEND/RE BEND TEST	
25MM	60,000	C-126	0.15	0.20	0.72	0.032	0.035	0.17	0.21	<0.005	<0.12	<0.005	0.28	520	635	1.22	19	OK	



MONARCH STEEL MILLS LTD

Factory Site: KM 15, Aning Shagari Road, Modupe Estate, Ewu - Egan Village, Kogi State, Nigeria.

By: TEE-EM ROWLAND, NIGERIA LIMITED

As certified by the material, the product is in accordance with the Nigerian Standards and Mechanical Properties of the product as tested in accordance with the standards of Testing and Inspection contained in the standards.

MILL TEST CERTIFICATE - MON 500-TMT

MILL TEST CERTIFICATE - MON 500-TMT														Certificate No.		NEM 202/207509		
High Tensile Corrosion Resistant Mild Steel Bar														Date		22/12/2021		
40mm diameter bar														Batch No		R00108XX		
Equivalent to ASTM A205														MECHANICAL PROPERTIES				
MON 500-TMT																		
CHEMICAL ANALYSIS (Wt %)																		
Size (mm)	Qty (MT)	HEAT NOS.	C	Si	Mn	P	S	Cr	Cu	Mo	Ni	V	Cas	YS (MPa)	TJS (MPa)	UTS (MPa)	Elongation % (50)	GENC. RE-TEST
40MM	40 MT	A-205	0.10	0.02	0.74	0.008	0.045	0.21	0.21	0.005	0.01	0.005	0.01	135	624	118	22	OK




MONARCH STEEL MILLS LTD

Factory Site : KM 16, Along Shagamu-Ikorodu Road, Al Ewu Jagun Village, Kamalo Ojo, Ogun State, Nigeria.

M/s. TEE-EM ROWLAND NIGERIA LIMITED

We certify that the material described below fully conforms to NIS17:2004 Chemical Composition and Mechanical Properties of the product as tested in accordance with the scheme of Testing and Inspection contained as per standard.

Product		High Tensile Concrete Reinforcement Ribbed Steel Bar												Certificate No		MSM/2024-7855		
Condition		Hot Rolled Reinforcing Bar												Date		25/07/2024		
Standard		Conforms to NIS17:2004												Truck No		BDS 708 XX		
Brand		MON 500-TMT																
Size (mm)	QTY (MT)	HEAT NOS	CHEMICAL ANALYSIS (Wt %)											MECHANICAL PROPERTIES				
			C	Si	Mn	P	S	Cr	Cu	Mo	Ni	V	Ceq	YS (Mpa)	UTS (Mpa)	UTS/YS RATIO	Elongation % (50)	SENT / RE-BEND TEST
20MM	60.00	B-125	0.21	0.23	0.69	0.042	0.036	0.22	0.21	<0.005	<0.12	<0.005	0.33	512	619	1.21	19	OK



MONARCH STEEL MILLS LTD

Factory Site : KM 16, Along Shagamu-Ikorodu Road, At Ewu-Jagun Village, Kumbi Ogijo, Ogun State, Nigeria.

M/s. TEE-EM ROWLAND NIGERIA LIMITED

We certify that the material described below fully conforms to NISIT 2004 Chemical Composition and Mechanical Properties of the product as tested in accordance with the scheme of Testing and Inspection contained as per standard.

MILL TEST CERTIFICATE - MON 500-TMT

MILL TEST CERTIFICATE - MON 500-TMT																		
Product : High Tensile Concrete Reinforcement Ribbed Steel Bar														Certificate No		MSML/70251128		
Condition : Hot Rolled Reinforcing Bars														Date		30/04/2025		
Standard : Conforms to NISIT 2004														Truck No		R.D.G 708 XX		
Brand : MON 500-TMT														MECHANICAL PROPERTIES				
Size (mm)	QTY (MT)	HEAT NOS.	CHEMICAL ANALYSIS (WT %)											YS (Mpa)	UTS (Mpa)	UTS/Y S RATIO	Elongatio n % (5D)	BEND/ RE- BEND TEST
			C	Si	Mn	P	S	Cr	Cu	Mo	Ni	V	Ceq					
16MM	60.000	A-155	0.20	0.21	0.74	0.008	0.031	0.21	0.21	<0.005	<0.10	<0.005	0.32	530	635	1.20	19	OK



MONARCH STEEL MILL LTD.
 AUTHORIZED SIGNATURE
 G.A. & O.C.

30/4/2025