

Submitter Details

Name : SPA PUBLIC SCHOOL
Mobile No / Email : 9415039255 / spapublicschool@gmail.com
Sample Id : U1141629L361S288642
Date & time of sample collection: 2022/09/27 15:57
Source of sample : Tube well / Bore well / Well
Entry time : 2022/09/27 16:03
Sample Remarks :

Submitted Test Results

Sr. No.	Test name	Value	Value in Safe Range	Measurement method	Testing time	Entry time
1	Colour	0	yes	Visual comparison method	2022/09/27 16:40	2022/09/27 16:03
2	Turbidity	0.43	yes	Nephelometric method	2022/09/28 12:20	2022/09/27 16:03
3	pH	7.2	yes	Electrometric method	2022/09/27 16:50	2022/09/27 16:03
4	TDS	794	yes	Gravimetric method	2022/09/27 16:50	2022/09/27 16:03
5	Total Alkalinity (as Calcium Carbonate)	444	yes	Titration method	2022/09/28 11:10	2022/09/27 16:03
6	Chloride (as Cl)	98	yes	Argentometric method	2022/09/28 12:20	2022/09/27 16:03
7	Fluoride (as F)	0.31	yes	Ion selective electrode method	2022/09/28 11:25	2022/09/27 16:03
8	Total Hardness (As CaCO ₃)	392	yes	EDTA Titrimetric method	2022/09/28 14:35	2022/09/27 16:03
9	E. coli	0	yes	MFT	2022/09/27 16:40	2022/09/27 16:03
10	Total coliform bacteria	0	yes	MFT	2022/09/27 16:40	2022/09/27 16:03