

			Map of data exchange addresses of the Termodinamica Bridge card (MODBUS Protocol)		IO05-35 Ed. 23 - 2021 Issued by: TDM Technical Office Compatibility from Bridge v.8.14.13 - v.8.14.14
Register Name	Address	Mode	Description	Notes	
REG_BRIDGE_STATUS_FLAGS	0	-	Reserver Register "Bridge Status Flags"	RESERVED	
REG_DIAG_ALL_SPLIT_WRITE_PWR	1	W	ALL Unit Power On/Off 0=OFF 1=ON	Default initialization to all the Air Handler units	
REG_DIAG_ALL_SPLIT_WRITE_SP_ROOM	3	W	ALL Unit SetPoint: (hundredths of degrees Celsius) es: 2300 = 23.00 °C Range: 1800..3000°C	Default initialization to all the Air Handler units (set 1°C steps)	
REG_DIAG_ALL_SPLIT_WRITE_FAN_SPEED	4	W	ALL Unit Fan Speed: 1 = Vel.Night 2 = Vel.1 3 = Vel.2 4 = Vel.3 5 = Vel.4 6 = Vel.5 7 = Vel.6 8 = Vel.Auto	Default initialization to all the Air Handler units	
REG_DIAG_ALL_SPLIT_WRITE_UPDATE	5	W	ALL Unit Update flag: 1=Send Update PWR 2=Send Update SetPoint 4=Send Update Fan Speed 8=Send Update All	Enable sending Initialization selected default to all Air Handler units (Write only after set the 1,3,4 registers)	
REG_DIAG_SPLIT_WRITE_MODE	6	R/W	Unit Function Mode: 4 = Heating 8 = Cooling 16 = Ventilation		
REG_DIAG_SPLIT_WRITE_MODE_MIRROR	7	R/W	Unit Function Mode: 4 = Heating 8 = Cooling 16 = Ventilation	Mirror Addr. 6	
REG_DIAG_SPLIT_WRITE_SELECTION	10	W	Diag Slave Unit Selection Write Address:	Select the slave unit on which you want to update data (Write only after set the 11,12,13 registers)	
REG_DIAG_SPLIT_WRITE_PWR	11	W	Unit Power On/Off 0=OFF 1=ON	Writing to the Air Handler units selected by the register "REG_DIAG_SPLIT_WRITE_SELECTION" (Addr:10)	
REG_DIAG_SPLIT_WRITE_SP_ROOM	12	W	Unit SetPoint: (hundredths of degrees Celsius) es: 2300 = 23.00 °C Range: 1800..3000°C (set 1°C steps)	Writing to the Air Handler units selected by the register "REG_DIAG_SPLIT_WRITE_SELECTION" (Addr:10)	
REG_DIAG_SPLIT_WRITE_FAN_SPEED	13	W	Unit Fan Speed (cabin with SynchSense): 1 = Vel.Night 2 = Vel.1 3 = Vel.2 4 = Vel.3 5 = Vel.4 6 = Vel.5 7 = Vel.6 8 = Vel.Auto Unit Fan Speed (Other case): 1 = Vel.Night 2 = Vel.1 3 = Vel.2 4 = Vel.3 5 = Vel.4 6 = Vel.5 7 = Vel.6 8 = Vel.7 9 = Vel.Auto	Writing to the Air Handler units selected by the register "REG_DIAG_SPLIT_WRITE_SELECTION" (Addr:10)	
REG_ECO_MODE_ENABLE	15	R/W	System in eco mode: 1=OFF 0=ON		
REG_ECO_MODE_ENABLE_MIRROR	16	R/W	System in eco mode: 1=OFF 0=ON	Mirror Addr. 15	
REG_DIAG_SPLIT_HEATER_PWR	17	W	Heater Power On/Off 0=OFF 1=ON	Writing to the Air Handler units selected by the register "REG_DIAG_SPLIT_WRITE_SELECTION" (Addr:10) NOTE: only if available in the unit	
REG_DIAG_SPLIT_AHU_WRITE_MODE	26	W	AHU MODE 16 = Ventilation; 32=Automatic	Writing to the Air Handler units selected by the register "REG_DIAG_SPLIT_WRITE_SELECTION" (Addr:10) NOTE: only if available in the unit	
REG_SYSTEM_DISABLE	30	R/W	Gloabal On/Off System: 1=OFF 0=ON		
REG_SYSTEM_DISABLE_MIRROR	31	R/W	Gloabal On/Off System: 1=OFF 0=ON	Mirror Addr. 30	
REG_SPLIT_ENGINE_BOX_COMPRESSOR_SPEED	140	R	Engine Box Inverter Compressor Speed: (percentage) Range: 0..100% es. 500 = 50.0%		
REG_SPLIT_ENGINE_BOX_WATER_PUMP_SPEED	141	R	Engine Box Inverter Water Pump Speed: (percentage) Range: 0..100% es. 500 = 50.0%		
REG_SPLIT_CURRENT_REQ_PRESSURE	142	R	Engine Box Max Air Handler Required Pressure: (thousandths of Bar) es: 22543 = 22.543 Bar		
REG_SPLIT_ENGINE_BOX_T_SEA_WATER	145	R	Engine Box Sea Water Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C		
REG_SPLIT_ENGINE_BOX_P_GAS	149	R	Engine Box Gas Pressure: (thousandths of Bar) es: 22543 = 22.543 Bar		
REG_SPLIT_ENGINE_BOX_P_LIQUID	150	R	Engine Box Liquid Pressure: (thousandths of Bar) es: 22543 = 22.543 Bar		
REG_SPLIT_ENGINE_BOX_P_CONDENSER	151	R	Engine Box Condenser Pressure: (thousandths of Bar) es: 22543 = 22.543 Bar		
REG_SPLIT_ENGINE_BOX_COMPRESSOR2_SPEED	155	R	Engine Box Inverter Compressor2 Speed: (percentage) Range: 0..100% es. 500 = 50.0%		
REG_ABSORPTION_WATT_AC_COMPRESSOR 1	182	R	Instantaneous absorption control of the AC compressor 1 (1=0.01 Watt)		
REG_ABSORPTION_WATT_AC_COMPRESSOR 2	183	R	Instantaneous absorption control of the AC compressor 2 (1=0.01 Watt)		
REG_ABSORPTION_WATT_SEA_WATER_PUMP	184	R	Instantaneous absorption control of the AC Sea Water Pump (1=0.01 Watt)		
REG_ABSORPTION_AC_COMPRESSOR 1	185	R	Instantaneous absorption control of the AC compressor 1 (1=0.01 Ampere)		
REG_ABSORPTION_AC_COMPRESSOR 2	186	R	Instantaneous absorption control of the AC compressor 2 (1=0.01 Ampere)		
REG_ABSORPTION_SEA_WATER_PUMP	187	R	Instantaneous absorption control of the AC Sea Water Pump (1=0.01 Ampere)		
REG_ACTIVE_ERROR	190	R	General Active Error: bit 0: Engine Box Error bit 1: Split Error bit 2: reserved bit 3: reserved bit 4: not used bit 5: not used bit 6: not used bit 7: not used bit 8: not used bit 9: not used bit 10: not used bit 11: not used bit 12: not used bit 13: not used bit 14: not used bit 15: Cumulative error		

Register Name	Address	Mode	Description	Notes
REG_SPLT_01_READ_PWR	200	R	Unit Power On/Off: 0=OFF 1=ON	
REG_SPLT_01_READ_SP_ROOM	201	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C"	
REG_SPLT_01_READ_FAN_SPEED	202	R	Unit Fan Speed (with Syxthsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLT_01_READ_AIR_IN	203	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLT_01_READ_STATUS	204	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLT_01_AHU_MODE	205	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLT_01_READ_HEATER_PWR	206	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLT_01_READ_HUMI	207	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLT_01_READ_FREE4	208	-	Free 4	
REG_SPLT_01_READ_FREE5	209	-	Free 5	
REG_SPLT_02_READ_PWR	210	R	Unit Power On/Off: 0=OFF 1=ON	
REG_SPLT_02_READ_SP_ROOM	211	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C"	
REG_SPLT_02_READ_FAN_SPEED	212	R	Unit Fan Speed: 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto	
REG_SPLT_02_READ_AIR_IN	213	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLT_02_READ_STATUS	214	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLT_02_AHU_MODE	215	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLT_02_READ_HEATER_PWR	216	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLT_02_READ_HUMI	217	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLT_02_READ_FREE4	218	-	Free 4	
REG_SPLT_02_READ_FREE5	219	-	Free 5	
REG_SPLT_03_READ_PWR	220	R	Unit Power On/Off: 0=OFF 1=ON	
REG_SPLT_03_READ_SP_ROOM	221	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C"	
REG_SPLT_03_READ_FAN_SPEED	222	R	Unit Fan Speed (with Syxthsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLT_03_READ_AIR_IN	223	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLT_03_READ_STATUS	224	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLT_03_AHU_MODE	225	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLT_03_READ_HEATER_PWR	226	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLT_03_READ_HUMI	227	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLT_03_READ_FREE4	228	-	Free 4	
REG_SPLT_03_READ_FREE5	229	-	Free 5	
REG_SPLT_04_READ_PWR	230	R	Unit Power On/Off: 0=OFF 1=ON	
REG_SPLT_04_READ_SP_ROOM	231	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C"	
REG_SPLT_04_READ_FAN_SPEED	232	R	Unit Fan Speed (with Syxthsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLT_04_READ_AIR_IN	233	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLT_04_READ_STATUS	234	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLT_04_AHU_MODE	235	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLT_04_READ_HEATER_PWR	236	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLT_04_READ_HUMI	237	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLT_04_READ_FREE4	238	-	Free 4	
REG_SPLT_04_READ_FREE5	239	-	Free 5	
REG_SPLT_05_READ_PWR	240	R	Unit Power On/Off: 0=OFF 1=ON	
REG_SPLT_05_READ_SP_ROOM	241	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C"	
REG_SPLT_05_READ_FAN_SPEED	242	R	Unit Fan Speed (with Syxthsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLT_05_READ_AIR_IN	243	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLT_05_READ_STATUS	244	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLT_05_AHU_MODE	245	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLT_05_READ_HEATER_PWR	246	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLT_05_READ_HUMI	247	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLT_05_READ_FREE4	248	-	Free 4	
REG_SPLT_05_READ_FREE5	249	-	Free 5	
REG_SPLT_06_READ_PWR	250	R	Unit Power On/Off: 0=OFF 1=ON	
REG_SPLT_06_READ_SP_ROOM	251	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C"	
REG_SPLT_06_READ_FAN_SPEED	252	R	Unit Fan Speed (with Syxthsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLT_06_READ_AIR_IN	253	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLT_06_READ_STATUS	254	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLT_06_AHU_MODE	255	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLT_06_READ_HEATER_PWR	256	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLT_06_READ_HUMI	257	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLT_06_READ_FREE4	258	-	Free 4	
REG_SPLT_06_READ_FREE5	259	-	Free 5	
REG_SPLT_07_READ_PWR	260	R	Unit Power On/Off: 0=OFF 1=ON	
REG_SPLT_07_READ_SP_ROOM	261	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C"	
REG_SPLT_07_READ_FAN_SPEED	262	R	Unit Fan Speed (with Syxthsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLT_07_READ_AIR_IN	263	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLT_07_READ_STATUS	264	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLT_07_AHU_MODE	265	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLT_07_READ_HEATER_PWR	266	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLT_07_READ_HUMI	267	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLT_07_READ_FREE4	268	-	Free 4	
REG_SPLT_07_READ_FREE5	269	-	Free 5	
REG_SPLT_08_READ_PWR	270	R	Unit Power On/Off: 0=OFF 1=ON	
REG_SPLT_08_READ_SP_ROOM	271	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C"	
REG_SPLT_08_READ_FAN_SPEED	272	R	Unit Fan Speed (with Syxthsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLT_08_READ_AIR_IN	273	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLT_08_READ_STATUS	274	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLT_08_AHU_MODE	275	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLT_08_READ_HEATER_PWR	276	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLT_08_READ_HUMI	277	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLT_08_READ_FREE4	278	-	Free 4	
REG_SPLT_08_READ_FREE5	279	-	Free 5	
REG_SPLT_09_READ_PWR	280	R	Unit Power On/Off: 0=OFF 1=ON	
REG_SPLT_09_READ_SP_ROOM	281	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C"	
REG_SPLT_09_READ_FAN_SPEED	282	R	Unit Fan Speed (with Syxthsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLT_09_READ_AIR_IN	283	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLT_09_READ_STATUS	284	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLT_09_AHU_MODE	285	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLT_09_READ_HEATER_PWR	286	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLT_09_READ_HUMI	287	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLT_09_READ_FREE4	288	-	Free 4	
REG_SPLT_09_READ_FREE5	289	-	Free 5	

Register Name	Address	Mode	Description	Notes
REG_SPLUT_10_READ_PWR	290	R	Unit Power On/Off. 0=OFF 1=ON	
REG_SPLUT_10_READ_SP_ROOM	291	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C	
			Unit Fan Speed (with Syxthsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto	
REG_SPLUT_10_READ_FAN_SPEED	292	R	Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLUT_10_READ_AIR_IN	293	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLUT_10_READ_STATUS	294	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLUT_10_AHU_MODE	295	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLUT_10_READ_HEATER_PWR	296	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLUT_10_READ_HUMI	297	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLUT_10_READ_FREE4	298	-	Free 4	
REG_SPLUT_10_READ_FREE5	299	-	Free 5	
REG_SPLUT_11_READ_PWR	300	R	Unit Power On/Off. 0=OFF 1=ON	
REG_SPLUT_11_READ_SP_ROOM	301	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C	
			Unit Fan Speed (with Syxthsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto	
REG_SPLUT_11_READ_FAN_SPEED	302	R	Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLUT_11_READ_AIR_IN	303	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLUT_11_READ_STATUS	304	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLUT_11_AHU_MODE	305	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLUT_11_READ_HEATER_PWR	306	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLUT_11_READ_HUMI	307	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLUT_11_READ_FREE4	308	-	Free 4	
REG_SPLUT_11_READ_FREE5	309	-	Free 5	
REG_SPLUT_12_READ_PWR	310	R	Unit Power On/Off. 0=OFF 1=ON	
REG_SPLUT_12_READ_SP_ROOM	311	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C	
			Unit Fan Speed (with Syxthsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto	
REG_SPLUT_12_READ_FAN_SPEED	312	R	Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLUT_12_READ_AIR_IN	313	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLUT_12_READ_STATUS	314	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLUT_12_READ_AHU_MODE	315	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLUT_12_READ_HEATER_PWR	316	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLUT_12_READ_HUMI	317	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLUT_12_READ_FREE4	318	-	Free 4	
REG_SPLUT_12_READ_FREE5	319	-	Free 5	
REG_SPLUT_13_READ_PWR	320	R	Unit Power On/Off. 0=OFF 1=ON	
REG_SPLUT_13_READ_SP_ROOM	321	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C	
			Unit Fan Speed (with Syxthsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto	
REG_SPLUT_13_READ_FAN_SPEED	322	R	Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLUT_13_READ_AIR_IN	323	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLUT_13_READ_STATUS	324	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLUT_13_AHU_MODE	325	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLUT_13_READ_HEATER_PWR	326	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLUT_13_READ_HUMI	327	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLUT_13_READ_FREE4	328	-	Free 4	
REG_SPLUT_13_READ_FREE5	329	-	Free 5	
REG_SPLUT_14_READ_PWR	330	R	Unit Power On/Off. 0=OFF 1=ON	
REG_SPLUT_14_READ_SP_ROOM	331	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C	
			Unit Fan Speed (with Syxthsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto	
REG_SPLUT_14_READ_FAN_SPEED	332	R	Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLUT_14_READ_AIR_IN	333	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLUT_14_READ_STATUS	334	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLUT_14_AHU_MODE	335	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLUT_14_READ_HEATER_PWR	336	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLUT_14_READ_HUMI	337	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLUT_14_READ_FREE4	338	-	Free 4	
REG_SPLUT_14_READ_FREE5	339	-	Free 5	
REG_SPLUT_15_READ_PWR	340	R	Unit Power On/Off. 0=OFF 1=ON	
REG_SPLUT_15_READ_SP_ROOM	341	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C	
			Unit Fan Speed (with Syxthsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto	
REG_SPLUT_15_READ_FAN_SPEED	342	R	Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLUT_15_READ_AIR_IN	343	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLUT_15_READ_STATUS	344	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLUT_15_AHU_MODE	345	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLUT_15_READ_HEATER_PWR	346	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLUT_15_READ_HUMI	347	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLUT_15_READ_FREE4	348	-	Free 4	
REG_SPLUT_15_READ_FREE5	349	-	Free 5	
REG_SPLUT_16_READ_PWR	350	R	Unit Power On/Off. 0=OFF 1=ON	
REG_SPLUT_16_READ_SP_ROOM	351	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C	
			Unit Fan Speed (with Syxthsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto	
REG_SPLUT_16_READ_FAN_SPEED	352	R	Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLUT_16_READ_AIR_IN	353	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLUT_16_READ_STATUS	354	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLUT_16_AHU_MODE	355	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLUT_16_READ_HEATER_PWR	356	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLUT_16_READ_HUMI	357	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLUT_16_READ_FREE4	358	-	Free 4	
REG_SPLUT_16_READ_FREE5	359	-	Free 5	
REG_SPLUT_17_READ_PWR	360	R	Unit Power On/Off. 0=OFF 1=ON	
REG_SPLUT_17_READ_SP_ROOM	361	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C	
			Unit Fan Speed (with Syxthsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto	
REG_SPLUT_17_READ_FAN_SPEED	362	R	Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLUT_17_READ_AIR_IN	363	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLUT_17_READ_STATUS	364	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLUT_17_AHU_MODE	365	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLUT_17_READ_HEATER_PWR	366	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLUT_17_READ_HUMI	367	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLUT_17_READ_FREE4	368	-	Free 4	
REG_SPLUT_17_READ_FREE5	369	-	Free 5	
REG_SPLUT_18_READ_PWR	370	R	Unit Power On/Off. 0=OFF 1=ON	
REG_SPLUT_18_READ_SP_ROOM	371	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C	
			Unit Fan Speed (with Syxthsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto	
REG_SPLUT_18_READ_FAN_SPEED	372	R	Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLUT_18_READ_AIR_IN	373	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLUT_18_READ_STATUS	374	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLUT_18_AHU_MODE	375	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLUT_18_READ_HEATER_PWR	376	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLUT_18_READ_HUMI	377	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLUT_18_READ_FREE4	378	-	Free 4	
REG_SPLUT_18_READ_FREE5	379	-	Free 5	

Register Name	Address	Mode	Description	Notes
REG_SPLUT_19_READ_PWR	380	R	Unit Power On/Off 0=OFF 1=ON	
REG_SPLUT_19_READ_SP_ROOM	381	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C	
REG_SPLUT_19_READ_FAN_SPEED	382	R	Unit Fan Speed (with Syxtsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLUT_19_READ_AIR_IN	383	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLUT_19_READ_STATUS	384	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLUT_19_AHU_MODE	385	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLUT_19_READ_HEATER_PWR	386	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLUT_19_READ_HUMI	387	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLUT_19_READ_FREE4	388	-	Free 4	
REG_SPLUT_19_READ_FREE5	389	-	Free 5	
REG_SPLUT_20_READ_PWR	390	R	Unit Power On/Off 0=OFF 1=ON	
REG_SPLUT_20_READ_SP_ROOM	391	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C	
REG_SPLUT_20_READ_FAN_SPEED	392	R	Unit Fan Speed (with Syxtsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLUT_20_READ_AIR_IN	393	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLUT_20_READ_STATUS	394	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLUT_20_AHU_MODE	395	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLUT_20_READ_HEATER_PWR	396	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLUT_20_READ_HUMI	397	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLUT_20_READ_FREE4	398	-	Free 4	
REG_SPLUT_20_READ_FREE5	399	-	Free 5	
REG_SPLUT_21_READ_PWR	400	R	Unit Power On/Off 0=OFF 1=ON	
REG_SPLUT_21_READ_SP_ROOM	401	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C	
REG_SPLUT_21_READ_FAN_SPEED	402	R	Unit Fan Speed (with Syxtsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLUT_21_READ_AIR_IN	403	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLUT_21_READ_STATUS	404	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLUT_21_AHU_MODE	405	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLUT_21_READ_HEATER_PWR	406	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLUT_21_READ_HUMI	407	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLUT_21_READ_FREE4	408	-	Free 4	
REG_SPLUT_21_READ_FREE5	409	-	Free 5	
REG_SPLUT_22_READ_PWR	410	R	Unit Power On/Off 0=OFF 1=ON	
REG_SPLUT_22_READ_SP_ROOM	411	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C	
REG_SPLUT_22_READ_FAN_SPEED	412	R	Unit Fan Speed (with Syxtsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLUT_22_READ_AIR_IN	413	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLUT_22_READ_STATUS	414	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLUT_22_AHU_MODE	415	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLUT_22_READ_HEATER_PWR	416	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLUT_22_READ_HUMI	417	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLUT_22_READ_FREE4	418	-	Free 4	
REG_SPLUT_22_READ_FREE5	419	-	Free 5	
REG_SPLUT_23_READ_PWR	420	R	Unit Power On/Off 0=OFF 1=ON	
REG_SPLUT_23_READ_SP_ROOM	421	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C	
REG_SPLUT_23_READ_FAN_SPEED	422	R	Unit Fan Speed (with Syxtsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLUT_23_READ_AIR_IN	423	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLUT_23_READ_STATUS	424	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLUT_23_AHU_MODE	425	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLUT_23_READ_HEATER_PWR	426	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLUT_23_READ_HUMI	427	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLUT_23_READ_FREE4	428	-	Free 4	
REG_SPLUT_23_READ_FREE5	429	-	Free 5	
REG_SPLUT_24_READ_PWR	430	R	Unit Power On/Off 0=OFF 1=ON	
REG_SPLUT_24_READ_SP_ROOM	431	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C	
REG_SPLUT_24_READ_FAN_SPEED	432	R	Unit Fan Speed (with Syxtsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLUT_24_READ_AIR_IN	433	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLUT_24_READ_STATUS	434	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLUT_24_AHU_MODE	435	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLUT_24_READ_HEATER_PWR	436	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLUT_24_READ_HUMI	437	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLUT_24_READ_FREE4	438	-	Free 4	
REG_SPLUT_24_READ_FREE5	439	-	Free 5	
REG_SPLUT_25_READ_PWR	440	R	Unit Power On/Off 0=OFF 1=ON	
REG_SPLUT_25_READ_SP_ROOM	441	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C	
REG_SPLUT_25_READ_FAN_SPEED	442	R	Unit Fan Speed (with Syxtsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLUT_25_READ_AIR_IN	443	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLUT_25_READ_STATUS	444	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLUT_25_AHU_MODE	445	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLUT_25_READ_HEATER_PWR	446	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLUT_25_READ_HUMI	447	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLUT_25_READ_FREE4	448	-	Free 4	
REG_SPLUT_25_READ_FREE5	449	-	Free 5	
REG_SPLUT_26_READ_PWR	450	R	Unit Power On/Off 0=OFF 1=ON	
REG_SPLUT_26_READ_SP_ROOM	451	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C	
REG_SPLUT_26_READ_FAN_SPEED	452	R	Unit Fan Speed (with Syxtsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLUT_26_READ_AIR_IN	453	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLUT_26_READ_STATUS	454	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLUT_26_AHU_MODE	455	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLUT_26_READ_HEATER_PWR	456	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLUT_26_READ_HUMI	457	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLUT_26_READ_FREE4	458	-	Free 4	
REG_SPLUT_26_READ_FREE5	459	-	Free 5	
REG_SPLUT_27_READ_PWR	460	R	Unit Power On/Off 0=OFF 1=ON	
REG_SPLUT_27_READ_SP_ROOM	461	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C	
REG_SPLUT_27_READ_FAN_SPEED	462	R	Unit Fan Speed (with Syxtsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLUT_27_READ_AIR_IN	463	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLUT_27_READ_STATUS	464	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLUT_27_AHU_MODE	465	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLUT_27_READ_HEATER_PWR	466	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLUT_27_READ_HUMI	467	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLUT_27_READ_FREE4	468	-	Free 4	
REG_SPLUT_27_READ_FREE5	469	-	Free 5	

Register Name	Address	Mode	Description	Notes
REG_SPLIT_28_READ_PWR	470	R	Unit Power On/Off 0=OFF 1=ON	
REG_SPLIT_28_READ_SP_ROOM	471	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C"	
REG_SPLIT_28_READ_FAN_SPEED	472	R	Unit Fan Speed (with Syxthsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto	
			Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLIT_28_READ_AIR_IN	473	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLIT_28_READ_STATUS	474	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLIT_28_AHU_MODE	475	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLIT_28_READ_HEATER_PWR	476	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLIT_28_READ_HUMI	477	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLIT_28_READ_FREE4	478	-	Free 4	
REG_SPLIT_28_READ_FREE5	479	-	Free 5	
REG_SPLIT_29_READ_PWR	480	R	Unit Power On/Off 0=OFF 1=ON	
REG_SPLIT_29_READ_SP_ROOM	481	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C"	
REG_SPLIT_29_READ_FAN_SPEED	482	R	Unit Fan Speed (with Syxthsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto	
			Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLIT_29_READ_AIR_IN	483	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLIT_29_READ_STATUS	484	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLIT_29_AHU_MODE	485	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLIT_29_READ_HEATER_PWR	486	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLIT_29_READ_HUMI	487	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLIT_29_READ_FREE4	488	-	Free 4	
REG_SPLIT_29_READ_FREE5	489	-	Free 5	
REG_SPLIT_30_READ_PWR	490	R	Unit Power On/Off 0=OFF 1=ON	
REG_SPLIT_30_READ_SP_ROOM	491	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C"	
REG_SPLIT_30_READ_FAN_SPEED	492	R	Unit Fan Speed (with Syxthsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto	
			Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLIT_30_READ_AIR_IN	493	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLIT_30_READ_STATUS	494	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLIT_30_AHU_MODE	495	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLIT_30_READ_HEATER_PWR	496	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLIT_30_READ_HUMI	497	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLIT_30_READ_FREE4	498	-	Free 4	
REG_SPLIT_30_READ_FREE5	499	-	Free 5	
REG_SPLIT_31_READ_PWR	500	R	Unit Power On/Off 0=OFF 1=ON	
REG_SPLIT_31_READ_SP_ROOM	501	R	Unit SetPoint: (hundredths of degrees Celsius) es: 2350 = 23.50 °C -> Range: 18..30°C"	
REG_SPLIT_31_READ_FAN_SPEED	502	R	Unit Fan Speed (with Syxthsense): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 7=Vel.5; 8=Vel.6; 9=Vel.Auto	
			Unit Fan Speed (in other case): 1=Vel.Night; 2=Vel.1; 3=Vel.2; 4=Vel.3; 5=Vel.4; 6=Vel.5; 7=Vel.6; 8=Vel.7; 9=Vel.Auto	
REG_SPLIT_31_READ_AIR_IN	503	R	Unit Input Air Temperature: (hundredths of degrees Celsius) es: 2350 = 23.50 °C	
REG_SPLIT_31_READ_STATUS	504	R	Diagnostic Split Communication Status: Bit 0=Unit not connected on the bus; Bit 1=Unit connected on the bus; Bit 2=Unit connected on the bus but offline; Bit 3=Unit in error.	
REG_SPLIT_31_AHU_MODE	505	R	AHU State 16 = Ventilation 32=Automatic	Only if Slave Unit is in AHU Mode
REG_SPLIT_31_READ_HEATER_PWR	506	R	Heater State 0 = OFF; 1 = ON	Only if Slave Unit have Heater
REG_SPLIT_31_READ_HUMI	507	R	Humidity 0..100%	Only if Slave Unit have Humidity Probe
REG_SPLIT_31_READ_FREE4	508	-	Free 4	
REG_SPLIT_31_READ_FREE5	509	-	Free 5	
REG_BRIDGE_STATUS_FLAGS	65535		Reserver Register "Bridge Status Flags"	RESERVED