

5.3	Solar inverter control	121
5.3.1	Reference frame transformation	122
	A. Clarke transformation ($abc \rightarrow \alpha\beta$)	122
	B. Park transformation ($\alpha\beta \rightarrow dq$)	123
5.3.2	Grid-connected current control	124
	A. Modeling of the grid current controller	124
	B. Design of the grid current controller	125
5.3.3	PQ Control	128
	A. Modeling of the PQ control	128
	B. Design of the DC-link controller	128
5.3.4	DC-link voltage control	129
	A. Modeling of the DC-link controller	129
	B. Design of the DC-link controller	129
5.4	Case study	130
5.4.1	PI controller for three-phase inverters	130
5.4.2	PR controller for single-phase inverters	135
5.5	Summary	137
	References	137
6	Control strategy for grid-connected solar inverter for IEC standards	141
	<i>Mohammed Ali Khan and Ariya Sangwongwanich</i>	
6.1	LVRT requirement for control	141
6.1.1	Permissible limit for voltage fluctuation	142
6.1.2	Permissible limit for frequency fluctuation	142
6.1.3	Power factor, reactive current injection, and reactive power requirement	144
6.1.4	Overview of LVRT requirement based on grid codes	145
6.2	Control strategy used to meet LVRT standards	148
6.2.1	Generator-side converter	149
	6.2.1.1 Cost function	150
	6.2.1.2 Control algorithm	151
6.2.2	Grid-side converter	151
	6.2.2.1 Inverter modeltationary reference	151
	6.2.2.2 Cost function	154
	6.2.2.3 Current tracking control algorithm and simulation	154
6.2.3	Control structure on symmetrical faults	155
6.2.4	Control structure and minimization function under unbalanced faults	156
6.2.5	Experimental analysis	159
6.3	Anti-islanding requirements for control	162
6.3.1	IEEE Standard for Interconnection and Interoperability of resources and interfaces (IEEE 1547)	162
6.3.2	Utility-interconnected PV inverters—test procedure of islanding prevention measures (IEC 62116)	164