



## TEST CERTIFICATE

TC NO: AFPL/2026-27/3458976

DATE: 2026-07-22

CLIENT NAME: MACLEODS PHARMACEUTICALS LIMITED

CLIENT PO NO: PO-4500019002

PO DATE: 2026-07-04

FILTER SERIAL NUMBER: 484515

TESTING DATE: 2026-07-21

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

|                                                                                                     |                       |                                                                                                               |                 |
|-----------------------------------------------------------------------------------------------------|-----------------------|---------------------------------------------------------------------------------------------------------------|-----------------|
| MANUFACTURER : AIRFIL FILTECH PVT. LTD.                                                             |                       |                                                                                                               |                 |
| TYPE OF FILTER : FINE FILTER - 3 MICRON (FLANGE TYPE)                                               |                       |                                                                                                               |                 |
| PRODUCT DETAILS                                                                                     |                       |                                                                                                               |                 |
| FILTER MEDIA                                                                                        | FILTER CAPACITY       | FILTER DIMENSION                                                                                              | MOC             |
| HDPE + NON-WOVEN SYNTHETIC MEDIA + HDPE                                                             | 2000 CFM              | 610 X 610 X 150 MM                                                                                            | ALUMINIUM       |
| AIR FLOW RATE                                                                                       | INITIAL PRESSURE DROP | FINAL PRESSURE DROP                                                                                           | TEMPERATURE     |
| 2000 CFM                                                                                            | 70 - 80 Pa            | 450 Pa                                                                                                        | AMBIENT         |
| TEST DATA                                                                                           |                       |                                                                                                               |                 |
| TEST AIRFLOW                                                                                        | AIR VELOCITY          |                                                                                                               | AIR TEMPERATURE |
| 2000 CFM                                                                                            | 500 FPM               |                                                                                                               | 25 °C           |
| TEST RESULT                                                                                         |                       |                                                                                                               |                 |
| INITIAL PRESSURE DROP (Pa)                                                                          | EFFICIENCY            |                                                                                                               | FILTER CLASS    |
| 70 ± 5 %                                                                                            | 99% DOWN TO 03 MICRON |                                                                                                               | EU 07           |
| TEST TYPE : BS EN 779                                                                               |                       | INSPECTED BY                                                                                                  |                 |
|                  |                       | <br>Authorised Signatory |                 |
| For Queries Related To TC Please Contact : <a href="mailto:quality@airfil.in">quality@airfil.in</a> |                       |                                                                                                               |                 |