



## TEST CERTIFICATE

TC NO: AFPL/2026-27/3464

DATE: 2026-07-21

CLIENT NAME: MACLEODS PHARMACEUTICALS LIMITED

CLIENT PO NO: PO-4500019002

PO DATE: 2026-07-04

FILTER SERIAL NUMBER: AFPL/2026-27/EU04/7430 TO 7439

TESTING DATE: 2026-07-21

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

|                                                      |                       |                     |             |
|------------------------------------------------------|-----------------------|---------------------|-------------|
| MANUFACTURER : AIRFIL FILTECH PVT. LTD.              |                       |                     |             |
| TYPE OF FILTER : RISER FILTER - 10 MICRON (BOX TYPE) |                       |                     |             |
| PRODUCT DETAILS                                      |                       |                     |             |
| FILTER MEDIA                                         | FILTER CAPACITY       | FILTER DIMENSION    | MOC         |
| HDPE + NON-WOVEN SYNTHETIC MEDIA + HDPE              | 691 CFM               | 585 X440 X 15 MM    | ALUMINIUM   |
| AIR FLOW RATE                                        | INITIAL PRESSURE DROP | FINAL PRESSURE DROP | TEMPERATURE |
| 691 CFM                                              | 40 - 50 Pa            | 150 Pa              | AMBIENT     |
| TEST DATA                                            |                       |                     |             |
| TEST AIRFLOW                                         | AIR VELOCITY          | AIR TEMPERATURE     |             |
| 691 CFM                                              | 250 FPM               | 25 °C               |             |
| TEST RESULT                                          |                       |                     |             |
| INITIAL PRESSURE DROP (Pa)                           | EFFICIENCY            | FILTER CLASS        |             |
| 40 ± 5 %                                             | 99% DOWN TO 10 MICRON | EU 04               |             |
| TEST TYPE : BS EN 779                                |                       |                     |             |



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : [quality@airfil.in](mailto:quality@airfil.in)