



TEST CERTIFICATE

TC NO: AFPL/2026-27/3475

DATE: 2026-07-24

CLIENT NAME: HVAX Technologies Ltd

CLIENT PO NO: HVAX/PO/26-27/0607

PO DATE: 2026-07-20

FILTER SERIAL NUMBER: AFPL/2026-27/H14/7514

TESTING DATE: 2026-07-24

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER AND AEROSOL PHOTOMETER

MANUFACTURER : AIRFIL FILTECH PVT. LTD.			
TYPE OF FILTER : GEAL SEAL MINIPLEAT HEPA FILTER – 0.3 MICRON (BOX TYPE)			
PRODUCT DETAILS			
FILTER MEDIA	FILTER CAPACITY	FILTER DIMENSION	MOC
IMPORTED SUBMICRONIC GLASS FIBRE MEDIA PLEATED BY HOT MELT GLUE	500 CFM	450 X 450 X 150 MM	ALUMINIUM
AIR FLOW RATE	INITIAL PRESSURE DROP	FINAL PRESSURE DROP	TEMPERATURE
500 CFM	250 Pa	600 Pa	AMBIENT
TEST DATA			
TEST AIRFLOW	AIR VELOCITY	AIR TEMPERATURE	
500 CFM	250 FPM	25 °C	
TEST RESULT			
INITIAL PRESSURE DROP (Pa)	EFFICIENCY	FILTER CLASS	
250 ± 5 %	99.997 % DOWN TO 0.3 MICRON	H 14	
TEST TYPE : BS EN 1822			
 INSPECTED BY  Authorised Signatory			
For Queries Related To TC Please Contact : quality@airfil.in			

AIRFIL FILTECH PVT. LTD.

Email : sales@airfil.in | Website : www.airfil.in