



# AIR FILTER

## TEST CERTIFICATE

TC NO: AFPL/2026-27/3498

DATE: 2026-07-27

CLIENT NAME: WARKEM BIOTECH PVT. LTD.

CLIENT PO NO: PO - 4500047835

PO DATE: 2026-07-07

FILTER SERIAL NUMBER: AFPL/2026-27/EU04/7584 TO 7593

TESTING DATE: 2026-07-26

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

|                                                       |                       |                     |                 |
|-------------------------------------------------------|-----------------------|---------------------|-----------------|
| MANUFACTURER : AIRFIL FILTECH PVT. LTD.               |                       |                     |                 |
| TYPE OF FILTER : PRE FILTER - 10 MICRON (FLANGE TYPE) |                       |                     |                 |
| PRODUCT DETAILS                                       |                       |                     |                 |
| FILTER MEDIA                                          | FILTER CAPACITY       | FILTER DIMENSION    | MOC             |
| HDPE + NON-WOVEN SYNTHETIC MEDIA + HDPE               | 2000 CFM              | 610 X 610 X 50 MM   | ALUMINIUM       |
| AIR FLOW RATE                                         | INITIAL PRESSURE DROP | FINAL PRESSURE DROP | TEMPERATURE     |
| 2000 CFM                                              | 40 - 50 Pa            | 150 Pa              | AMBIENT         |
| TEST DATA                                             |                       |                     |                 |
| TEST AIRFLOW                                          | AIR VELOCITY          |                     | AIR TEMPERATURE |
| 2000 CFM                                              | 500 FPM               |                     | 25 °C           |
| TEST RESULT                                           |                       |                     |                 |
| INITIAL PRESSURE DROP (Pa)                            | EFFICIENCY            |                     | FILTER CLASS    |
| 40 ± 5 %                                              | 99% DOWN TO 10 MICRON |                     | EU 04           |
| TEST TYPE : BS EN 779                                 |                       |                     |                 |



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : [quality@airfil.in](mailto:quality@airfil.in)