



AIR FILTER

TEST CERTIFICATE

TC NO: AFPL/2026-27/3545

DATE: 2026-07-30

CLIENT NAME: Samarth Engineering Services

CLIENT PO NO: Samarth Engineering Services

PO DATE: 2026-07-25

FILTER SERIAL NUMBER: AFPL/2026-27/EU04/7896 to 7898

TESTING DATE: 2026-07-30

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

MANUFACTURER : AIRFIL FILTECH PVT. LTD.			
TYPE OF FILTER : PRE FILTER - 10 MICRON (BOX TYPE)			
PRODUCT DETAILS			
FILTER MEDIA	FILTER CAPACITY	FILTER DIMENSION	MOC
HDPE + NON-WOVEN SYNTHETIC MEDIA + HDPE	513 CFM	437 X 437 X 25 MM	PLASTIC
AIR FLOW RATE	INITIAL PRESSURE DROP	FINAL PRESSURE DROP	TEMPERATURE
513 CFM	30 - 40 Pa	513 CFM	AMBIENT
TEST DATA			
TEST AIRFLOW	AIR VELOCITY		AIR TEMPERATURE
513 CFM	250 FPM		25 °C
TEST RESULT			
INITIAL PRESSURE DROP (Pa)	EFFICIENCY		FILTER CLASS
30 ± 5 %	99% DOWN TO 10 MICRON		BS EN 779
TEST TYPE : BS EN 779			



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : quality@airfil.in