



TEST CERTIFICATE

TC NO: AFPL/2026-27/3567

DATE: 2026-07-31

CLIENT NAME: APEX AIRTECH SYSTEMS

CLIENT PO NO: PO-AAS/213/26-27

PO DATE: 2026-07-22

FILTER SERIAL NUMBER: AFPL/2026-27/H14/7992

TESTING DATE: 2026-07-31

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER AND AEROSOL PHOTOMETER

MANUFACTURER : AIRFIL FILTECH PVT. LTD.			
TYPE OF FILTER : GEAL SEAL MINIPLEAT HEPA FILTER – 0.3 MICRON (BOX TYPE)			
PRODUCT DETAILS			
FILTER MEDIA	FILTER CAPACITY	FILTER DIMENSION	MOC
IMPORTED SUBMICRONIC GLASS FIBRE MEDIA PLEATED BY HOT MELT GLUE	1000 CFM	610 X 610 X 105 MM	ALUMINIUM
AIR FLOW RATE	INITIAL PRESSURE DROP	FINAL PRESSURE DROP	TEMPERATURE
1000 CFM	250 Pa	600 Pa	AMBIENT
TEST DATA			
TEST AIRFLOW	AIR VELOCITY		AIR TEMPERATURE
1000 CFM	250 FPM		25 °C
TEST RESULT			
INITIAL PRESSURE DROP (Pa)	EFFICIENCY		FILTER CLASS
250 ± 5 %	99.997 % DOWN TO 0.3 MICRON		H 14
TEST TYPE : BS EN 1822			



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : quality@airfil.in