



# AIR FILTER

## TEST CERTIFICATE

TC NO: AFPL/2026-27/3568

DATE: 2026-07-31

CLIENT NAME: APEX AIRTECH SYSTEMS

CLIENT PO NO: PO-AAS/213/26-27

PO DATE: 2026-07-22

FILTER SERIAL NUMBER: AFPL/2026-27/H14/7993

TESTING DATE: 2026-07-31

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER AND AEROSOL PHOTOMETER

|                                                                          |                             |                     |                 |
|--------------------------------------------------------------------------|-----------------------------|---------------------|-----------------|
| MANUFACTURER : AIRFIL FILTECH PVT. LTD.                                  |                             |                     |                 |
| TYPE OF FILTER : GEAL SEAL MINIPLEAT HEPA FILTER – 0.3 MICRON (BOX TYPE) |                             |                     |                 |
| PRODUCT DETAILS                                                          |                             |                     |                 |
| FILTER MEDIA                                                             | FILTER CAPACITY             | FILTER DIMENSION    | MOC             |
| IMPORTED SUBMICRONIC GLASS FIBRE MEDIA PLEATED BY HOT MELT GLUE          | 1000 CFM                    | 610 X 610 X 105 MM  | ALUMINIUM       |
| AIR FLOW RATE                                                            | INITIAL PRESSURE DROP       | FINAL PRESSURE DROP | TEMPERATURE     |
| 1000 CFM                                                                 | 250 Pa                      | 600 Pa              | AMBIENT         |
| TEST DATA                                                                |                             |                     |                 |
| TEST AIRFLOW                                                             | AIR VELOCITY                |                     | AIR TEMPERATURE |
| 1000 CFM                                                                 | 250 FPM                     |                     | 25 °C           |
| TEST RESULT                                                              |                             |                     |                 |
| INITIAL PRESSURE DROP (Pa)                                               | EFFICIENCY                  |                     | FILTER CLASS    |
| 250 ± 5 %                                                                | 99.997 % DOWN TO 0.3 MICRON |                     | H 14            |
| TEST TYPE : BS EN 1822                                                   |                             |                     |                 |



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : [quality@airfil.in](mailto:quality@airfil.in)