



# AIR FILTER

## TEST CERTIFICATE

TC NO: AFPL/2026-27/3615

DATE: 2026-08-03

CLIENT NAME: Apple Air Engineers, Ahmedabad

CLIENT PO NO: AFT/2026-27/013/AP/R1

PO DATE: 2026-05-13

FILTER SERIAL NUMBER: AFPL/2026-27/EU14/8053

TESTING DATE: 2026-08-02

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER AND AEROSOL PHOTOMETER

|                                                                 |                             |                     |                 |
|-----------------------------------------------------------------|-----------------------------|---------------------|-----------------|
| MANUFACTURER : AIRFIL FILTECH PVT. LTD.                         |                             |                     |                 |
| TYPE OF FILTER : MINIPLEAT HEPA FILTER – 0.3 MICRON (BOX TYPE)  |                             |                     |                 |
| PRODUCT DETAILS                                                 |                             |                     |                 |
| FILTER MEDIA                                                    | FILTER CAPACITY             | FILTER DIMENSION    | MOC             |
| IMPORTED SUBMICRONIC GLASS FIBRE MEDIA PLEATED BY HOT MELT GLUE | 125 CFM                     | 305 X 305 X 69 MM   | ALUMINIUM       |
| AIR FLOW RATE                                                   | INITIAL PRESSURE DROP       | FINAL PRESSURE DROP | TEMPERATURE     |
| 125 CFM                                                         | 250 Pa                      | 600 Pa              | AMBIENT         |
| TEST DATA                                                       |                             |                     |                 |
| TEST AIRFLOW                                                    | AIR VELOCITY                |                     | AIR TEMPERATURE |
| 125 CFM                                                         | 250 FPM                     |                     | 25 °C           |
| TEST RESULT                                                     |                             |                     |                 |
| INITIAL PRESSURE DROP (Pa)                                      | EFFICIENCY                  |                     | FILTER CLASS    |
| 250 ± 5 %                                                       | 99.997 % DOWN TO 0.3 MICRON |                     | EU 14           |
| TEST TYPE : BS EN 1822                                          |                             |                     |                 |



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : [quality@airfil.in](mailto:quality@airfil.in)